

**ANNEXURE. NO. C**  
**PREVENTIVE MAINTENANCE FROM 01.04.2020**

↓  
232



Preventing Maintenance of 132/220/400KV Lines for the period of 01/04/2020 to 30/06/2020.

6 of 7

Sr.No	Name of Transmission Line	Date	From Time		PTW NO.	Detail of Towers which are covered		Remarks (if any)
			From Time	To Time		From Tower No.	To Tower No.	
1	132kv Verka-Pakherpura	01-04-2020	09:00	15:30	686-38	804	834	
2	220 KV GHTP Lehra Mohabbat-Himmatpura-1	01-04-2020	11:15	14:15		1	1	Tree cutting
3	400KV Raipura-NPL ckt-1	01-04-2020	09:53	13:35	19	24	24	Y-ph Jumper Tightening
4	132kv Patti-Sultanpur Lodhi	02-04-2020	08:00	18:00		1	7	Replaced 1 No special clamp at Tower no-24 on R-phase.
5	220KV Mahipur-Jamsher	02-04-20	09:40	16:15	34	Gantry		Tree cutting
6	132 kv Verka-Jandiala	03-04-2020	09:00	16:30	88	33	34	R-Phase hot point attend at Jamsher S-S
7	132 kv Verka-Jandiala	03-04-2020	09:00	16:30	88	52	68	Repair damage conductor
8	132 KV Panigrahi Moga Line	03-04-2020	9:40	18:10	79	291(B-ph), 331 (R&B-ph)		Tree Cutting
9	132Kv Civil Line-Naraingarh	04-04-2020	09:00	16:00		20		flashod Insulator strings changed
10	132Kv civil Line-Power colony	06-04-2020	01:30	15:00		12	41	
11	220KV Raipura-Abawal ckt-2	06-04-2020	08:30	16:40	3	6	18	Tree cutting
12	132kv Verpal-Tam Taran	07-04-2020	09:00	16:00		1	48	Tree cutting
13	220KV G1-G3	07-04-2020	9:30	20:30	36	Gantry	N-A	Replacement of burnt Jumper of Wave trap
14	400KV Fagganrajat(PGCIL)-Nabha ckt-1	07-04-2020	09:00	17:10	6	17	43	Checking & tightening of nut bolts of dead end towers from tower no. 06 to 18
15	220KV Materkotla- Dhuri 1	07-04-2020	10:00	16:00	64		71	Tree cutting
16	220KV Materkotla- Dhuri 2	07-04-2020	10:00	16:00	63			Replacement of nut bolts of dead end towers no-71 to 43
17	220kv Civil line -Fatehgarh chauran	08-04-2020	09:10	17:00		1	38	Checking & tightening of nut bolts of dead end towers no-63
18	220 KV GHTP Lehra Mohabbat-Himmatpura-1	08-04-2020	12:40	13:45	11	116	116	tree cutting & GMTC
19	132 KV Panigrahi Moga Line	08-04-2020	9:15	18:25	48	350	283	B-ph Jumper Tightening
20	132 KV Phillaur Jamalpur line	08-04-20	10:10	16:30	Patrolling	0	52	tree trimming done
21	220KV Raipura-Abawal ckt-2	08-04-2020	09:30	13:50	21	19	56	Ground Maintenance of tower no. from 0 to 52
22	132kv Verpal-Tam Taran	09-04-2020	09:30	16:30		21	39	Checking & tightening of nut bolts of dead end towers from tower no. 19 to 56 alongwith 400 KV S-S Raipura gantry
23	132 KV Panigrahi Moga Line	09-04-2020	9:30	17:25	51	269 (R-ph)		Tree cutting
24	220KV Line Ferozpur-Sadiq	9-4-2020	14:02	16:30	56	65	66	flashed insulator string changed Emergency Tree Cutting done

233

25	220 KV Abkhal-Rajja Ckt	09-04-2020	08:45	18:30	45	69	70	Checking & tightening of nut bolts of flying jumpers between tower no. 69-70
26	132 KV Panigrain Moga Line	10-04-2020	9:40	17:20	52	282(y-ph), 278(y-ph)		Flashed insulator strings changed
27	220KV Bangan-chahtaji	10-04-2020	16:10	22:00	NIR	100	104	Night Patrolling of Line from tower no. 100-104
28	220KV Bangan-Sunam	10-04-2020	16:10	22:00	NIR	14, 14-1, 40		Night Patrolling of Line from tower no. 14, 14-1, 40
29	220kv Bhaiwan-chaaji	10-04-2020	16:10	22:00	NIR	94	99	Night Patrolling of Line from tower no. 94-99
30	132 KV Muktsar Sarenaga Line	11-04-2020	9:15	18:10	3557	447(r-ph), 490(r-ph)		Flashed insulator string changed, jumper tightening done respectively
31	132KV Hoshiarpur-Mahipur ckt-1	11-04-20	13:00	19:10	32	54	54	Y-Phase hot point attend
32	220KV Line Kotkror-Dharamkot Ckt No 1	11-4-2020	09:25	16:50	70	99	103	Jumper Tightened of all the phases of dead end Tower No.99, 102 and 103
33	132 KV Nakkian-Ropar Line	11-04-2020	10:00	17:00	15	74	75	01 no flashed disc insulator replaced at gantry 01 R-phase in lower span no. 74-75
34	132kv Moga-Badhni kalan	11-4-2020	17:55	20:40	54-55	3	4	Breakdown of R-Ph cooductor between Tower No.3-4 attended
35	220 kv Sarao- W Granthiyen Ckt-4	12-04-2020	19:55	12:05	2930	181	181	Hot point attended
36	132KV Hoshiarpur-Mahipur ckt-1	12-04-20	09:05	15:40	33	54	54	R-phase Jumper replace
37	132kv Moga-Badhni kalan	12-4-2020	17:55	20:40	54-56	3	4	Breakdown of R-Ph cooductor between Tower No.3-4 attended
38	220 KV Jaunir-Sunam	13-04-2020	16:10	19:20	75	96	97	Jumper Tightening-Replacement
39	132 KV Panigrain Moga Line	13-04-2020	9:30	17:10	54	306(y-ph)		Flashed insulator string changed
40	220KV Line Makhu-Dharamkot Ckt no. 2	13-4-2020	13:12	16:50	89	61	62	Jumper Tightened of all the phases of Gantry tower
41	220 KV Sunam-Bangan (S. C.)	13-04-2020	10:00	16:00	14	24, 30, 34, 40, 14-36, 14-34, 14-32		Checking & tightening of nut bolts of tower no- 24, 30, 34, 40, 14-36, 14-34, 14-32
42	220 KV Mahali- Majra line	13-04-2020	10:00	17:00	46	188-1, gantry1,		Checking & tightening of nut bolts of jumpers.
43	220 KV Rajpura-Devigarh Ckt-1	13-04-2020	11:45	17:15	23	gantry2, 188-2, 188-4	84	Checking & tightening of nut bolts of dead end towers from tower no. 33 to 84
44	220kv Civil line -Fatehgarh chunan	14-04-2020	09:20	14:02	8	72	9	Hot point Removed
45	132kv Hakima gate -Skkaini bagh	14-04-2020	16:30	23:50		1	36	Night Patrolling & check dead end Tower Hotpoint.
46	132kv Varpal- Hakima Gate	14-04-2020	18:30	23:50		1	7	Night Patrolling & check dead end Tower Hotpoint.
47	220 KV Talwandi Sabo- Maserkhana (Railway)	14-04-2020	15:20	18:41	82	7	7	Jumper Tightening
48	132KV Hoshiarpur-Mahipur ckt-1	14-04-20	16:50	20:40	34	50	60	Patroll the Line dus to Breakdown



48	132 KV Goraya Phikaur Line	14-04-20	11:25	14:15	87	185	198	Checking of Disc Insulator
50	220KV Line Muktsar-Sadiq	14-4-2020	10:30	16:07	578	161	165	Emergency Tree Cutting done
51	220 KV Rip-Jadla Ckt 1&2 Line	14-04-2020	10:00	17:00	38	33,36,37,44		Checking & tightening of nut bolts of jumpers
52	220 kv Sama- W Granthiyain Ckt-4	15-04-2020	6:30	8:17	2931	52	52	Dead end damaged disks replaced
53	132 kv Bataia W granthiyain Ckt-3	15-04-2020	19:50	5:30	54	26	28	Dead end damaged disks replaced
54	132 KV Gidderbaha-Malout	15-04-2020	06:45	12:35	98	5	5	B-ph Disc Insulators replacement
55	132KV Hosharpur-Mahlipur ckt-1	15-04-20	05:30	16:10	34	60	60	Y-Pakse Flash Insulator string replace
56	132KV BBMB JAL -Dhilwan	15-04-20	17:00	18:15	54	239	240	Tree Trimming done
57	220KV Line himmatpura -bedhani kalan and himmatpura jagraon ilo portion	15-4-2020	12:50	13:05	16	84	85	Tightening of jumpers of all the three phases of Tower no. 84 & 85
58	220 KV Sunam-Patnan (S. C.)	15-Apr-20	10:00	16:00	45	gantry		Jumper repaired & tightening of nut bolts of gantry at 220kv s-s Sunam
59	220 KV Bemala- Sanchaur (S. C.)	15-Apr-20	10:00	16:00	81	169		Checking & tightening of nut bolts of tower no. -169
60	220 KV RTP-Koharar line	15-Apr-20	10:00	17:00	39	17	19	Checking & tightening of nut bolts of jumpers
61	220 KV RTP-Jadla Ckt 1&2	15-Apr-20	10:00	17:00	38	16	18	Under PTW No. 38 Tightening of nut bolts of jumpers of 220 KV Rip-Jadla Ckt 1&2 Line from Tower no 15,17,18 was done
62	220 KV Ablowal-Rajla Ckt	15-Apr-20	08:00	18:55	54	1	70	Checking & tightening of nut bolts of dead end towers from tower no. 01 to 70 and from tower no. 1 to 20
63	132kv varpal- Mall mandi	16-04-2020	18:40	22:38		1	38-09	Night Patrolling & check dead end Tower Hotpoint
64	220 KV Jhaur-Sunam	16-04-2020	15:15	16:11	82	36	90	Jumper Tightening
65	132 KV Koikapura-1-Moga	16-04-2020	12:30	22:30	12	27, 29, 30		Jumpers tightening done
66	132 KV Malout-Abohar Line	16-04-2020	12:30	22:30		112-113		emergency tree trimming done
67	220KV JAMALPUR-GANGUWAL	16-04-2020	10:00	15:30	NIL	42	50	Tree cutting, tower checking etc.
68	220kv Line Kotkor-Dharamkot Ckt No. 1and 2	16-4-2020	09:30	16:50	77-79	95	103	Jumper Tightening of all the phases
69	220 KV RTP-Jadla Ckt 1&2 Line	16-Apr-20	10:00	17:00	38	63	65	Checking & tightening of nut bolts of jumpers
70	220 KV Rajpura-Devigath Line	16-Apr-20	09:30	16:40	NR	80	112	Patrolling of ckt from tower no. 80 to 112 and pruning the trees under near the line be done
71	132 KV Muktsar Koikapura 1 Line	17-04-2020	9:30	15:40		280	180	tree trimming done
72	220kv Line Kotkor-Dharamkot Ckt No. 1and 2	17-4-2020	10:30	17:30	77-79	89	95	Jumper Tightening of all the phases

235

73	220 KV Ablowal-Rajla Ckt	17-Apr-20	08:00	17:40	NR	8	58	Line has been patrolled from tower no. 8 to 59 and pruning the trees under-near the line be done Checking & tightening of nut bolts of jumpers.
74	220 KV Nalagarh- Mohali Circuit-1	17-Apr-20	10:00	17:00	54	83,84,87		
75	220kv Patti-Algonkothi	18-04-2020	18:00	00:50		1	64	Night Patrolling & check dead end Tower Hotpoint
76	220 KV Jhuniir-Sunam	18-04-2020	15:52	17:18	49	1	36	Jumper Tightening
77	132 KV Mukisar Jalalabad Line	18-04-2020	8:00	14:50	578			line charged after doing its patrolling
78	132KV Hoshiarpur-Mahilpur ckt-1	18-04-20	06:50	18:30	36	70	70	R-Phase Flash insulator string replace
79	132KV Karlarpur-Beas	18-04-20	7:30	13:05	54	57	59	Patrolled Line After Tripping of line, earth wire break down was cleared between the tower span no. 57-58-59.
80	132KV BBMB JAL-Phagwara	18-04-20	12:30	15:50	55	228	229	Repaired Damaged Earth wire strands between the tower span no. 228 and 229.
81	132 KV Phillaur Jamalpur line	18-04-20	10:50	15:05	76			changing of T-Clamp at Tower No. 132 A
82	220 KV Nalagarh- Mohali Circuit-2	18-Apr-20	10:00	17:00	56	81A, 93, 95		Checking & tightening of nut bolts of jumpers.
83	220kv Bala Chak-Khasasa	19-04-2020	10:00	19:20	43	16,22,28,70		Disc cleaning & dead End jumper nut bolt lightning
84	220 KV Mansa-Sunam	19-04-2020	17:50	18:21	44	38	38	Long piece of cloth removed
85	132 KV Panigrain Moga Line	19-04-2020	9:00	17:30	57	338(b-ph); 335(b-ph)		flushed insulator strings changed
86	132 KV Panigrain Moga Line	20-04-2020	9:00	17:10	58	279(y-ph); 272(y-ph)		flushed insulator strings changed
87	132KV Bhogpur-Hoshiarpur	20-04-20	08:20	14:20		83	86	Patrolling & tree trimming done
88	220KV Line Katkror-Dharamkot Ckt No. 1 and 2	20-4-2020	09:30	16:29	77-79	85 & 105	108	Jumper Tightening of all the phases at Tower No.85 and from 105-108
89	220 KV Ablowal-Rajla Ckt	20-Apr-20	08:00	17:30	NR	57	58	Pruning the trees under-near the line from tower no. 57 to 58.
90	220 KV Malerkotla- Dhur (D.C)	20-Apr-20	08:00	17:00	NR	40	72	Patrolling of Line from tower no. 40 to 72
91	132 KV Asson-Max Line	20-Apr-20	10:00	17:00	57	11,15,16-1,16-4		Checking & tightening of nut bolts of jumpers of 132 KV Asson-Max Line from Tower no 11,16,16-1,16-4 was done
92	400 KV Mukisar Talwandi ckt.1 Line	21-04-2020	10:15	13:20	53	277, 276, 260		Jumper tightening done
93	132KV Chahal-Hoshiarpur	21-04-20	09:10	15:30	62	199-4		Y-Phase hot point attend
94	132KV BBMB JAL -Alwalpur	21-04-20	10:00	12:15	NA	21	29	Tree cutting is done between towers span no 21-22 and 28-29.

236

96	220KV Line Kotkor-Dharamkot Ckt No. 1 and 2.	21-4-2020	09:30	15:50	77-79	38,41,49 & 60	38,41,49 & 60	Jumper Tightening of all the phases at Tower No. 38,41,49 & 60
96	220 KV Mohali-Banur	21-Apr-20	09:00	15:50	NR	46	47	Pruning the trees under-near the line from tower no. 46 to 47 done
97	220 KV Sunam-Patran	21-Apr-20	09:00	17:00	NR	72	108	Patrolling of Line from tower no. 72 to 108
98	Sunam-Bangan	21-Apr-20	09:00	17:00	NR	72	108	Patrolling of Line from tower no. 72 to 108
98	220 KV Nalagarh-Mohali ckt -1	21-Apr-20	10:00	17:00	59	81A,83,85		Checking & tightening of nut bolts of jumpers of 220 KV Nalagarh-Mohali ckt -1 Line
100	132 KV Nakkian s-s-Nakkian Line	21-Apr-20	10:00	17:00	55	1	5	Checking & tightening of nut bolts of jumpers of 132 KV Nakkian s-s-Nakkian Line from Tower no 1,2,3,4,5 and s-s gantry was done
101	132 KV Nakkian-Ropar Line	21-Apr-20	10:00	17:00	57	1	4	Checking & tightening of nut bolts of jumpers of 132 KV Nakkian-Ropar Line from Tower no 1,2,3,4 was done
102	132KV SARNA-GURDASPUR CKT-1&2	22-04-2020	09:25	15:45	.....	585	591	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
103	132 KV Panigrain Moga Line	22-04-2020	8:30	17:30	59	327(y,b-ph), 263(r-ph)	.....	Flashed insulator strings changed
104	132KV Kahampur-Bhogpur	22-04-20	10:32	13:40	6	75	77	Tree cutting is done between towers span no.75-76 and 76-77
105	132KV Ghulial-Jamalpur ckt 1 & 2	22-04-2020	9:50	17:10	NIL	301	370	Patrolling of line from Tower No. 301 to 321 and 341 to 370 and noted down the defects.
106	220 KV Bhalwan- Sunam 1 and 2	22-Apr-20	10:00	16:00	1067	40		Checking & tightening of nut bolts of tower no- 40
107	220 KV RTP-Kharar-Mohali Line	22-Apr-20	10:00	17:00	42	30,34,37A,37B		Checking & tightening of nut bolts of jumpers of 220 KV RTP-Kharar-Mohali Line from Tower no 30,34,37A,37B was done
109	220 KV Mohali-Banur	22-Apr-20	09:00	16:30	NR	28	34	Pruning the trees under-near the line from tower no. 28 to 34 done
109	132 KV KANGRA-PATHANKOT	23-04-2020	09:30	15:35	.....	213	219	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories

237



110	220KV RSD-SARNA CKT-1&2	23-04-2020	09:30	16:30		38	41	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories
111	132 KV Mukaisar-Fandkot Line	23-04-2020	9:50	15:55	580	108-109, 116(R-ph)		earth wire breakdown attended & flashed insulator string replaced at T-118
112	220KV Line Kotkror-Dharankot Ckt No 1 and 2	23-4-2020	10:30	17:30	77-79	21,22,26 & 30	21,22,26 & 30	Jumper Tightening of all the phases at Tower No.21,22,26 & 30
113	400 KV Bhatwa-Talwandi (D C)	43944	08:00	17:00	NR	1	30	Patrolling of Line from tower no. 1 to 30
114	132 KV Kofla -Ropar ckt2 Line	43944	10:00	17:00	48	123, 134, 141, 143, 149, 155		Patrolling of Line and bird nest removed from tower no 123,134,141,143,149,155
115	132KV SARNA-GURDASPUR CKT-1&2	24-04-2020	09:25	16:40		591	588	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
116	132KV KANGRA-SHANAN CKT-1&2	24-04-2020	09:35	15:45		208	213	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
117	220kv civil line - Chogawan	24-04-2020	09:45	16:50		20	40	Tree cutting
118	132 KV Parigrain Moga Line	24-04-2020	8:30	20:10	60	270(b-ph); 252(y-ph)		flashed insulator strings changed
119	220KV Rehansajattan-Jamshar	24-04-20	09:10	16:10	7	72, 73, 79		jumper tightening done
120	220KV Sultanpur-Pathi	24-04-20	10:35	15:10	9	Gantry	113	Replaced damage ACSR zebra conductor of Y-phase between tower no. 113 to Gantry of 220kv s-s Pathi
121	220Kv Badshahpur-Sultanpur	24-04-20	18:35(24:04:20)	11:35(25:4:20)	15	110	110	Replaced Flashed Disc insulators of R-phase at tower no. 110.
122	132kv JAMALPUR-SWADDI	24-04-2020	10:00	16:00	NIL	56	78	Tree cutting, tower checking etc.
123	220KV Line Kotkror-Dharankot Ckt No 1 and 2	24-4-2020	13:50	16:35	77-79	70,75 & 81	89	Jumper Tightening of all the phases at Tower No.70,75,81 & 89
124	220 KV Bhatwan- Dhanaula 1 and 2	43945	10:00	16:00	1070	49, 46, 60		Checking & tightening of nut bolts of tower no- 49,46,60
125	220 KV Ganguwai-mohali line	43945	10:00	17:00	62	143, 149, 160, 160A, 164		Checking & tightening of nut bolts of jumpers.
126	220 KV Mohali-Banur	24-Apr-20	08:00	17:30	NR	15	18	Pruning the trees under-near the line from tower no. 15 to 18 done
127	220kv Khassa-Bala Chak	25-04-2020	09:45	17:00	68	40,65,66		Disc cleaning & dead End jumper nut bolt tightening
128	132KV KANGRA-PATHANKOT CKT-1&2	25-04-2020	09:30	16:02		219	224	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.

238

Sl. No.	Line / Tower / Location	Date	Time	Duration	2932	35	44	Work Description
128	220 KV RSD-SARNA CKT-1	25-04-2020	17:05	2932			44	Jumper reighting and Checking of all tower accessories. Jumper checked
130	132 kv W Granthayan-SHG Pur Ckt2	25-04-2020	15:50	94	25,34,40			
131	220 KV Muktsar Bathinda(DC) Line	25-04-2020	14:35	581	149, 150, 151, 154			jumper tightening done
132	132Kv BBMB JAL -Chidren park	25-04-20	11:35	56	3	3		Flexible conducting wire was removed from Y-phase cross arm at tower no. 3.
133	220kv Ganguwal-G1 and 220kvGanguwal-Bhari	25-04-2020	18:25	NIL	18	20		Tree Cutting between Tower No 18-19 and 19-20
134	220KV G1-G3	25-04-2020	15:45	43	230-03	230-04		Repair of damage conductor between Tower No. 230-03 to 230-04
135	220KV Line Kokror-Dharamkol Ckt No. 1 and 2	25-4-2020	17:01	77-79	103 & 106	107		Jumper Tightening of all the phases at Tower No. 103,106 & 107
136	220 KV Nabha- Bhawanagarh 1	43946	16:00	63	27, 36, 35, 52, 51, 44			Checking & tightening of nut bolts of tower no.27,36,35,52,51,44 and 2no gantry(G3,G4)
137	132 KV Ropar-Asron Line	43946	17:00	53	43	44		Checking & tightening of nut bolts of jumpers
138	220 RTP-Jadla D-Ckt Line	43946	17:00	46	83,88,93,98			Checking & tightening of nut bolts of jumpers
139	220 kv W Granthayan-Sarna Ckt-4	27-04-2020	15:10	2933	14	14		Hot point attended
140	132kv Verka-Pakhepur	27-04-2020	15:50	18	83,78,58,859			Disc cleaning & dead End jumper nut bolt tightening
141	220 KV Muktsar Bathinda(DC) Line	27-04-2020	13:45	2598	147, 146, 138			jumper tightening done
142	132KV SWADDI- MOGA	27-04-2020	16:00	NIL	GANTRY	N-A		Hot point was attended at Moga Sub-station
143	400KV Line Mashtu-Amritsar ckt. 2	27-4-2020	12:45	90	165	165		Hot point attended at Tower No. 165 B-Phase.Also Tightened jumpers of other phases.
144	400KV Line Mashtu-Amritsar ckt. 1	27-4-2020	20:25	91	136	136		Puncture Disc insulator String replaced with new one at Tower no. 136 Y-Ph and charged the faulty line
145	220 KV Sunam-Bangan (S.C.)	27-Apr-20	16:00	55	82, 81, 65, 48			Checking & tightening of nut bolts of tower no: 82,81,65,48
146	220 RTP-Jadla D-Ckt Line	27-Apr-20	17:00	46	101, 102, 107, 113, 114			Checking & tightening of nut bolts of jumpers
147	220 KV Mohali-Banur	27-Apr-20	17:20	NR	9	14		Pruning the trees under-near the line from tower no. 09 to 14 done
148	220 kv W Granthayan- Udoko	28-04-2020	18:15	99	137,138,131,108,118.			Jumper checked

239

5

149	132KV SARNA-GURDASPUR CKT-2	28-04-2020	09:40	16:05	30	550	607	Jumper retightening and Checking of all tower accessories of tower no.550,593,594,607.
150	132KV KANGRA-SHANAN CKT-1&2	28-04-2020	09:20	15:50	.....	203	207	Ground mtc,tree cutting,checking of stubs, checking of all lower accessories.
151	132 KV Muktsar Sarainaga Line	28-04-2020	8:40	15:30	3593	459(r.b-ph), 448(r-ph)		flashed insulator strings changed
152	220KV Bhakra-Mahlipur-2	28-04-20	09:15	16:10	49-118	124, 125, 131		jumper tightening done
153	220kv BBMB JAL.-Alawalpur	28-04-20	8:35	12:40	34	257	257	Replaced Flashed Disc Insulators of y-phase at tower no. 257.
154	220KV SAHNEWAL-RAILWAY	28-04-2020	10:00	16:00	52	GANTRY	19	Re-Sagging of Earth wire at Railway Sub-station was done
155	220kv RTP-G1 ckt 1 & 2	28-04-2020	7:45	18:40	91	30	39	Checking and tightening of Jumper of Tower No. 30,31,32,33,34,35,36,37,38 and 39.
156	220 KV Malerkotla- Dhuan (D.C)	28-Apr-20	09:00	17:00	NR	1	40	Patrolling of Line from tower no. 1 to 40
157	132 KV Ropar-Nakkian Line	28-Apr-20	10:00	17:00	65	7,8,9,11,12		Checking & tightening of nut bolts of jumpers
158	220 RTP-Jadla D-Ckt Line	28-Apr-20	10:00	17:00	46	128, 130, 132, 133		Checking & tightening of nut bolts of jumpers
159	220 KV Rajpura-Mohali Ckt	28-Apr-20	09:00	18:20	37	66	105	Checking & tightening of nut bolts of dead end towers from TL no. 66 to 105
160	220 KV Rajpura-Abtawal(old line)	28-Apr-20	10:00	16:00	NR	13	21	patrolling of idle towers
161	132KV KANGRA-PATHANKOT CKT-1&2	29-04-2020	09:40	16:10	.....	225	230	Ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
162	132KV SARNA-PATHANKOT CKT-1&2	29-04-2020	09:30	16:20	.....	514	520	Ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
163	220 kv Kotli- F G Churnyan Ckt-2	29-04-2020	10:45	17:15	36	79,54,93,102-105-106		Jumper checked
164	132kv Verka-Power Colony	29-04-2020	09:05	14:25	22	1,2,6,10		Disc cleaning & dead End Jumper nut bolt tightening
165	132 KV Muktsar Sarainaga Line	29-04-2020	9:15	15:25	3595	470, 465	.....	flashed insulator strings changed at r ph

240





186	132KV SHANAN-KANGRA CKT-1&2	01-05-2020	09:10	16:20		186	202	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
187	132 KV Kotkapura 1- Moga Line	01-05-2020	9:10	14:30	2752			net point attended at Y-phase of gantry jumper
188	132 KV Muktsar Saranaga Line	01-05-2020	9:10	15:30	3598			flushed strings changed
189	132KV Hosharpur-Mahilpur Line	01-05-20	09:10	16:15		458(R&B-ph)		
190	132 KV Goraya Jamalpur Line	01-05-20	08:10	17:15	Patrolling	9	12	Patrolling & tree trimming done
191	220KV RTP-GHULAL-GAUNSGARH	01-05-2020	10:00	18:00	44,45	23	37	Ground Maintenance
192	220KV G1-Rajpura Ckt 1&2	01-05-2020	9:15	17:50	8	4	19	Tree cutting, tower checking, general mtc.
193	220KV Rajpura-Mohali ckt	01-05-2020	08:00	17:15	47	51	65	Checking of Jumpers of Tower No. 51,56,57,65 and Gantries
194	220KV Materkotla- Dhuri	01-05-2020	10:00	16:00	99	58	62	Checking & tightening of nut bolts of dead end towers from tower no. 29 to 65
195	220 KV Nalagarh- Mohali Circuit-1	01-05-2020	10:00	17:00	74	100, 107, 115 and 140		Earth wire sagging work is done from tower no 58 to 62
196	132KV SHANAN-KANGRA CKT-1&2	02-05-2020	09:10	16:10		191	195	Checking & tightening of nut bolts of jumpers
197	220kv Rashiana -Pati	02-05-2020	10:55	14:55	13	83,77,71,63		ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
198	132 KV Saranaga Kotkapura 2 Line	02-05-2020	14:00	20:10	4612			Disc cleaning & dead End jumper nut bolt tightening
199	220 KV Kartarpur-Kotla Janga	02-05-20	10:10	16:35	Patrolling	428	429	emergency tree trimming done
200	220KV JAMALPUR-GANGLUWAL	02-05-2020	10:00	16:00	NIL	1	20	Ground Maintenance
201	220KV RTP-GHULAL-GAUNSGARH	02-05-2020	10:00	16:00	NIL	226	227	Tree cutting, tower checking, general mtc.
202	220KV G1-Rajpura Ckt 1&2	02-05-2020	10:10	19:30	12	20	32	Tree cutting, tower checking, general mtc.
203	220KV Line Moga-Sadiq	2-5-2020	12:02	15:52	63	74	98	Checking of Jumpers of Tower No. 74,85,91,96 and 98
204	400KV Rajpura-Dhuri ckt-2	02-05-2020	10:06	16:10	30	20,29,37 & 45	20,29,37 & 45	Tightening of jumpers of all the three phases of Tower no. 20, 29, 37 and 45
205	220KV Materkotla- Dhuri	02-05-2020	10:00	16:00	4	1	21	Checking - tightening of nut bolts of dead end towers from tower no. 01 to 21
206	220 KV Nalagarh- Mohali Circuit-2 line	03-05-2020	10:00	17:00	76	100, 107, 115	19	Earth wire sagging work is done from tower no 17 to 19
207	132KV Mall Mandi- G T road	04-05-2020	10:10	14:05	85	1	5	Checking & tightening of nut bolts of jumpers. Disc cleaning & dead End jumper nut bolt tightening

242

208	132KV SHANAN-KANGRA CKT-1&2	04-05-2020	09.15	16.20	.....	183	190	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
209	220 kv Butari -Jaindhar	04-05-2020	10.15	16.20	85	18	20	jumper checked
210	132 KV Mukiser Malout Line	04-05-2020	10.00	13.20	.....	300	391	earth wire breakdown attended
211	132 KV GNDTP Buthinda-MES Camt.	04-05-2020	12.40	18.25	17	18	18	Disc Insulators replacement & Conductor Resagging
212	220KV Rehana-Jaitan-Mahlipur-Jamsher	04-05-20	09.15	16.30	.....	67-1	67-14	Patrolling & tree trimming done
213	220 KV Jamsher-kotla Janga	04-05-20	09.30	16.52	Patrolling	12	25	Ground Maintenance
214	400KV Rajpura-Dhuri ckt-2	04-05-2020	10.03	16.30	31	22	68	Checking - tightening of nut bolts of dead end towers from tower no. 22 to 68
215	220 KV Majra- Mahali	04-05-2020	10.00	17.00	80	188-24, 188-26, 188-27		Checking & tightening of nut bolts of jumpers
216	132 kv DVI-GSP-2	05-05-2020	10.40	16.05	60	523	558	jumper checked
217	132KV KANGRA-PATHANKOT CKT-1&2	05-05-2020	09:20	16:05	.....	483	479	ground mtc, tree cutting, checking of stubs, checking of all tower accessories. And checking of bulgings under the lines
218	220kv Patt- Aigonkolhi	05-05-2020	11:01	15:28	25	16, 19, 29, 52		Disc cleaning & dead End jumper nut bolt tightening
219	132KV SHANAN-KANGRA CKT-1&2	05-05-2020	09:20	16:40	.....	101	105	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
220	220KV Bhakra-Mahlipur-2	05-05-20	09:00	16:50	58	137, 140, 143		jumper tightening done
221	220kv RTP-GHULAL	05-05-2020	10.00	16.00	49	19	19	1No. Flashed Insulator String was replaced with healthy string
222	220KV RTP-G1 ckt 3, 220KV RTP-Bassi Pathana & 220KV G1-Bassi Pathana	05-05-2020	10.40	16.10	NIL	152	203	Patrolling of Line from Tower No. 152 to 203
223	400KV Rajpura-Dhuri ckt-1	05-05-2020	09:14	16:30	32	110	128	Checking - tightening of nut bolts of dead end towers from tower no. 110 to 128
224	132 kv Astron-Ropar line	05-05-2020	10.00	17.00	75	-	-	Emergency shutdown taken
225	132kv Patt- Suliampur lodhi	06-05-2020	10.10	16.05	11	1, 2, 22, 23		Disc cleaning & dead End jumper nut bolt tightening
226	132KV PATHANKOT-SARNA CKT-1&2	06-05-2020	19.35	10.25	.....	480	520	Night Patrolling of line
227	132KV SHANAN-KANGRA CKT-1&2	06-05-2020	09.10	16.30	.....	105	110	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.

243

2



228	132 KV Moga Baghapurana ckt.2	05-05-2020	9:00	20:55	91				1	damaged conductor changed
229	132KV Nawanshehar-Gorayan	05-05-20	08:10	16:50	39	gantry 1, 4, 5, 7				jumpers tightening done
230	400 KV Nakodar-Moga	06-05-20	10:05	15:30	23	430		433		jumpers, corona rings and dampers tightening.
231	220KV RTP-G1 ckt 3, 220kv RTP-Bassi Pathana & 220kv G1-Bassi Pathana	06-05-2020	8:35	17:15	NIL	73		152		Patrolling of Line from Tower No. 73 to 152
232	220 KV Rajpura-Lahu Ckt-2	06-05-2020	10:21	16:30	34			57		Repaired Y-Phase jumper at Tower No-57
233	220KV Malerkotla- Dhun	06-05-2020	10:00	16:00	8	53		56		Earth wire sagging work is done from tower no 53 to 56
234	220 KV Nalagarh- Mohali Circuit-1 line	06-05-2020	10:00	17:00	66	52, 53, 54, 55				Checking & tightening of nut bolts of jumpers.
235	132KV SHANAN-KANGRA CKT-1&2	07-05-2020	09:20	16:25	.....	110		118		ground mtc, tree cutting, checking of stubs, chocking of all tower accessories.
236	132kv Varpal- Hakima gate	07-05-2020	11:11	16:16	5	1, 2, 7, 11				Disc cleaning & dead End jumper nut bolt lightning
237	132kv Verka- Kathunangal	07-05-2020	10:10	14:58	33	860, 848, 836, 816				Disc cleaning & dead End jumper nut bolt lightning
238	132Kv Kapurthala-Khera Mandir	07-05-20	10:30	15:30	NA	21		21		Repaired Damaged Stubs of Tw no.21
239	220KV RTP-GAUNSGARH	07-05-2020	10:00	16:00	53	19		19		1No. Flashed Insulator String was replaced with healthy string
240	220kv RTP-G1 ckt3 and RTP-Bassi Pathana	07-05-2020	10:00	16:10	NIL	20		73		Patrolling from Tower No. 20 to 73
241	220 KV Patran - FTCL Ckt-1	07-05-2020	08:25	16:50	52		168			To attend the hot point of B-phase at tower no-166
242	132 Kv Kotla-Ropar ckt 1	07-05-2020	10:00	17:00	80	1, 2, 3, 4, 5				Checking & tightening of nut bolts of jumpers.
243	132Kv Jandiala- Tangra	08-05-2020	10:36	15:45	58	82, 68-4, 68-3				Disc cleaning & dead End jumper nut bolt lightning
244	132KV SARNA-PATHANKOT CKT- 1&2	08-05-2020	09:00	15:45	.....	511		513		Tree cutting between tower.
245	132 KV GNDTP Bathinda-MES Canal	08-05-2020	19:30	05:45 09:05:20 20	22	37		36		R-ph Disc Insulators replacement & Conductor Resegging
246	132KV Hoshiarpur-Mahiput-1	08-05-20	08:00	18:00	57	65				R-Phase Flash insulator string replace
247	132Kv Kapurthala-Khera Mandir	08-05-20	10:30	15:00	NA	21		21		Repaired Damaged Stubs and Offshoot of Tw no.21
248	400 KV Nakodar-Talwandi Saboo	08-05-20	09:50	16:25	25	431		433		Jumpers, corona rings and dampers tightening.

244

249	220 KV Nakodar-Hosharpur	08-05-20	14:50	59					Jumpers and dampers tightening of Tower No. 61, 56, 50, 44.
250	220KV RTP-GHULAL-GAUNSGARH	08-05-2020	16:00	NIL	60	76			Tree cutting, tower checking, general mtc.
251	220KV RTP-G1 ckt 1 & 2	08-05-2020	17:10	28	1	13			Checking of Jumpers of Tower No. 01, 01A, 02, 04, 06, 07, 08 and 13
252	220 KV Rajpura-Devigarh Ckt-1	08-05-2020	16:20	36	85	117			Checking - tightening of nut bolts of dead end towers from tower no. 85 to 117 along with 220kv 9-s end gantry.
253	220KV Materkotla- Dhuri	08-05-2020	17:00	NR	53	62			Installation of suspension clamps is done from tower no 53 to 62
254	220 KV Nalagarh- Mohall Circuit-2	08-06-2020	17:00	89	48, 49, 50, 52				Checking & tightening of nut bolts of jumpers
255	132KV KANGRA-PATHANKOT CKT-1&2	09-05-2020	16:30	.....	236	245			ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
256	132KV SARNA-PATHANKOT CKT-1&2	09-05-2020	15:40	.....	510	511			heavy tree cutting.
257	132kv Mail Mandi- Varpal	09-05-2020	15:45	45	2, 3, 28, 33				Disc cleaning & dead End jumper nut bolt tightening
258	400 KV Muktsar Tahwandi ckt. 2 Line	09-05-2020	22:30	57	273				flushed insulator strings replacing work started at this dead end tower by bringing its sag down
259	132 KV GNDTP Bathinda-MES Camt	09-05-2020	19:20	23	Gantry No. 2	Gantry No. 2			B-ph Disc Insulators replacement & Conductor Re-sagging
260	132 KV Phalaur Jamalpur line	09-05-20	17:10	Patrolling	0	26			Ground Maintenance
261	400KV Rajpura-Nakodar ckt 1 & 2	09-05-2020	16:30	NIL	120	197			Patrolling from Tower No. 120 to 197
262	220KV RTP-G1 ckt 3 and 220KV RTP-Bassi Pathana	09-05-2020	15:50	NIL	1	19			Patrolling from Tower No. 1 to 19
263	400KV NFL-Nakodar ckt	09-05-2020	16:30	NR	71	72			Joint inspection (with SSE-Railway, Bassi pathana) of railway crossing between Tower no-71-72
264	220 KV Dhanuata-lehra Mohabbat - Dhanuata-Majra	09-05-2020	17:00	NR	44-105, 44-107				Checking & tightening of tower structures of tower no. 44-105, 44-107
265	220 KV RTP-Mohali line	09-05-2020	17:00	80	79, 85, 91, 94 and 105				Checking & tightening of nut bolts of jumpers.
266	400 KV Muktsar Tahwandi ckt. 2 Line	10-05-2020	20:05	.....	273				flushed insulator strings replacing work started at this dead end tower by bringing its sag down

245

R

267	400 KV Talwandi-Mukatsar-2	10-05-2020	05.00	18.00 15.05.20 20	2.00TE+09	22	61	B-ph Disc Insulators replacement & Conductor Resagging
268	132KV Hoshiarpur-Mahilpur-1	10-05-20	08:10	18:00	61	5		B-Phase Flash insulator sitting replace
269	400KV Rajpura-Nakodar ckt 1 & 2	10-05-2020	9:40	17:20	NIL	198	215	Patrolling from Tower No. 198 to 215
270	132kv Hakima gale- Sakkatri bagh	11-05-2020	10:25	16:02	14	1	5	Disc cleaning & dead End jumper nut bolt tightening
271	132KV KANGRA-PATHANKOT CKT-1&2	11-05-2020	09:15	16:50		381	386	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
272	220 kv Sama - Tibber	11-05-2020	10:28	16:30	2939	3	4,8,32,92	jumper checked
273	132 KV Kolkapura1 -Moga Line	11-05-2020	9:05	16:10	10	38		flushed insulator strings changed at Y&B-phases
274	400 KV Mukatsar Talwandi ckt.2 Line	11-05-2020	18:20	22:40	57	273		flushed insulator strings replacing work continued
275	132kv Kapurthala-Khara Mandir	11-05-20	10:30	15:30	NA	21	21	The Re-concrete of Muff-Offshoots is done at Tw No.21
276	400 KV Nakodar-Talwandi Saboo	11-05-20	09:15	17:10	27			Jumpers, corona rings and dampers tightening of Tower No.406,405,398,397.
277	220 KV Jamshar-kolla Janga	11-05-20	09:30	16:52	Patrolling	25	35	Ground Maintenance
278	220KV RTP-GHULAL-GAUNSGARH	11-05-2020	10:00	16:00	NIL	68	70	Tree cutting, tower checking, general mtc.
279	220KV RTP-GT ckt 1 & 2	11-05-2020	9:35	19:00	33	39 A & 16	49	Checking of Jumpers of Ckt 1 of Tower No. 39A,40,41,42,43,44, 45,46,47 & 49 and checking of Jumpers of ckt 2 of Tower No. 16, 17,19,22,42,43,44,45,46,47 & 49.
280	220 KV Bhaeri-Devgarh Ckt-2	11-05-2020	09:00	16:30	67	1	30	Checking & tightening of nut bolts of dead end towers from TL no. 01 to 30 along with 220kv bhatri 5-s end gantry
281	220 KV Ganguwal-Majra line	11-05-2020	10:00	17:00	99	188-24, 188-26, 188-27, 188-32 and 188-33		Checking & tightening of nut bolts of jumpers.
282	132KV SHANAN-KANGRA CKT-2	12-05-2020	09:45	18:10		31	54	Jumper retightening and Checking of all tower accessories of tower no.31,49,50,54
283	132KV SARNA-GURDASPUR CKT-1&2	12-05-2020	09:50	16:55		598	606	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.



284	132kv Butari- Tam Teran	12-05-2020	10:55	16:25	89	1, 4, 5, 8		Disc cleaning & dead End Jumper nut bolt tightening
285	132Kv Civil Line -Power colony	12-05-2020	12:30	14:20	74	14		Disc cleaning & dead End Jumper nut bolt tightening & T. no 14 Blue phase suspension clump tightening.
286	400 KV Muktsar Talwandi ckt.2 Line	12-05-2020	8:30	23:10	.....	273	.....	flashed insulator strings replacing work completed, sagging stringing done & Jumper tightened
287	132KV Nakkian-Nawanshehar	12-05-20	09:20	16:30	.....	79	80	tree trimming done
288	220Kv Jamsher-Jadia	12-05-20	10:30	15:25	82	251	264	Patrolled line after tripping. Disc Insulators were checked from Tw no 251 to 264 and found healthy
289	400 KV Nakodar-Rajpura CKT No.1	12-05-20	11:15	16:20	29			Jumpers corona rings and dampers tightening of Tower
290	220 KV Jamsher-koda Janga	12-05-20	08:50	16:20	Patrolling	35	44	No.338,336,333,332
291	220KV G1-Rajpura Ckt 1	12-05-2020	10:05	18:00	37	1		Ground Maintenance
292	220KV G2-Shari	12-05-2020	9:30	23:30	66	Gantry	N-A	Replacement of damaged Jumper Y-phase at Tower No. 1
293	220 KV Bhaeri-Deviyath Ckt-2	12-05-2020	09:00	16:40	73	31	86	attened hot point of B-phase at Gantry at G2 Sub-Station
294	132 kv Kathunangai -Batala-	13-05-2020	10:30	15:55	4			Checking & tightening of nut bolts of dead end towers from TL no. 31 to 86 along with 220kv s-s devigath end gantry
295	132kv Verka - Jandiala	13-05-2020	09:25	16:30	45	1,2,17,18	793	jumper checked
296	400 KV Muktsar Talwandi ckt.2 Line	13-05-2020	8:20	13:30	.....	.....	.....	Disc cleaning & dead End jumper nut bolt tightening
297	132KV Nakkian-Nawanshehar	13-05-20	09:15	16:40	.....	86	88	flashed insulator strings replacing work completed, sagging stringing done & Jumper tightened
298	220Kv Jamsher-Badhalpur	13-05-20	10:00	14:00	NA	1	33-24	tree trimming done
299	400 KV Nakodar-Rajpura CKT No.2	13-05-20	11:10	16:40	30			Tree cutting is done between towers span no.27-28,28-29 and ground maintenance of towers at tw no. 1,29 and 33-24
300	220 KV Ganguwal-Majra line	13-May-20	10:00	17:00	100	188-2, 188-4, 188-7, 188-13, 188-17 and 188-21		Jumpers, corona rings and dampers tightening of tower No.338,336,333,332 Checking & tightening of nut bolts of jumpers.

247

R

301	220 KV Bhiseri-Devigarh Ckt-1	13-May-20	08:00	16:15	97	55	86	Checking & tightening of nut bolts of dead end towers from TL no. 55 to 86 along with 220kv s-s devigarh end gantry
302	132KV Phagwara-Banga	14-05-20	09:00	16:50	87	2,3,5,28		Jumper tightening done
303	220kv GVK-Sultanpur Ckt 1	14-05-20	13:10	14:12	2086	10	11	Tree cutting is done between tower span no. 10-11
304	220KV RTP-Bassi Pathana	14-05-2020	3:15	22:15	43	72	151-21	Patrolling of line from Tower No. 72 to 151-01 to 151-21 on fault and fix the hanging Jumper at Tower No. 151-21
305	220 KV Barnala - Sandhaur (S.C)	14-May-20	10:00	16:00	5	169, 154, 144, 133 & 133 to 137		Checking & tightening of nut bolts of tower no-169, 154, 144, 133 & Tree cutting- trimming is done between tower no 133 to 137
306	132 KV Aston-Ranbaxy-max line	14-May-20	10:00	17:00	76	16, 17, 19, 22, 24 and 25		Checking & tightening of nut bolts of jumpers.
307	220 KV Rajpura-Devigarh Ckt-2	14-May-20	09:36	16:20	39	1	38	Checking & lightening of nut bolts of dead end towers from TL no. 01 to 38.
308	132KV KANGRA-PATHANKOT CKT-1&2	15-05-2020	09:10	16:55		288	393	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
308	220KV RSD-SHAHPURKANDI CKT-1&2	15-05-2020	09:15	16:04		33	35	heavy tree cutting, And ground maintenance
310	220kv Civil line-Khassa	15-05-2020	11:28	16:40	45	12,15,21,19		Disc cleaning & dead End jumper nut bolt tightening
311	132 KV Gidderbaha-Malout	15-05-2020	16:23	17:59	86	NA	NA	Wave Trap hot point attended at Malout end
312	220 KV PGCIL-kotla Janga	15-05-20	09:20	17:00	Patrolling	40	55	Ground Maintenance
313	220kv Himmatpura-Budhmi kalan	15-5-2020	11:42	16:50	39	6	7	Pilot string suspension clamp tightened of R-Ph from Gantry to tower no. 6 to 7 attended
314	220 KV Barnala- Sandhaur (S. C )	15-May-20	10:00	16:00	17	124, 113, 80, 75, 65 & 133 to 118		Checking & tightening of nut bolts of lower no-124, 113, 80, 75, 65 & Tree cutting- trimming is done between tower no 133 to 118
315	220 KV Rip-Jadla ckt 1&2 line	15-May-20	10:00	17:00	59	19, 26, 33		Checking & lightening of nut bolts of jumpers of from Tower no 19, 26, 33
316	220 KV Rajpura-Devigarh Ckt-2	15-May-20	09:15	16:30	40	39	117	Checking & tightening of nut bolts of dead end towers from TL no. 39 to 117 alongwith 220 KV s-s Devigarh gantry

248

317	220kv Civil line-Fatehgadh charian	16-05-2020	11:15	16:40	49	1,4,10,11		Disc cleaning & dead End jumper nut bolt tightening
318	132KV KANGRA-PATHANKOT CKT-1&2	16-05-2020	09:15	16:50		375	381	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
319	220KV RSD-SHAHPURKANDI CKT-1&2	16-06-2020	09:20	16:04		30	33	heavy tree cutting. And ground maintenance
320	132 KV Muktsar Fardiket Line	16-06-2020	12:05	19:00		73	75	earth wire breakdown attended
321	220 KV Jamshier-kotla Janga	18-05-20	09:35	16:55	Patrolling	1	12	Ground Maintenance
322	220kv Ganguwal-G2 and	16-05-2020	17:15	3:30	NIL	20	61	Night Patrolling of lines from Tower No. 20 to 61
323	220 KV Bamala- Sandhaur (S. C.)	43967	10:00	16:00	30	57,48,38,39-1,39-2,39-5,39-11,39-12 & 57 to 40		Checking & tightening of nut bolts of tower no-57,48,38,39-1,39-2,39-5,39-11,39-12 & Tree cutting- trimming is done between tower no 57 to 40
324	132Kv Power Colony -Civil Line	17-05-2020	09:30	12:10	79	16		Blue phase suspension clump lightning.
325	132kv Sultanpur Lodhi-Patti	17-05-2020	08:00	17:35		44	65	Tree cutting
326	132 KV Muktsar kotkapura 1 line	17-05-2020	9:10	19:05		179		damaged tower stubs repair-welding work attended
327	132KV S-S Phagwara	17-05-20	09:00	18:50	97	Bus bar		33KV B-Phase Busbar Change
328	132kv Patti-Bhukhwind	18-05-2020	10:38	14:25	45	7,15,22,29		Disc cleaning & dead End jumper nut bolt tightening
329	132KV KANGRA-PATHANKOT CKT-1&2	18-05-2020	09:10	16:55		369	374	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
330	132KV SARNA-GURDASPUR CKT-1&2	18-05-2020	09:05	16:40		614	620	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
331	132 KV Sarainaga-Kolkapora2 Line	18-05-2020	9:05	20:50		430		damaged tower stubs repair-welding work attended
332	400 KV Talwandi-Mukatsar-2	18-05-2020	07:30	16:00 19:05:20 20	2.001E+09	165	165	Y-ph Disc Insulators replacement & Conductor Resagging
333	132KV Nawanshehar-Gorayan	18-05-20	09:05	16:50	67	Ganby		R-Phase & Y-Phase hot point attend at Gorayan S-S
334	132KV BBMB JAL-Alawalpur	18-05-20	9:50	15:10	50	31	36	Replaced flashed disc insulators at Tw no.31(R phase), Tw no.32(B phase) and Tw no.36(B phase) and Tree cutting is done between tower span no. 33-34

249

335	220 KV Nakodar-Rehana Jattan	18-05-20	09:00	17:00	Patrolling	1	26	Ground Maintenance and tree cutting of tower no. 4-5,6-7,24-25-26.
336	220 KV Faganmajra-Nabha CKT-1	18-May-20	09:00	17:30	61	72	106	Checking - tightening of nut bolts of dead end towers from TL no 72 to 106
337	220 KV Chhajji-Bangan ckt-1	18-May-20	10:00	16:00	91	151, 150, 148, 141, 133 & 146-147		Checking & tightening of nut bolts of tower no- 151, 150, 148, 141, 133 & Tree cutting- trimming between tower no-146-147
338	220 KV Gangurwal-Majra line	18-May-20	10:00	17:00	1	3, 4, 5, 6, 7, 8 and 9	510A	Checking & tightening of nut bolts of jumpers heavy tree cutting. And ground maintenance
339	132KV SARNA-PATHANKOT CKT-1&2	19-05-2020	09:10	15:40		508	70	Jumper retightening and Checking of all tower accessories of tower no.56,58,60,61,70.
340	132KV SHANAN-KANGRA CKT-2	19-05-2020	09:15	17:50	61	56	226	Disc cleaning & dead End jumper nut bolt lightning
341	220 kv Butan-Varpal	19-05-2020	10:10	16:20	93	209		damaged tower stubs repair-welding work attended
342	132Kv Butan-Ekegadda-Tam Taran	19-05-2020	10:35	15:50	94	9,29,41,56	108	Jumper lightning done
343	132 KV Sarainaga-Kotkaperaz Line	19-05-2020	8:30	18:30		430		Tree cutting is done between towers span no.91-92,92-93,105-106 and 107-108
344	132KV Hosharpur-Mahilpur-1	19-05-20	09:10	16:30	78	9,13,14,16,18		Jumper Tightening of tower no. 29,50
345	220Kv Suitampur-Patti	19-05-20	11:30	16:30	NA	91		Jumper Tightening of tower no. 29,50
346	132 KV Phulaur-Jamalpur	19-05-20	12:24	14:55	71			Jumper Tightening of tower no. 29,50
347	132 KV Goraya Jaisalpur line	19-05-20	12:24	14:55	71			Jumper Tightening of tower no. 7,11,12,18
348	220KV PG-PAKHOWAL	19-05-2020	10:00	16:00	NIL	1	26	Tree cutting, tower checking, general mtc.
349	132kv Ghatal-Samashpur-Sehe	19-05-2020	9:00	16:20	79	11	55	Checking of Jumpers of Tower No 11, 11A, 18, 18A, 20, 20A, 21, 35, 50, 54 & 55
350	220KV Line Moga-baghapurana-2	19-5-2020	11:26	17:04	29	1	Gantry	Conductor replaced with new of B-Ph from Gantry to tower no. 1 attended
351	220 KV Nabha- Bhawangarh 1	19-May-20	10:00	16:00	68	10,13,14,20,21,29,30		Checking & tightening of nut bolts of lower no-10,13,14,20,21,29,30 and 4no gantry
352	220 KV Faganmajra-Nabha Ckt-1	19-May-20	09:00	17:20	7	1 to 17	44 to 71	Checking & tightening of nut bolts of dead end towers from TL no. 1 to 17 and from 44 to 71.



353	220 KV Rajpura-Banur	19-May-20	09:00	17:20	99	-	-	To Attend the hot point on R-Phase wave trap PG clamp at 220 KV s-s Rajpura
354	132kv Patli-Bhikhwind	20-05-2020	10:06	15:10	54	55,62,65,66	Disc cleaning & dead End jumper nut bolt tightening	
355	132KV SHANAN-KANGRA CKT-2	20-05-2020	09:10	18:05	62	65	Jumper relighting and Checking of all tower accessories of tower no.65,66,68,71	
356	132KV SARNA-PATHANKOT CKT-1	20-05-2020	09:20	15:45	54	600	heavy tree cutting between tower no.500-501 and 510A-511	
357	132 KV Mukisar Faridkot & Mukisar Kotkapura2	20-05-2020	8:50	22:20	.....	263,430	damaged tower stubs repair-welding work attended	
358	132KV Phagwara-Banga	20-05-20	09:10	17:20	2	1, 2, 1, 2, 2, 54	jumper lightning done	
359	220kv Goraya-Jadla	20-05-20	10:50	12:30	77	Gantry S-s goraya	Attends hot point of Y-phase clamp(Line side)at Gantry(Goraya S-S)	
360	220KV Rajpura-G1 ckt1	20-05-2020	9:40	17:30	45	3	Tree Cutting between Tower No.03-04,04-05,06-07, 28-29 & 29-30	
361	220KV Line Moga-bejakhana-2	20-5-2020	13:31	17:05	34	1	Conductor replaced with new of R-Ph at tower no. 1 attended and repaired	
362	220 KV Nabha- Bhawanigarh 2	20-May-20	10:00	16:00	75	47,51,52,55,44,36,35,24,22,21 and 4,22,21	Checking & tightening of nut bolts of tower no- 47,51,52,55,44,36,35,24,22,21 and 4no gantry	
363	220 KV RTP-Kharar Line	20-May-20	10:00	17:00	87	48, 49, 52, 55 and 58	Checking & tightening of nut bolts of tower no 48, 49, 52, 55 and 58	
364	400 KV NPL- Nakodar	20-May-20	09:00	16:40	NR	5	Applied rubber seal at towers stubs for protection against corrosion- rust(TL no. 5 to 32)	
365	132KV SARNA-GURDASPUR CKT-1&2	21-05-2020	19:05	01:15	.....	517	Night Patrolling of line	
366	132KV KANGRA-PATHANKOT CKT-1&2	21-05-2020	09:15	16:50	.....	366	ground mic tree cutting,checking of stubs,checking of all tower accessories	
367	220 Sarna- W Granthiyar ckt-2	21-05-2020	10:2	15:26	29&2	65,90	jumper checked	
368	220kv Algonkothi-Patti	21-05-2020	11:35	17:35	52	49,58,60,13	Disc cleaning & dead End jumper nut bolt tightening	
369	132kv Sultanpur Lodhi-Patb	21-05-2020	11:40	17:30	51	47,71,80,91	Disc cleaning & dead End jumper nut bolt tightening	
370	132 KV Mukisar Faridkot Line	21-05-2020	9:05	18:40	.....	26	damaged tower stubs repair-welding work attended	
371	132KV Makkian-Nawanshehar-1	21-05-20	08:50	17:15	56	72,75,79,89	jumper tightening done	

251

372	132Kv BBMB Jal.-Phagwara	21-05-20	9:40	16:30	55	180	199	Tree cutting is done between towers span no. 180-181, 184-185, 186-187, 192-193, 193-194 and 198-199
373	220 KV PGCIL-kolla Janga	21-05-20	09:20	16:10	Permit taken by TLSC	1	6	Jumper Tightening of tower no. 1,2,3,4,5,6.
374	220KV JAMALPUR-GANGUWAL	21-05-2020	10:00	16:00	NIL	64	66	Tree cutting, tower checking, general mtc.
375	132kv Ghulaj-Jamalpur ckt 1 & 2	21-05-2020	9:45	16:50	NIL	367	369	Tree Cutting between Tower No. 367-368 & 368-369
376	220KV G1-Bassi Pathana	21-05-2020	10:20	16:00	47	151-01	151-21	Checking of Jumpers of Tower No. 151-10, 151-13, 151-14, 151-15, 151-16, 151-20 & 151-21 and Tree Cutting between Tower No. 151-152 & 151-6-151-07
377	220KV Line Power grid- Moga-3	21-5-2020	11:00	17:02	35	1.3	1.3	Conductor and Jumper replaced with now of Y-Ph from Gantry to tower no. 1 and Jumper tightening at Tower No.3
378	220 KV Nabha- Bhawanigarh 2	21-May-20	10:00	16:00	70	1,2,5,7,10,13,14,20,27,29,30		Checking & tightening of nut bolts of tower no- 1,2,5,7,10,13,14,20,27,29,30 and 2nd gantry
379	220 KV RTP-Kharar Line	21-May-20	10:00	17:00	67	48, 49, 52, 55 and 58		Checking & tightening of nut bolts of jumpers of from Tower no. 48, 49, 52, 55 and 58
380	400 KV NPL- Nakodar	21-May-20	09:00	17:40	NIR	33	58	Applied rubber seal at towers stubs for protection against corrosion- nuts(TL no. 33 to 58)
381	132KV Tam Taraan- Patti	22-05-2020	10:35	15:40	26	13, 19, 30, 39		Disc cleaning & dead End jumper nut bolt tightening
382	132KV SARNA-PATHANKOT CKT-1&2	22-05-2020	09:15	15:05	.....	480	487	ground mtc including uprooting of weeds, checking of muffs and tree cutting.
383	132KV KANGRA-PATHANKOT CKT-1&2	22-05-2020	09:20	16:55	.....	339	342	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
384	220 kv W Gramfinyan-Sama Ckt-4	22-05-2020	11:4	17:14	38	96	10,11,05,159	Tree cutting
385	220 kv Buhari-Yarpat	22-05-2020	11:4	17:14	38	193	224	Tree cutting
386	132KV Bhogpur-Hoshiarpur	22-05-20	09:00	16:40	.....	1	10	Patrolling & tree trimming done
387	132 KV Phallaur Jamalpur line	22-05-20	15:10	21:20	94	-	-	Replacement of jumper at tower no. 119, red phase.
388	220kv Ganguwal-G2 and 220kv Ganguwal-Bhari	22-05-2020	17:50	3:40	NIL	62	56	Night Patrolling of lines from Tower No. 62 to 96

252



389	132KV Line Moga 1 Interlink ckt 1	22-5-2020	11:30	15:36	37	1	Gantry	Conductor replaced with new of B-Ph Gantry to tower no. 1
390	220 KV Sunam-Bangan (S.C.)	43973	10:00	16:00	10	108, 107A, 91		Checking & tightening of nut bolts of tower no. - 108, 107A, 91
391	132KV SARNA-GURDASPUR CKT-2	23-05-2020	09:15	16:35	36	572	622	Heavy tree looping between tower no. 572-573 and conductor repair between tower no. 621-622
392	132KV KANGRA-PATHANKOT CKT-1&2	23-05-2020	06:20	17:00	.....	363	366	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
393	220 kv Sama - Railway line	23-05-2020	11:15	14:20	2943	23	27	.....
394	132kv Verka-Maji Mandi	23-05-2020	06:55	15:05	59	39, 43		Disc cleaning & dead End jumper nut bolt lightning
395	400 KV Talwandi-Mukatsar-2	23-05-2020	06:00	11:30 27.05.20 20	2.001E+09	165	165	R-ph Disc Insulators replacement & Conductor Resagging
397	400 KV Nakodar Moga	23-05-20	09:12	16:20	Patrolling	241	255	Ground Maintenance
398	132kv Ghujal-Jamalpur ckt 1 & 2	23-05-2020	9:10	16:25	NIL	327	335	Tree Cutting between Tower No. 327-328, 333-334 and 334-335
398	220KV RTP-G1 ckt3	23-05-2020	9:30	18:30	51	68	93	Checking of Jumpers of Tower No. 68, 69, 71, 74, 79, 88, Gantries and 93
398	220 KV Bhalwan -Chhajli (D.C)	43974	09:00	17:00	NR	1 to 40 & 6 to 8		patrolling (Checking) of line is done from tower no- 1 to 40 & Tree trimming-cutting is done from tower no. 6 to 8
400	132kv Verka-Maji Mandi	24-05-2020	09:20	15:30	68	48, 44		Disc cleaning & dead End jumper nut bolt lightning
401	400 KV Muktsar Talwandi ckt.2 Line	24-05-2020	8:30	22:10	61	258	.....	R-ph fault attended by replacing damaged strings
402	132KV Pims-Science city	24-05-20	10:10	16:30	62	50	51	During patrolling of this line founds illegal construction of building between tower span no. 50-51 and Clearance from line is maintained by removing first floor of that building
403	132KV Ghujal-Jamalpur ckt 1 & 2	24-05-2020	8:30	17:35	85	1	370	Checking of jumpers and attended breakdown of Conductor of Ckt 1 from Gantry to Tower No. 370
404	220kv RSD-Sama ckt-1&2	26-05-2020	19:20	01:40	.....	53	101	Night Patrolling of line
405	132KV KANGRA-PATHANKOT CKT-1&2	25-05-2020	08:10	16:50	.....	352	357	ground mtc, tree cutting, checking of stubs, checking of all tower accessories

253

406	132 kv Butari line	25-05-2020	16.2	17.2	80	4	120	Wave trap jumper checked	58.69
407	220 kv Butari-Varpal	25-05-2020	10.3	14.4	1		158	jumper checked	5,7,13,14
408	220kv Varpal-Pakti	25-06-2020	10:50	16:10	78			Disc cleaning & dead End jumper nut bolt lightning	
409	132KV Ghutal-Jamalpur ckt 1 & 2	25-05-2020	9:30	17:00	NIL	340	347	Tree cutting between Tower No. 340-341 & 346-347	
410	220KV G1-G2	25-05-2020	10:50	13:55	91	226	226	attended Hotpoint of lower phase at tower No. 226	
411	400KV Line Makhu-Muktsar Ckt 1	25-5-2020	13:25	17:44	94	239	239	Puncture Disc insulator String replaced with new one at Tower no.239 B-ph and charged the faulty line	
412	132 Kv Butari - Tam Taran	26-05-2020	09:30	14:45	34	72, 80, 93, 94		Disc cleaning & dead End jumper nut bolt lightning	
413	400KV Line Makhu-Muktsar Ckt 1	26-5-2020	13:09	16:20	95	127	127	Puncture Disc insulator String replaced with new one at Tower no.127 B-ph and charged the faulty line	
414	220kv Civil Line-Majitha	27-05-2020	10:18	15:50	10	46-4, 46-8, 46-3, 46-14		Disc cleaning & dead End jumper nut bolt lightning	
415	132KV KANGRA-PATHANKOT CKT-1&2	27-05-2020	09:15	17:10		343	352	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.	
416	220 kv Varpal -WG	27-05-2020	10.4	16	52	131	139	Tree cutting	
417	220 kv Varpal -WG	27-05-2020	10.4	16	52	118	122	Tree cutting	
418	132KV Hamarpur-Chahal	27-05-20	09:00	20:50	72	92,93,94	95,97,108,110	Jumper lightninging done	
419	132 KV Phalaur Jamalpur and 132 KV Goraya Jamalpur lines	27-05-20	09:00	17:20	Patrolling	0	28	Ground Maintenance	
420	220KV Rajpura-G1 Ckt 2	27-05-2020	9:40	16:10	56	Gantry	N-A	Repair Jumper of B-phase at Gantry	
421	220 KV Sunam-Bangan (S.C.)	27-May-20	10:00	16:00	96	14-36, 14-32-14-31 and 14-29-14-30		Jumper repaired of tower no- 14-36 and work on gantry & Tree cutting - lightning between tower no. 14-32-14-31 and 14-29-14-30	
422	400 KV NPL- Nakhodar	27-May-20	09:00	17:10	-	59	76	Applied rubber seal at towers stubs for protection against corrosion- nusk(TL no. 59 to 76)	
423	132Kv Sarma -Gurdapur CKT-1&2	28-05-2020	09:15	16:20		560	565	Heavy free looping between tower no.560-561 and 564-565.	

254

424	132KV KANGRA-PATHANKOT CKT-1&2	28-05-2020	08:15	16:50			332	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
425	132 kv Verka- Pakherpura	28-05-2020	08:10	13:55	73	783		Disc cleaning & dead End jumper nut bolt tightening & tree cutting.
426	220kv Varpal-Patti	28-05-2020	09:55	16:02	81	51, 55, 71, 77		Disc cleaning & dead End jumper nut bolt tightening
427	132KV Nakkian-Nawanshehar	28-05-20	09:00	17:30		28	27	Clear the E-W Breakdown
428	132kv Ghulai-Jamapur ckt 1 & 2	28-05-2020	9:40	17:15	NIL	315	325	Tree cutting between Tower No.315-316, 321-322 & 324-325
429	220kv G2-Bhain	28-05-2020	10:25	14:55	98	191-01	215	Checking of Jumpers of Tower No. 191-01, 191-02, 192, 194,
430	220KV Line Kotkor-Ferozeshah	28-5-2020	11:28	16:01	49	96, 96A, 96B & 126	96, 96A, 96B & 126	Tightening of jumpers of all the three phases of Tower no. 96, 96A, 96B & 126
431	220 KV Rajla-PTCL	28-05-2020	09:00	17:20	-	132	142	Applied rubber seal at towers stubs for protection against corrosion- rust(TL no. 132 to 142)
432	220kv Civil Line-Khassa	29-05-2020	09:15	15:47	64	81, 91, 94, 95		Disc cleaning & dead End jumper nut bolt lightning
433	132Kv Sama -Gurdapur CKT-1&2	29-05-2020	09:20	16:20		573	574	Ground mtc including uprooting of weeds, clear the drain between span.
434	132KV KANGRA-PATHANKOT CKT-1&2	29-05-2020	09:10	17:05		323	326	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
435	220 Sarma- W/Gramthiyan ckt-1	29-05-2020	10:05	17:35	2947	3, 9, 11, 13, 16, 87	12, 41, 46, 171	Tree cutting
436	400 KV Muktesar Talwandi ckt.2 Line	29-05-2020	8:20	22:10	61	228		Damaged strings changed
437	220kv RTP-G1 ckt3	29-05-2020	9:25	18:10	NIL	26	32	Tree cutting between Tower No.26-27, 27-28, 28-30, 30-31 & 31-32
438	220kv Line Moga-Kotkarar ckt -1	29-5-2020	13:20	18:55	55	63, 70 & 71	63, 70 & 71	Tightening of jumpers of all the three phases of Tower no. 63, 70 & 71
439	220 KV Rajla-PTCL CKT	29-05-2020	09:00	22:05	NR	-	-	Pruning the trees under-near the line be done
440	220 kv Udoko	30-05-2020	10:58	12	93			Wave trap jumper checked
441	220KV RSD-SARNA CKT-1&2	30-05-2020	19:10	01:20		1	52	Night Patrolling of line
442	132KV KANGRA-SHANAN CKT-1	30-05-2020	10:35	14:20	63	116	116	attend hot point.
443	220kv Civil line- fatehgarn Churian	30-05-2020	09:00	16:15		38	72	Tree cutting

255

444	220 KV Kartarpur-Kolia Janga	30-05-20	09:10	15:50	on line Permit by Hotline team				Hot point attended by hot line team at tower no. 16 Red phase.
445	220KV RTP-G1 CKT3	30-05-2020	9:30	18:00	65	51	138		Checking of Jumpers of Tower No. 51,54,57,59,62,64, 66,134, 137, 137A, 137B & 138
446	220KV Line ferozepur -Botianwala	30-5-2020	11:15	15:35	3	80-45,80-51,80-54,80-56	80-45,80-51,80-54, 80-58		Tightening of jumpers of all the three phases of Tower no. 80-45, 80-51,80-54 & 80-56.
447	220 KV RTP-Mohali	30-May-20	08:00	18:10	-	-	-		To sag the conductor of ERS tower near Kharar flyover
448	132KV Hosharpur-Mahilpur-1	31-05-20	08:05	16:10	7	13			B-Pahise Flash insulator string replace
449	220Kv Varpal-Path	01-05-2020	08:50	17:10	NA	30	52		Tree cutting
450	132KV KANGRA-PATHANKOT CKT-1&2	01-05-2020	09:10	17:10		312	322		Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
451	220 kv Butari-Jalandhar	01-06-2020	10:1	17:15	9	1,31,43,16,01,07,115			tree cutting
452	132 KV Muktsar Jalandhar Line	01-06-2020	9:00	13:50		1	56		Patrolling & tree trimming done
453	132Kv BBMB Jar.-Phagwara	01-06-20	10:00	15:30	NA	211	216		Tree cutting is done between towers span no.211-212,212-213 and 215-216.
454	132 KV Goraya Phagwara CKT no.2	01-06-20	08:10	17:15	Patrolling	105A	120		Ground Maintenance
455	220KV PGCIL-MEHAL KALAN	01-06-2020	10:00	16:00	NIL	67	73		Tree cutting, tower checking, general mtc.
456	220KV PGCIL-MEHAL KALAN	01-06-2020	10:00	16:00	NIL	81	98		Tree cutting, tower checking, general mtc.
457	220KV RTP-G1 ckt 3 and 220KV RTP-Beasi Pathana	01-06-2020	8:00	15:00	NIL	32	37		Tree cutting between Tower No.32-33,33-34, 34-35,35-36 & 36-37
458	132KV Line Moga - Dhalleke	1-6-2020	10:50	14:45	66	9	10		Tree cutting done between Tower No. 9 and 10 and then line charged
459	400KV Rajpura-Dhuni ckt-2	01-06-2020	09:00	16:40	43	69	93		Checking & lightening of nut bolts of dead end towers. (TL no - 69 to 93)
460	220KV Nabha-Bhaiwan	01-06-2020	10:00	16:00	1076	40,46,53,56,59,61, 62,63 & 53 to 55			Jumper lightened of dead end towers.
461	132 kv Butari -Beas	02-06-2020	10:55	15	11	1,41,14,21,54,164			Tree cutting from 53 to 55
462	132KV SARNA-PATHANKOT CKT-1&2	02-06-2020	08:25	16:20		488	499		tree cutting, checking of stubs, checking of all tower accessories.

256



463	132KV KANGRA-PATHANKOT CKT-1&2	02-06-2020	09:10	16:40		299	311	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
464	132kv Sultanpur Lodhi- Patti	02-06-2020	11:48	15:35	77	54, 56, 57, 59, 40		Disc cleaning & dead End jumper nut bolt tightening
465	132 KV Muktsar Srainaga Line	02-06-2020	10:00	17:05	3661	490(b-ph), 487, 484		jumper tightening done
466	400 KV Muktsar Talwandi ckt.2 Line	02-06-2020	9:20	15:30		273, 267, 258, 228, 185	165	Towers earthing resistance checked
467	220 KV Muktsar-Katorewala from 400kv s-s	02-06-2020	17:10	20:30	64	08-09 (ganby)		changed B-ph suspension clamp
468	132KV Hoshiarpur-Mahilpur-1	02-06-20	06:00	14:10	12	65		Y-Pahse Flash insulator string replace
469	132Kv Khera Mandir-RCF	02-06-20	13:15	16:45	75	18	18	Replaced flashed disc insulators of R phase at Dead end Tw no. 18.
470	220KV PGCIL-MEHAL KALAN	02-06-2020	10:00	16:00	NIL	135	158	Tree cutting, tower checking, general mtc.
471	400KV Rajpura-Dhuri ckt-2	02-06-2020	10:30	16:50	46	94	128	Checking & tightening of nut bolts of dead end towers. (TL no. 94 to 128)
472	400KV Rajja-PTGLCKT	02-06-2020	09:00	17:40	NR	126	151	Joint inspection with AEE-TL Dhun of TL no. 125 & 126 (JILD tower no. 1 of Kakrela)
473	220KV Maierkotla-Malerkotla (P.G.) ckt-1	02-06-2020	10:00	18:00	1	1	2	Jumper lightened of dead end towers- 1 & 2
474	220kv Civil Line -Chogawan	03-06-2020	11:30	16:00	75	29,64		Disc cleaning & dead End jumper nut bolt tightening
475	132KV KANGRA-PATHANKOT CKT-1&2	03-06-2020	09:15	15:50		262	269	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
476	132KV KANGRA-PATHANKOT CKT-1&2	03-06-2020	18:10	22:20		218	281	Night Patrolling of line
477	220 KV Muksar Ghubaya (d-c)	03-06-2020	12:30	16:55		1-34, 42-43		line patrolled & tree trimming done
478	132KV Phagwara-Banga	03-06-20	09:10	16:30		3	5	Tree trimming done
479	220 KV Kartarpur-Kotla Janga	03-06-20	11:05	14:20	61	1	20	Jumper Tightening of tower no. 1,2,3
480	220KV PGCIL-MEHAL KALAN	03-06-2020	10:00	16:00	NIL	110	135	Tree cutting, tower checking, general mtc.
481	220KV Line Kulkror-Sadiq	3-6-2020	11:15	16:55	32	46,49,54,59,64,75 & 78	46,49,54,59,64,75 & 4,75 & 78	Tightening of jumpers of all the three phases of Tower no. 46, 49, 54, 59, 64, 75 & 78

257

482	220KV Dhinaula-Mansa	03-06-2020	10:00	16:00	58	44-46, 44-47, 44-44		Jumper tightened of dead end towers - 44-48, 44-47 change of insulator string of blue phase tower no. 44-44
483	132KV SARNA-GURDASPUR CKT-1&2	04-05-2020	09:30	16:10	.....	517	521	Ground mtc line cutting, checking of stubs, checking of all tower accessories. Night Patrolling of line
484	132KV KANGRA-PATHANKOT CKT-1&2	04-06-2020	17:20	23:40	.....	282	309	
485	132KV KANGRA-PATHANKOT CKT-1&2	04-06-2020	09:15	15:40	.....	246	252	Ground mtc including uprooting of weeds, clear the drain between span.
486	132Kv Verka -Pakhepura	04-06-2020	08:40	13:40	93			T. no 793 Hot point removed
487	220Kv Verpal-Pati	04-06-2020	08:40	13:40	93	96, 10, 31, 09, 112		Disc cleaning & dead End Jumper nut bolt tightening
488	220 KV Muktsar Bathinda(DC)	04-06-2020	9:30	16:30	.....	91	.....	missing members fixing work done
489	132KV Manipur-Jamsher-Rehana Jaitan	04-06-20	09:00	17:05	.....	48	56	Patrolling & tree trimming done
490	132Kv BBMB Jal.-Phagwara	04-06-20	10:25	15:16	41	167	225	Tree cutting is done between towers span no. 167-168, 173-174, 221-222 and 224-225.
491	132 KV Urban Estate Kolla Janga	04-06-20	10:55	15:25	22	-	-	Tree Cutting of tower no. 79-80, 73-72, 65-64, 64-63.
492	220kv PGCIL-MEHAL KALAN	04-06-2020	10:00	16:00	NIL	80	110	Tree cutting, tower checking, general mtc.
493	132kv Ghulal-Doraha	04-06-2020	9:05	16:30	NIL	2	10	Tree Cutting between Tower No. 2-3, 6, 7, 8-9 & 9-10
494	220KV Rajpura-Railway ckt-1	04-06-2020	09:00	16:40	52	1	14	Checking & tightening of nut bolts of dead end towers from tower no. 1 to 14
495	220KV Nabha-BHawan	04-06-2020	10:00	16:00	1077	35, 37 & 38		Jumper tightened of dead end towers - 35, 37 & 38 and jumpers of 2 no. gentry
496	400kv Line Makhu-Amrisar Ckt 1	4-6-2020	16:30	14:31	96	71	71	Puncture Disc insulator String replaced with new one at Tower No. 71 R-ph and charged the faulty line
497	132Kv Verpal - Nainagam	05-06-2020	10:55	14:40	4	2, 3, 14, 22		Disc cleaning & dead End jumper nut bolt lightning
498	132KV KANGRA-PATHANKOT CKT-1&2	05-06-2020	09:10	16:40	.....	260	266	Ground mtc including uprooting of weeds, clear the drain between span.
499	132KV SARNA-PATHANKOT CKT-1&2	05-06-2020	19:40	22:40	.....	480	520	Night Patrolling of line



Sl. No.	Line Name	Date	Time	Duration	Remarks	MB125	MB133	Patrolling & tree trimming done
500	132KV MPH2-Bhogpur - Tandapur	05-06-20	16:30	NA	Patrolling			
501	220KV BBMB Jal-Jamsher ckt1	05-06-20	17:00	NA	Attends hot point of B phase t-clamp at Gantry Jamsher s-s with Hol line team Jal	Gantry Jamsher S-sin		
502	220KV BBMB Jal-Jamsher ckt2	05-06-20	17:00	NA	Attends hot point of R phase clamp at Gantry 5-1 (BBMB side) and R phase clamp (BBMB side) at Tw no.41 with hol line team Jal.	Gantry 5-1	41	
503	220 KV PGCIL-kotla Janga	05-06-20	15:15	88	Jumper Tightening of tower no 3,4,5,9,10,12.			
504	132kv Ghulaj-Doraha	05-06-2020	16:40	NIL	Tree cutting between Tower No.15-18,18-17 & 19-20	15	20	
505	220 KV Rajja-PTCL Ckt	05-06-2020	19:30	60	For conductor repair under span 125-126	125	126	
505	400kv Line Makhu-Amritsar Ckt 1	5-6-2020	14:31	96	Puncture Disc insulator String replaced with new one at Tower No.71 R-ph and charged the faulty line	71	71	
507	132KV SARNA-GURDASPUR CKT-1&2	06-06-2020	00:45	.....	Night Patrolling of line	517	625	
508	220KV Algon kothi -Patti	06-06-2020	17:50		Tree cutting	20	30	
509	132KV Varpal- Hakima Gate	06-06-2020	16:10		Tree cutting	36	18	
510	220 KV PGCIL-kotla Janga	06-06-20	17:40	29	Jumper Tightening of tower no 51,48,47,38,30,12,15,18			
511	220KV RTP-G1 ckt 3 and 220KV RTP-Bassi Pathana	06-06-2020	17:30	NIL	Tree cutting between Tower No.26-27,27-28 & 30-31	26	31	
512	220 KV Sumam-Patran	06-06-2020	16:00	42	change of insulator string of red phase tower no. 95	95		
513	132kv Tam taran-patti	08-06-2020	15:15	56	Disc cleaning & dead End jumper nut bolt tightening	30,39,58,67		
514	132KV KANGRA-PATHANKOT CKT-1&2	08-06-2020	16:10	.....	Ground mtc including uprooting of weeds, clear the drain between span	266	274	
515	132KV KANGRA-PATHANKOT CKT-1&2	08-06-2020	23:40	.....	Night Patrolling of line	312	381	
515	132KV SARNA-GURDASPUR CKT-1&2	08-06-2020	16:40	.....	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.	522	527	
517	132 kv Butan n-Diwana	08-06-2020	16:45	17	jumper checked	120a, 121, 26, 162a		
518	132 KV Makatsar interlink ckt.2	08-06-2020	17:40	3671	y-ph clamp repaired & jumper breakdown attended	wavetrap at s-s		
519	132KV MPH4-Shri Hargobindpur	08-06-20	17:30	.....	Patrolling & tree trimming done	28	46	

257

Handwritten signature

520	132kv Kapurthala-RC#	08-06-20	11.15.	16.15	45	11	11	Patrolled line after tripping and replaced flashed disc insulators of R and Y phase at Tw no 11
521	220KV PGCIL-MEHAL KALAN	08-06-2020	10.00	16.00	NIL	49	66	Tree cutting, tower checking, general mtc.
522	220kv Kotkor-Dharamkot Ckt. 1	8-6-2020	11.40	15.15	83	61,62,66,69,70 & Gantry between 61 & 62	61,62,66,69,70 & Gantry between 61 & 62	Tightening of jumpers of all the three phases of Tower no. 61,62,66,69,70 & Gantry between 61 & 62
523	220KV Rajpura-Railway ckt-2	08-06-2020	09.10	17.00	67	1	14	Checking & tightening of nut bolts of dead end towers from tower no. 1 to 14
524	132 kv Butari-Diwan	09-06-2020	9.5	15	18	165,168,62.		jumper checked
525	132KV KANGRA-PATHANKOT CKT-1&2	09-06-2020	09.20	16.00	.....	274	285	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
525	132KV KANGRA-PATHANKOT CKT-1&2	09-06-2020	16.10	09.50	.....	388	454	Night Patrolling of line
527	132KV SARNA-GURDASPUR CKT-1&2	09-06-2020	09.35	16.45	.....	528	535	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories
528	132kv Sultanpur Lodhi- Pathi	09-06-2020	11:20	15:30	90	1,00,11,11,19,123		Disc cleaning & dead End jumper nut bolt lightning
529	132 V Kotkapura-1 -Moga	09-06-2020	10.00	17.30	.....	155	82	tree trimming done
530	132 KV Panjgrain Moga	09-06-2020	.....	.....	.....	351	305	tree trimming done
531	132KV MPH4-Shri Hargobindpur	09-06-20	09.05	17.10	.....	46	74	Patrolling & tree trimming done
532	132Kv Kapurthala-Khera Mandir	09-06-20	10-30,	15.00	NA	20	39-3	Tree cutting is done between towers span no.20-21,39-1-39-2 and 39-2-39-3
533	132 KV Urban Estate Kotla Janga	09-06-20	11:20	16:30	34	-	-	Replacement Disc insulators on tower no. 72.
534	220KV PGCIL-MEHAL KALAN	09-06-2020	10.00	16.00	NIL	18	38	Tree cutting, tower checking, general mtc.
535	220kv line Bajakhana- Baghapurana	9-6-2020	14.57	14:05	79	105,85 & 89	105,85 & 89	Tightening of jumpers of all the three phases of Tower no. 105,85 & 89
536	220 KV Ablawal-Passana CKT	09-06-2020	09.10	16.30	67	1	30	Checking & tightening of nut bolts of dead end towers from tower no. 1 to 30 and LILO tower no. 1 to 5
537	220 KV Nabha-Bhawanigarh ckt-1	09-06-2020	10.00	16.00	9	21		Jumper tightened of dead end towers - 21 and jumpers of 2 no. gantry

260

538	132kv Varpal-Mall Mandi	10-06-2020	11:35	17:25	94	34,35		Disc cleaning & dead End jumper nut bolt tightening
539	132KV KANGRA-PATHANKOT CKT-1&2	10-06-2020	09:10	16:30		286	292	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
540	132KV SARNA-GURDASPUR CKT-1&2	10-06-2020	09:38	16:45		536	544	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
541	132 V Kotkapura-1 -Moga	10-06-2020	9:30	17:05		82	30	tree trimming done
542	132KV Panjgram moga	10-06-2020				305	246	tree trimming done
543	132KV Bhogpur-Hoshiarpur	10-06-20	08:00	17:10		10	19	Patrolling & tree trimming done
544	220KV NAKODAR-LADOWAL	10-06-2020	10:00	16:00	NIL	1	28	Tree cutting, tower checking, general mtc.
545	220kv line Muktsar -Sandhwan	10-6-2020	11:05	16:49	588	185	208	Tightening of jumpers of all the three phases of Tower no. 193 and patrolling done from: 186 to 208
546	400 KV Rajpura-Dhua CKT-1 & 2	10-06-2020	13:15	20:30	NR	158	182	Checking & tightening of nut bolts of towers, their members, foundations, fittings and pruning of trees under-nearby ckt if any
547	132KV KANGRA-PATHANKOT CKT-1&2	11-06-2020	09:10	16:00		292	299	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
548	132 kv Butari-Diwari	11-06-2020	9:28	15	18	1,71,17,21,73,174		Tree cutting
549	132KV KANGRA-SHANAN CKT-1&2	11-06-2020	18:30	23:50		57	116	Night Patrolling of line
550	132KV SARNA-GURDASPUR CKT-1&2	11-06-2020	09:25	16:25		545	551	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
551	132kv Varpal-Mall Mandi	11-06-2020	08:35	15:35		19	28	Tree cutting
552	132 KV Malout Abohar	11-06-2020	9:00	15:05		1	135	tree trimming done
553	132KV Hamirpur-Chahal	11-06-20	17:10	17:10	79	31		Y-Phase hot point attend
554	132Kv Alawalpur-Bhogpur	11-06-20	10:35	11:35	85	Gantry Alawalpur	Gantry Alawalpur	Attends hot point of Y phase wavetrap lower clamp at Gantry Alawalpur s-s
555	220Kv BBMB JAL -Alawalpur	11-06-20	12:30	13:30	87	Gantry(Alawalpur s-s)	253-6	Attends hot point of R phase t-clamp(the side) at Gantry Alawalpur s-s and tree cutting is done between tower no.253-8-253-9.
556	132 KV Goraya Phillaur	11-06-20	09:10	18:30	Patrolling	135	151	Ground Maintenance
557	220KV NAKODAR-LADOWAL	11-06-2020	10:00	16:00	NIL	30	62	Tree cutting, tower checking, general mtc.

261

✓



Sl. No.	Location / Project Name	Date	Start Time	End Time	NR	Manpower	Material	Remarks
555	400 KV Rajpura-Dhuri CKT-1 & 2	11-06-2020	08:30	19:00	NR	158		Checking & tightening of nut bolts of towers, their members, foundations, fittings and pruning of trees under-nearby ckt if any
559	132Kv Varpal-Hakina gate Ckt 1& 2	12-06-2020	10:20	22:40	70, 28	12, 13, 36, Gantery		T. no 12, 13, Disc insulator String replace, T. 35 Hot point removes & Gantery Jumper replaced
560	132KV KANGRA -SHANAN CKT-1&2	12-06-2020	08:15	15:50		160		Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
561	132KV KANGRA -SHANAN CKT-1&2	12-06-2020	18:10	00:01		121		Night Patrolling of line
562	132KV SARNA, GURDASPUR CKT-1&2	12-06-2020	10:05	16:20		552		Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
563	132 KV Ferozpur sadiq	12-06-2020	9:20	16:30		1	84	tree trimming done
564	132KV Chohal-Hoshiarpur	12-06-20	08:10	16:00		212	216	Patrolling & tree trimming done
565	132Kv Pims-Science city	12-06-20	10:00	15:30	NA	45	52	Tree cutting is done between towers span no. 45-46, 46-47, 47-48 and 51-52
566	220KV NAKODAR-LADOWAL	12-06-2020	10:00	16:00	NIL	62	95	Tree cutting, tower checking, general mtc.
567	220KV RTP-G1 ckt 3 and 220KV RTP-Bassi Pathana	12-06-2020	9:30	17:00	NIL	36	38	Tree Cutting between Tower No. 36-37 & 37-38
568	220KV Line Kotkor-Dharamkot ckt -1	12-6-2020	10:40	16:45	78	60, 86	60, 86	Hot point abended at Tower No. 60 of Y-Ph, Also Tightening of Jumpers at Tower No. 86
569	132KV KANGRA -SHANAN CKT-1&2	13-06-2020	09:45	17:00		153	150	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories
570	220Kv Civil line -Fatehgarh Churian	13-06-2020	08:35	21:00		16	38	Tree cutting
571	220KV RTP-G1 ckt 3 and 220KV RTP-Bassi Pathana	13-08-2020	9:10	19:40	NIL	84	98	Tree cutting between Tower No. 84-85, 91-92 & 97-98
572	220KV Moga-Badhni Kailan	13-6-2020	11:10	17:35	51	45	45	Rail Post No. 45 suspension clamp pin put in and line charged
573	132KV SARNA-GURDASPUR CKT-1&2	14-06-2020	12:15	18:05		517	626	Check the clearance of L T-HT lines from lower no. 517 to 528, 565 to 526.
574	132KV KANGRA -SHANAN CKT-1&2	15-06-2020	09:15	16:40		145	148	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
575	132KV KANGRA-PATHANKOT CKT-1	15-06-2020	09:15	17:55		463	479	check the dip of Conductor and clearance of buildings

262



576	132kv Varpal-Mali Mandi	15-06-2020	11:25	12:30	36,38			Disc cleaning & dead End jumper nut bolt tightening
577	220 KV Jhunjir-Surnam	15-06-2020	18:34	19:47	36	91	36	Y-ph hot point attended
578	132Kv Kapurthala-Science city	15-06-20	10:39	15:30	101	NA	108	Tree cutting is done between towers span no.101-102,102-103 and 108-109
579	132 KV Goraya Noormahal	15-06-20	12:01	15:12		52		Jumper Tightening of tower no. 1,2,5,7,8
580	220 KV Faganmajra-Nabha Ckt-2	15-Jun-20	15:30	01:40(16:06:20)		25		For displacement of B-phase jumper from gantry to L&E S-W and repair of R-phase of jumper.
581	132Kv Varpal- Hakina Gale Ckt 1	16-06-2020	08:25	13:10	21,28,30,31			Disc cleaning & dead End jumper nut bolt tightening
582	132KV KANGRA -SHAMAN CKT-1&2	16-06-2020	09:10	17:10	139		145	Ground mtc,tree cutting,checking of stubs,checking of all tower accessories
583	132KV SARNA-GURDASPUR CKT-1&2	16-06-2020	10:00	16:25	579		583	Ground mtc,tree cutting,checking of stubs,checking of all tower accessories
584	132 KV Malout Abohar	16-06-2020	9:00	15:45	135		270	tree trimming done
585	132KV MPH4-Shri Hargobindpur	16-06-20	09:10	17:00	74		93	Patrolling & tree trimming done
586	132KV Hamirpur-Chohal	16-06-20	08:10	16:20	Gantry	81		Y-Phase hot point attend' at Chohal S-S
587	132 KV Goraya Phillaur	16-06-20	11:10	14:35		56		Replacement Disc insulators on tower no. 152&153.
588	220KV NAKODAR-LADOWAL	16-06-2020	10:00	16:00	95	NIL	128	Tree cutting, tower checking, general mtc.
589	132 KV SARNA-PATHANKOT CKT-1&2	17-06-2020	10:20	15:00	480		518	check the dip of Conductor and clearance of buildings
590	132 kv Batala -Pakharpur	17-06-2020	17:55	21:05		23		Wave trap jumper set bright at Pakharpur
591	220Kv Patti- Algonkothi	17-06-2020	08:40	16:48	1		20	Tree cutting
592	220 KV Muktsar Ghubaya (s-c)	17-06-2020	9:35	15:45	1		117	tree trimming done
593	132KV MPH4-Shri Hargobindpur-2	17-06-20	08:00	22:10	72	63		B-Phase Flash insulator string replace
594	132Kv Pima-Science city	17-06-20	10:43	16:15	42	79	49	Tree cutting is done between towers span no.42-43,43-44 and 48-49.
595	400 KV Nakodar Makhu	17-06-20	09:00	16:50	1	Patrolling	25	Ground Maintenance
596	220KV PGCIL-MEHAL KALAN	17-06-2020	10:00	16:00	1	NIL	18	Tree cutting, tower checking, general mtc.
597	220 KV Ablowat-Passiana CKT	17-Jun-20	09:30	16:50				To attend hot point at tower no. 1 Y. phase and 10 B-phase

263



598	400 KV Rajpura-Dhuri Ckt-1 & 2	17-Jun-20	08:30	18:50					Checking & tightening of nut bolts of towers, their members, foundations, fittings and pruning of trees under-nearby ckt if any
599	132Kv Varpal- naraingarh ckt 1	18-06-2020	11:03	17:58		30.39.50.51			Disc cleaning & dead End jumper nut bolt tightening
600	132KV KANGRA-PATHANKOT CKT-1&2	18-06-2020	09:10	17:10		441	450		Ground mtc, tree cutting, checking of stubs, checking of all tower accessories
601	220 KV Katorewala LJLO	18-06-2020	9:10	17:00		35	74		tree trimming done
602	132 KV Sadiq Fandkot	18-06-2020	8:00	14:30		1	57		tree trimming done
603	220KV Bhakra-Mahlipur-2	18-06-20	05:00	17:30	28-119	92			R-Pahse Flash insulator string replace
604	132Kv BBMB Jal.-Urban Estate	18-06-20	9:30	14:30	NA	8	21		Tree cutting is done between towers span no. 9, 10-11, 18-19 and 20-21.
605	220 KV Jamsher-kofia Janga	18-06-20	10:10	16:40	Patrolling				Ground Maintenance and tree cutting between tower no. 44-45, 1-2, 7-8, 32-31
606	400KV Line Makhu-Amrisar Ckt 1	18-6-2020	09:49	16:50	100	74	78.887		Tightening of jumpers of all the three phases of Tower no. 74, 75, 76, 78& 87
607	132KV KANGRA-PATHANKOT CKT-1&2	19-06-2020	09:00	17:20		431	441		Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
608	132 kv W.G - Batala-1	19-06-2020	7:25	10:1	73				Hot point attended at Batala
609	400 KV Mukisar Makhu ckt.1	19-06-2020	9:15	15:40		1	54		tree trimming done
610	220 KV Badal LJLO	19-06-2020	9:00	15:00		1	20		tree trimming done
611	132KV GVK-Sultanpur Ckt2	19-06-20	11:25	14:10	20334	31	32		Repaired Damaged R phase conductor between tower span no. 31-32.
612	132 KV Goraya Phagwara Ckt no.2	19-06-20	09:20	16:14	Patrolling	120	133		Ground Maintenance
613	400kv Line Makhu-Mukisar Ckt 1	19-6-2020	11:05	18:02	3	152,157,161 & 167	152,157,161 & 167 167		Tightening of jumpers of all the three phases of tower no. 152, 157, 161 & 167.
614	132KV KANGRA-PATHANKOT CKT-1&2	20-06-2020	09:00	17:30		426	430		Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
615	132KV Hoshiarpur-Mahlipur-1	20-06-20	05:15	16:10	55	47			B-Pahse Flash insulator string replace
616	132 KV Philsaur Jamaipur line	20-06-20	09:10	16:40	Patrolling	91	106		Ground Maintenance
617	220 kv Ladoke -Varpal	21-06-2020	10:58	12:05	4				Hot point attended at Ladoke

264

Sl. No.	Line Name	Date	Time	Duration	Remarks	118	124	124	124
618	132KV KANGRA -SHANAN CKT-1&2	22-06-2020	09:10	16:50					
619	132KV Tanda-Bhogpur	22-06-20	09:00	17:05	78	118			Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
620	132 KV Goraya Noormahal	22-06-20	11:20	16:20	80				Remove like Bird nest tree cutting between tower no. 61-62, 61-60
621	132 KV Goraya Phillaur	22-06-20	11:20	15:35	66				Replacement Disc insulators on tower no. 190
622	400KV Line Makhu-Amritsar Ckt 2	22-6-2020	10:20	15:20	4	74	78 & 87		Tightening of jumpers of all the three phases of Tower no. 74, 75, 76, 78 & 87
623	132KV KANGRA -SHANAN CKT-1&2	23-06-2020	09:15	16:30		125	133		Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
624	132KV SARNA-GURDASPUR CKT-1&2	23-06-2020	09:30	16:10		576	579		Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
625	220Kv Patti- Algonkothi	23-06-2020	08:10	17:05		30	40		Tree cutting
626	400 KV Muktsar Makhu ckt 1	23-06-2020	9:00	15:10		54	131		tree trimming done
627	132KV MPH2-Tanda-Bhogpur	23-06-20	09:10	16:50		MB35	MB45		Patrolling & tree trimming done
628	132 KV Phillaur -Jamalpur line	23-06-20	11:25	16:58	15				Replacement Disc insulators and jumper on tower no. 29
629	220KV PGCIL-AJTWAL	23-06-2020	10:00	16:00	NIL	73	102		Tree cutting, tower checking, general mtc.
630	220Kv Patti- Algonkothi	24-06-2020	08:05	16:50		40	64		Tree cutting
631	132KV SARNA-GURDASPUR CKT-1&2	24-06-2020	09:30	16:40		559	565		Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
632	132 KV Muktsar Malout	24-06-2020	8:00	12:15	3700	27			flushed string at y-ph changed
633	132KV Shri hargobindpur S-S	24-06-20	10:10	16:30	96	Bus bar			66KV B-Phase Hot point attended
634	132 KV Goraya Jamalpur Line	24-06-20	09:10	16:30	Patrolling	45	59		Ground Maintenance
635	220KV PGCIL-AJTWAL	24-06-2020	10:00	16:00	NIL	48	73		Tree cutting, tower checking, general mtc.
636	220 KV RSD-SARNA CKT-1&2&3	25-06-2020	19:05	01:20		1,1	42,41		Night Patrolling of line
637	220Kv Varpal- Patti	25-06-2020	09:05	16:50		110	96		Tree cutting
638	132KV Mahipur-Banga	25-06-20	08:05	17:00		58	68		Patrolling & tree trimming done
639	132 KV Goraya Jamalpur Line	25-06-20	09:00	17:10	Patrolling	60	73		Ground Maintenance
640	220KV JAMALPUR-GANGUWAL	25-06-2020	10:00	16:00	NIL	102	120		Tree cutting, tower checking, general mtc.
641	220 KV RSD-SARNA CKT-1&2&3	26-06-2020	18:40	01:10		42,43	1,01,109		Night Patrolling of line
642	132KV KANGRA-SHANAN CKT-1&2	26-06-2020	09:20	16:10		178	181		heavy tree cutting
643	132 KV Muktsar Sadq	26-06-2020	9:35	15:40		85-126 & 1-95			tree trimming done
644	132KV MPH2-Tanda-Bhogpur	26-06-20	09:05	17:20		MB45	MB53		Patrolling & tree trimming done
645	132 KV Nakodar-Noormahal	26-06-20	09:35	16:10	Patrolling	1	16		Ground Maintenance

265

546	220KV JAGRAON-HIMMATPURA	26-08-2020	10.00	16.00	NIL	22	48	Tree cutting, tower checking, general mtg.
547	132KV BBMB Jal-Dhikwan	27-06-20	9.30	15.45	NA	37A	280	Tree cutting is done between towers span no.37A-37B,37B-37C,278-279 and 279-280.
548	400 KV Nakodar-Moga	27-06-20	09.00	16.50	23	423	409	Ground Maintenance
549	132KV Mahilpur-Banga	28-06-20	06.00	17.10	17	72		Y-Phase Jumper Breakdown attended
550	220 KV Muktsar Ghubaya (d-c)	29-06-2020	10.00	15.00	...	1	30	tree trimming done
551	132 KV Phillaur Jamalpur line	29-08-20	12.15	16.00	17	-	-	Replacement Disc. Insulators on tower no. 46
552	220 KV Badel LILO	30-06-2020	9.15	15.20	...	20	62	tree trimming done
553	220 KV Muktsar Ghubaya (d-c)	30-06-2020	9.15	16.25	...	30	65	tree trimming done
554	132KV Hamirpur-Chahal	30-06-20	08.00	21.00	87	43		Y-Phase Hot Point attended
555	220 KV Nakodar-Hoshiarpur	30-06-20	09.15	16.38	Patrolling	26	39	Ground Maintenance and tree cutting

  
 Chief Engineer/P & M,  
 P.S.T.C.L. Ludhiana.  


ms. 2166



Preventive maintenance of 132/220/400 KV Transmission lines for the period of 01/07/20 to 30/09/2020.										
Sr.No	Name of Transmission Line	Mtc- Schudule	Date	From Time	To Time	PTW NO.	Detail of	From Tower No.	To Tower No.	Remarks (If any)
1	132KV KANGRA-PATHANKOT CKT-1&2	7/1/2020	7/1/2020	9:00	17:10	.....	.....	419	425	Ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
2	132Kv Patti- Sultanpur Lodhi	7/1/2020	7/1/2020	8:10	17:20	NA	NA	57	40	Tree Cutting & GMTC
3	132 kv Butari -Dhillon	7/1/2020	7/1/2020	9:02	15:00	33	33	170	178	Tree cutting
4	132 KV Muktsar Malout	7/1/2020	7/1/2020	12:00	15:05	...	...	1	62	Patrolling & tree trimming
5	220 KV Nakodar-Hoshiarpur	7/1/2020	7/1/2020	9:15	16:45	Patrolling	g	69	89	Ground Maintenance Tower no. 69 to 89.Tree cutting Between T.No.66-67,70-71,72-73-74,85-86.
6	132Kv Pims-Science city	7/1/2020	7/1/2020	0:00	0:00	NA	NA	23	28	Tree cutting is done between towers span no.23-24,25-26 and 27-28. .
7	132KV Bhogpur-Hoshiarpur	7/1/2020	7/1/2020	9:10	16:30	.....	.....	19	33	Patrolling & tree trimming done
8	132 kv Varpai- Tarn Taran	7/2/2020	7/2/2020	8:30	16:55	NA	NA	21	39	Tree cutting
9	220Kv Fatehgarh churtian - Civil line	7/2/2020	7/2/2020	8:30	16:55	19	19	60	72	Civil line side Wave trap jumper Hot point removed & Gmtc
10	132KV KANGRA-PATHANKOT CKT-1&2	7/2/2020	7/2/2020	9:05	17:15	.....	.....	410	418	Ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
11	132KV SARNA-GURDASPUR CKT-1&2	7/2/2020	7/2/2020	9:38	16:35	.....	.....	595	599	Ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
12	220 KV Nakodar-Rehana Jattan	7/2/2020	7/2/2020	9:05	16:30	.....	.....	90	119	Ground Maintenance Tower no. 90 to 119.Tree cutting Between T.No.95-96,97-98,101-102,109-110,117-117A.
13	132kv BBMB Jai.-Dhitwan	7/2/2020	7/2/2020	4:04	12:28	80	80	254		Patrolled line after tripping and replaced flashed disc insulators of B phase at Tw no.254 .
14	132KV MPH-2-Tanda/Bhogpur	7/2/2020	7/2/2020	9:00	16:50	.....	.....	MB53	MB60	Patrolling & tree trimming done
15	132KV KANGRA-PATHANKOT CKT-1&2	7/3/2020	7/3/2020	9:10	17:05	.....	.....	402	410	Ground mtc,tree cutting,checking of stubs,checking of all tower accessories.

267

16	220Kv Civil line- Khaasa	7/3/2020	9:30	15:40	NA	64/1	64/17	Tree Cutting & GMTC
17	132 KV Muktsar Srainaga	7/3/2020	9:00	15:45	....	491	442	Patrolling & tree trimming
18	220 KV Badai LILO	7/3/2020	9:05	17:15	.....	1	24	tree trimming
19	220 KV Reahan Jattan- Hoshiarpur	7/3/2020	0:00	0:00	NA	271	274	Ground Maintenance Tower no. 1 to 42. Tree cutting Between T.No.3-4,9- 10,19-20,33-32,35-36. Tree cutting is done between towers span no.271-272,272-273 and 273-274 .
20	132Kv BBMB Jal.-Dhilwan	7/4/2020	6:55	12:50	NA	1	9	Tree cutting
21	132Kv Civil Line- Khanna Paper Mill	7/4/2020	9:35	16:30	.....	590	594	Ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
22	132KV SARNA-GURDASPUR CKT-1&2	7/4/2020	9:35	16:30	.....	583	589	Ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
23	132KV SHANAN-KANGRA CKT-1&2	7/4/2020	9:15	16:25	.....	133	139	Ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
24	400 KV Muktsar Talwandi sabo D/C	7/4/2020	9:00	14:00	....	277	253	Hammer testing of towers for checking looseness
25	400 KV Muktsar Makhu D/C	7/4/2020	9:10	15:20	....	1	24	Hammer testing of towers for checking looseness
26	132 KV Phillaur-Jamalpur line	7/4/2020	8:55	16:45	....	0	29	Ground Maintenance Tower no.0 to 29. Tree cutting Between T.No.20- 21,17-18.
27	132KV BBMB JAL.-Children park	7/4/2020	6:00	0:00	55	9	13/15	Tree cutting is done between towers span no.9-10,13/13-13/14,13/14-13/15.
28	132 Moga- Gholian Kalan	05-07-2020 - 06-07-2020	22:00	2:00	86	52	-	Damaged Jumper of B-Ph Changed at T-off point at Tower No. 52
29	132 kv WG- SHGP -1	7/5/2020	23:40	8:09	34	430	431	Line petrolling heavy tree trimming
30	132 KV Srainaga Kotkapura-2	7/5/2020	10:10	19:35	....	74/11		Replace the R-Pahse Flash jumper replace
31	132KV MPH-2- Tanda	7/5/2020	4:14	19:10	67	54	-	Damaged jumper of Y-Phase changed at Tower No.54
32	132KV Moga- Sosan	7/5/2020	11:30	13:25	54	54	-	

268

34	132KV SARNA-GURDASPUR CKT-1&2	7/6/2020	9:30	16:55	.....	564	626	Critical tree cutting between span no.564/565,595/596,624/625,625/626.
35	132Kv Sultanpur Lodhi -Patti	7/6/2020	9:50	17:05	71	57, 59 .60	82	T.no 57,59 Disc cleaning & dead End jumper nut bolt tightening & tree Cutting
36	132 KV Muktsar Srainaga	7/6/2020	9:10	13:15	4645	s/s gantry	.....	Hot point attended at R-ph wavetrap at srainaga s/s
37	132 KV Goraya-phillaur line	7/6/2020	9:45	17:15	....	183	169	Ground Maintenance Tower no. 183 to 163.Tree cutting Between T.No.181- 182.
38	132KV Tanda-Bhogpur	7/6/2020	7:00	16:00		84	133	Y-phase jumper replace at Bhogpur S/S and patrolling of line
39	132 kv Butari -Beas	7/7/2020	12:30	14:30	89	175 180	176	Tree cutting
40	132Kv Taim taran -patti	7/7/2020	9:05	16:50	NA	39	181	Tree Cutting & GMTC
41	132KV KANGRA- PATHANKOT CKT-1&2	7/7/2020	9:10	17:10	.....	321	322	Clean the retaining wall of towers
42	132KV SARNA-GURDASPUR CKT-1&2	7/7/2020	9:30	16:15	.....	566	575	Ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
43	220 KV Katorewala badal	7/7/2020	9:00	16:00	37	24	82	tree trimming
44	220 KV Muktsar Ghubaya D/C	7/7/2020	9:10	15:30	....	65	114	tree trimming
45	220 KV PGCIL-Kartarpur CKT No.1	7/7/2020	9:30	15:55	....	1	22	Ground Maintenance Tower no. 1 to 22.Tree cutting Between T.No.3-5,11- 12.
46	220KV RSD-SARNA CKT-4	7/8/2020	9:25	17:05	.....	1	13	Jumper retightning work of tower no.1,2,7,12,13 with TLSC Team
47	132Kv Verka- Pakherpura	7/8/2020	8:50	16:05	NA	801	824	Tree Cutting & GMTC
48	220 KV Katorewala Muktsar	7/8/2020	9:00	15:00	....	1	42	tree trimming
49	132 KV muktsar Srainaga	7/8/2020	9:30	15:40	....	490	442	bird nests removal work
50	132Kv Varpal-naraingarh Ckt 1	7/9/2020	9:20	16:45	97	1	22	T.no 22 Disc cleaning & dead End jumper nut bolt tightening & tree Cutting
51	220KV RSD-SARNA CKT-4	7/9/2020	9:30	16:55	.....	9	10	fight the jumper of tower no.9,10 with TLSC Team
52	220 KV Katorewala Muktsar	7/9/2020	9:00	14:30	....	42	65	tree trimming

269

✓

53	132 KV Srainaga Kotkapura2	7/9/2020	9.10	15.40	4547	442	380	bird nests removal work
54	132 KV Goraya-Jamalpur line	7/9/2020	9:10	16:40	....	36	48	Ground Maintenance Tower no. 36 to 48.
55	220Kv Badshahpur-Sultanpur	7/9/2020	10:48	13:26	8	33/1	33/10	Attended hot point of middle phase clamp at tw no.33/1 (Sultanpur side), Top phase clamp at tw no.33/10 (Badshahpur side) and tree cutting is done between towers span no. 33/2-33/3,33/8-33/9.
56	132KV MPH-2- Tanda / Bhogpur	7/9/2020	9:15	16:30	.....	MB60	MB71	Patrolling & tree trimming done
57	220 KV MALER KOTLA-SANDAUR-1	7/9/2020	10:00	16:00	63	1	1	ATTENDED HOT POINT OF R-PHASE LINE SIDE AT SANDAUR S/S
58	220kv Botiwala- Ferozpur	7/9/2020	10:15	14:55	52	55	-	attended Hot Point On R-Ph at tower no.55
59	132KV SHANAN-KANGRA CKT-1&2	7/10/2020	9:10	16:40	.....	151	153	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
60	220KV RSD-SARNA CKT-4	7/10/2020	9:38	16:50	.....	17	19	Jumper Retightningwork of tower no.9,10 with TLSC Team
61	220 KV MAJITHA - FATEHGARH CHURIAN	7/10/2020	9:30	18:20	52		45/2,45/1 8	Disc cleaning & dead End jumper nut bolt tightening .
62	220 KV Katorewala Muktsar	7/10/2020	9:00	14:45	590	65	79	emergency tree trimming
63	220 KV Kotla Janga- Kartarpur CKT NO.2	7/10/2020	6:10	11/07/2020 and 14:50	14	4	7	Sag between T.No.4-5-6-7.
64	400 KV Rajpura-Dhuri CKT-1 & 2	7/10/2020	9:00	16:55	52	1	49	Checking & tightening of nut bolts of dead end towers from TL no. 01 to 49
65	132Kv varpal-Hakima Gate	7/11/2020	9:10	16:12	NA	11	12	Tree cutting
66	132Kv Varpal-Tain taran	7/11/2020	9:10	16:12	NA	24	33	Tree cutting
67	400 KV Rajpura-Dhuri CKT-1 & 2	7/11/2020	8:30	17:30	52	50	96	Checking & tightening of nut bolts of dead end towers from TL no. 50 to 96
68	220KV RSD-SARNA CKT-4	7/12/2020	9:10	16:40	.....	11	24	Jumper retightningwork of tower no.11,14,23,24 with TLSC Team
69	220 kv WG- Varpal	7/12/2020	18:40	20:35	8	1		Hot point attended

270



70	400 KV Rajpura-Dhuri CKT-1 & 2	7/12/2020	7:30	16:40	52	97	128	Checking & tightening of nut bolts of dead end towers from TL no. 97 to 128	
71	220KV RSD-SARNA CKT-4	7/13/2020	9:30	16:55	.....	25	36	Jumper retighteningwork of tower no.25,28,29,36with TLSC Team	
72	132Kv Jandiala -Tangra	7/13/2020	9:15	16:25	NA	68	98	Tree cutting & GMTC	
73	132 KV Moga Kotkapura-1	7/13/2020	10:00	17:30	53	26	52	patrolling & tree trimming	
74	220 KV Badal Bathinda	7/13/2020	9:15	14:15	....	79	110	tree trimming	
75	132Kv civil Line- Naraingarh	7/14/2020	8:50	16:45	NA	19	42	Tree cutting	
76	132 KV Pangrain Moga	7/14/2020	9:15	16:25	1	350	315	bird nests removal work	
77	132 KV Muktsar Malout	7/14/2020	16:30	18:10	....	1	64	patrolling	
78	220 KV Kotla Janga-Jamsher CKT NO.1	7/14/2020	11:15	13:41	50	19	19	Attending hot pont on tower no. 19 and wave trap gantry of sis kotla janga	
79	132 KV JAMALPUR-SWADDI LINE	7/14/2020	10:10	16:15	NIL	....	....	TREE CUTTING BETWEEN TOWER NO. 78-79, 83-84, 87-88, 90-91, 94-95, 98-99.	
80	220kv Bala Chak - Naraingarh	7/15/2020	8:55	16:25	NA	9	38	Tree cutting	
81	220KV RSD-SARNA CKT-4	7/15/2020	9:20	16:40	.....	56	66	Jumper retighteningwork of tower no.56,57,61,66 with TLSC Team	
82	220 KV Badal Bathinda	7/15/2020	9:15	14:15	....	110	130	tree trimming	
83	132Kv Pims-Children Park	7/15/2020	13:12	2:24	92	14	17/3	Tree cutting is done between tower span no.14-15,15-16,17/1-17/2,17/2-17/3 ..	
84	220KV Pong-Dasuya ckt-3	7/15/2020	9:10	17:10	.....	18	25	Patrolling & tree trimming done	
85	132Kv Varpal-Mall mandi	7/16/2020	9:05	16:45	18	1	1	Hot Point Removed	
86	220kv Bala Chak -Varpal	7/16/2020			NA	1	9	Tree Cutting & GMTC	
87	220 KV Badal Bathinda	7/16/2020	9:10	15:30	48	130	149	tree trimming	
88	220 KV Kotla Janga-Kartarpur CKT NO.2	7/16/2020	11:20	14:42	45	1	1	Replaced the jumper of B-Phase at T.No. 1	
89	220 KV Kotla Janga-Kartarpur CKT No.1	7/16/2020	15:35	16:53	46	2	2	Replaced the jumper of R-Phase at T.No. 2	
90	132 KV JAMALPUR-SWADDI LINE	7/16/2020	10:00	16:10	NIL	63	74	TREE CUTTING BETWEEN TOWER NO. 63-64, 66-67, 69-70, 73-74. .	
91	220KV RSD-SARNA CKT-4	7/17/2020	12:25	18:35	.....	42	29	Jumper retighteningwork of tower no.42,43,46,47,48,49 with TLSC Team	
92	220kv, Bala Chak - Naraingarh	7/17/2020	9:10	16:20	23	39, 1	9	Hot Point Removed on Tower No 39 & tree Cutting	

272

✓

93	132 KV Srainaga Kotkapura-2	7/17/2020	10.00	17.00	4578	397	399	emergency tree trimming
94	132 KV Muktsar sarainaga	7/17/2020	9.10	12.25	4367	490	...	hot point attended at R-ph of T:490
95	220 KV Reahan Jattan-Hoshiarpur	7/17/2020	9:10	16:40	...	43	63	Ground Maintenance Tower no. 43 to 63. Tree cutting Between T.No.60-59-50-51.
96	132Kv Kapurthala-Science city	7/17/2020	1:12	6:00	95	104	109	Tree cutting is done between towers span no.104-105,106-107,108-109...
97	220 KV PG-DHANDARI LINE	7/17/2020	9.50	16.25	NIL	1	12	TREE CUTTING BETWEEN TOWER NO. 3-4, 6D-6E, 7-8,9-10, 11-12.
98	220Kv Rashiana -Patti	7/18/2020	9:20	16:25	21	12		Hot Point Removed
99	220KV RSD-SARNA CKT-4	7/18/2020	9:35	16:40	.....	31	34	Jumper retightningwork of tower no.31,32,34 with TLSC Team
100	132 kv Batala -Pakharpur	7/18/2020	7.15	8.30	71	747		Jumper adjusted
101	132 KV Kotkapura1 Moga	7/18/2020	9.00	15.10	...	168	155	tree trimming
102	132 KV Kotkapura2 Srainaga	7/18/2020	9.00	15.10	...	378	442	tree trimming
103	132 KV Kotla Janga-Nakodar Line	7/18/2020	9:30	16:10	...	1L	11L	Ground Maintenance Tower no. 1L to 11L. Tree cutting Between T.No.4-5,8-9.
104	220Kv Goraya-Jadla	7/18/2020	13:12	3:36	32	256/13	256/23	Attends hot point of B phase clamp at tw no.256/19 (Goraya side) and B phase clamp(Jadla side) at Tw no. 256/23 and tree cutting is done between tower span no. 256/13-256/14
105	220 KV PG-DHANDARI LINE	7/18/2020	10.05	16.30	NIL	16	17	TREE CUTTING BETWEEN TOWER NO. 16-17.
106	220KV R.T.P - G1 Ckt-3, R.T.P.-Bassi	7/18/2020	10:10	18:40	.....	3	8	Tree cutting between span no 03-04,04-05,05-06,06-07 and 07-08 was done.
107	220KV RSD-SARNA CKT-4	7/20/2020	10:00	16:20	.....	70	78	Jumper retightningwork of tower no.70,74,78with TLSC Team
108	220Kv Khassa- Chogawan	7/20/2020	9:15	16:50	54		64/16, 64/17	Disc cleaning & dead End jumper nut bolt tightening
109	132 KV Bathinda Thermal-IGC	7/20/2020	6:35	13:10	1/116	20	21	To attend hot point on gantry of IGC S/s
110	132 KV Kotkapura2 Panjgrain	7/20/2020	6.05	10.35	...	379	351	line patrolling
111	132 KV Muktsar Malout	7/20/2020	10.35	16.00	4376	64	140	tree trimming

274

112	132 KV Muktsar Malout	7/20/2020	9:10	11:10	.....	1	63	tree trimming
113	132 KV Kotkapura1 Moga	7/21/2020	12:20	17:00	8	Kkp1 s/s gantry	1	hot point attended at Y-ph of wavetrap & tree trimming near gantry
114	132 KV Phillaur-Jamalpur line	7/21/2020	8:50	16:36	....	106	132	Ground Maintenance Tower no. 106 to 132. Tree cutting Between T.No.106-107,110-111-112.
115	132Kv Khera Mandir-Sultanpur	7/21/2020	11:25,	12:00	16	44	45	Setright loose sag of earthwire between tw no.44-45
116	220Kv Varpal-Patti	7/22/2020	9:25	16:10	26		12	Hot Point Removed
117	132KV SHANAN-KANGRA CKT-1&2	7/22/2020	9:10	16:10	.....	190	194	ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.
118	220KV RSD-SARNA CKT-4	7/22/2020	9:30	16:50	.....	8	34	Jumper retightningwork of tower no.8,26,34with TLSC Team
119	132 KV Panjgrain Moga	7/22/2020	9:30	17:05	....	351	247	patrolling & tree trimming
120	132 KV Muktsar Malout	7/22/2020	9:15	15:30	....	140	220	tree trimming
121	132 KV Urban Estate-Kotla Janga Line	7/22/2020	9:00	16:10	....	37	55	Ground Maintenance Tower no. 37 to 55. Tree cutting Between T.No.54-55,53-52,41A-41,40-41.
122	132 Kv BBMB JAL.-Kahanpur	7/22/2020	09:50,	0:00	43	15	31,	Attended hot point of R phase clamp at tw no.15 (Kahanpur side) and Y phase clamp(Kahanpur side) at Tw no.31.
123	220 KV PG-DHANDARI LINE	7/22/2020	10:10	16:00	NIL	17	21	TREE CUTTING BETWEEN TOWER NO. 17-18, 18-19, 20-21.
124	132KV Dhallek-Moga1-dharamkot	7/22/2020	14:00	17:30	4	9	10	Tree Cutting between span 9-10
125	132KV SARNA-PATHANKOT CKT-1	7/23/2020	9:25	16:20	.....	499	501	ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.
126	220Kv Bala chak-Naraingarh	7/23/2020	8:45	15:50	NA	1	9	Tree cutting & GMTC
127	132 KV Panjgrain Moga	7/23/2020	9:15	17:30	4	298	234	emergency tree trimming
128	132 KV Muktsar Malout	7/23/2020	9:15	14:30	....	220	278	tree trimming
129	132 KV Phillaur-Jamalpur line	7/23/2020	11:25	28/07/2020 and 20:08	28	8	12	Sag between 8-9-10-11-12
130	220Kv Gvk-Sultanpur ckt1	7/23/2020	5:16	6:00	82	59		Attended hot point of B phase clamp at tw no.59 (Gvk side).
131	220Kv Gvk-Sultanpur ckt2	7/23/2020	13:12	1:12	83	59		Attended hot point of Y phase clamp at tw no.59 (Gvk side).

275

2

		7/23/2020	10:00	17:20	NR	90	110	Checking & tightening of nut bolts of dead end towers from tower no. 90 to 110
132	400 KV NPL-Nakoder							
133	220Kv Bala Chak-Khassa	7/24/2020	8:55	16:50	NA	21	42	Tree cutting
134	132KV KANGRA-PATHANKOT CKT-1&2	7/24/2020	9:15	17:15	.....	310	325	Cleaning and checking of retaining wall of tower ,310,311 tree cutting between tower no.324/325 and make path for tower no.323,324
135	220KV RSD-SARNA CKT-4	7/24/2020	9:40	16:45	.....	4	4	jumper replaced with tisc team
136	132 Muktsar Kotkapura1	7/24/2020	9:30	16:50	....	167/5-6, 157-158, 138-39	....	tree trimming
137	132Kv Kapurthala-RCF	7/24/2020	7:12	7:12	NA	8	25	Tree cutting is done between towers span no.8-9,9-10,24-25.
138	132KV Nakkian-Nawanshehar Line	7/24/2020	9:00	17:20	.....	109	118	Patrolling & tree trimming done
139	220 KV JAMALPUR-GANGUWAL 1	7/24/2020	10:15	16:45	NIL	42	49	TREE CUTTING BETWEEN TOWER NO. 42-43, 44-45, 45-46, 48-49.
140	220KV R.T.P - G1 Ckt-2	7/24/2020	10:00	16:10	7	....	....	Damaged Jumper of R- phase replaced at gantry side on wave trap at 220KV S/S G1
141	220KV Civil line- Fatehgarh Churian	7/25/2020	9:00	16:10	NA	6	27	Tree cutting
142	132Kv BBMB Jal.-Phagwara	7/25/2020	6:00	7:12	4	224	225	Setright loose sag of earthwire between tw no.224-225
143	220KV R.T.P - G1 Ckt-3, R.T.P.-Bassi	7/25/2020	8:40	22:40	....	125	126	Tree cutting between span no 125-126 is done
144	132KV Dhalleke-Moga1-dharamkot	7/26/2020	10:00	15:00	18	1	2	Creep of plant and shrubs under the tower was removed and patrolling of line from tower no. 1 to 34
145	132Kv Tarn taran -patti	7/27/2020	9:15	16:20	55	29	....	Hot Point Removed
146	220KV RSD-SARNA CKT-4	7/27/2020	9:35	16:40	.....	6	6	Jumper replaced with tisc team
147	132 KV Bti Thermal-Cant	7/27/2020	12:00	15:00	Work Permit	13	13	Hot Line team Ludhiana replace disc insulator string at Tower No.13 C phase
148	132 KV Kotkapura1 Moga	7/27/2020	9:20	16:30	....	26	60	tree trimming
149	220 KV Muktsar Abohar D/C	7/27/2020	9:15	14:45	....	13	30	tree trimming

276



150	132KV MPH2- Bhogpur /Tanda - Bhogpur	7/27/2020	9:10	16:50	.....	MB71	MB83	Patrolling & tree trimming done
151	220 KV PG-DHANDARI LINE	7/27/2020	10:10	16:20	NIL	32	38	TREE CUTTING BETWEEN TOWER NO. 32-33, 34-35, 36-37-38.
152	220KV R.T.P - G1 Ckt-3, R.T.P.-Bassi	7/27/2020	9:40	17:10	.....	124	126	Tree cutting between span no 124-125 and 125-126 was done.
153	132KV KANGRA- PATHANKOT CKT-1&2	7/28/2020	9:30	16:55	.....	312	322	Cleaning and checking of retaining wall of towers
154	220KV RSD-SARNA CKT-4	7/28/2020	9:20	17:20	.....	2	2	jumper replaced with tisc team
155	132Kv Verka- Pakherpura	7/28/2020	8:30	15:20	NA	799	839	Tree cutting
156	132 K/ Kotkapura 1 Moga	7/28/2020	9:15	15:30	...	60	132	tree trimming
157	220 KV Muktsar Abohar D/C	7/28/2020	9:10	14:30	80	66	91	tree trimming
158	132 Kv BBMB JAL.-Alawalpur	7/28/2020	1:12	9:07	9	31		Replaced flashed disc insulators of Y phase at Tw no.31.
159	132KV Hamirpur-Chohal	7/28/2020	8:00	17:10	.....	70 to 76	57 to 61	Patrolling & tree trimming done
160	132 KV JAMALPUR-MOGA	7/28/2020	10:20	16:32	NIL	17	21	TREE CUTTING BETWEEN TOWER NO. 17-18, 18-19, 19-20, 20-21.
161	220 KV PG-DHANDARI LINE	7/28/2020	9:35	16:35	NIL	40	50	TREE CUTTING BETWEEN TOWER NO. 40-41, 44-45, 45-46, 47-48, 49-50.
162	220KV R.T.P - G1 Ckt-3, R.T.P.-Bassi	7/28/2020	10:10	17:30	.....	126	129	Tree cutting between span no 126-127,127-128 and 128-129 was done.
163	132Kv Verka- Power colony	7/29/2020	8:40	16:05	NA	1	9	Tree cutting & GMTC
164	220KV RSD-SARNA CKT-4	7/29/2020	9:25	17:35	.....	1	19	jumper replaced of tower no.1 and 19 with tisc team
165	132KV KANGRA- PATHANKOT CKT-1&2	7/29/2020	9:30	18:35	69	322	324	Repair of conductor between spanno.322/324 and rectified the pipe jumper of tower 324.
166	132 KV Muktsar Kotkapura1	7/29/2020	9:10	15:15	....	267	210	tree trimming
167	132 KV Goraya-Phagwara CKT No.2	7/29/2020	16:05	20:37	69	149	Gantry	Replaced the conductor between gantry and T.No.149
168	132Kv Focal point-Kartarpur	7/29/2020	0:00	0:00	NA	33	39	Tree cutting is done between towers span no.33-34,35-36 and 38-39 ..
169	220KV Dasuya-RailwayLine	7/29/2020	10:00	17:15	.....	7	12	Patrolling & tree trimming done

277

170	220KV Bhakra-Mahilpur Line	7/29/2020	9:00	17:15	.....	151	156	Patrolling & tree trimming done
171	132 KV JAMALPUR-SWADDI LINE	7/29/2020	10:00	16:25	NIL	49	51	TREE CUTTING BETWEEN TOWER NO. 49-50, 50-51.
172	400 KV Rajpura-Dhuri CKT-1 & 2	7/29/2020	9:00	16:30	NR	1	1	For checking & tightening the nut bolt of tower's members
173	220KV RSD-SARNA CKT-4	7/30/2020	9:30	18:00	.....	46	46	Jumper replaced with tisc team
174	220kv Majitha -FatehGarh churian	7/30/2020	8:50	16:25	NA	45	60	Tree cutting
175	132Kv Kartarpur-Beas	7/30/2020	13:12	2:24	81	87		Replaced flashed disc insulators of R and B phase at Tw no.87 .
176	132KV MPH4-Shri Hargobindpur Line	7/30/2020	9:20	16:45	.....	6	17	Patrolling & tree trimming done
177	220KV Mahilpur-Jamsher/ RehanaJattan-Jamsher	7/30/2020	9:50	17:40	.....	114	115	Patrolling & tree trimming done
178	400 KV Rajpura-Dhuri CKT-1 & 2	7/30/2020	9:00	16:00	NR	2	2	For checking & tightening the nut bolt of tower's members
179	132Kv Mail Mandi-verka	7/31/2020	8:20	11:35	NA	1	9	Tree cutting & GMTC
180	132KV KANGRA-SHANAN CKT-1&2	7/31/2020	9:10	16:50	.....	102	120	Bamboo cutting between spans.
181	220KV RSD-SARNA CKT-4	7/31/2020	9:15	15:50	.....	18	18	Install 2no. Suspension strings for maintaining the gap between jumper at tower no.18 with TLSC Team
182	220 KV Muktsar Abohar D/C	7/31/2020	10:10	15:30	....	110	134	tree trimming
183	132Kv Kartarpur-Beas	7/31/2020	1:12	4:48	82	83	90	Replaced flashed disc insulators of B phase at Tw no.83 ,tw no.89 and R phase at tw no.90 .
184	132 KV JAMALPUR-SWADDI LINE	7/31/2020	10:15	16:10	NIL	44	48	TREE CUTTING BETWEEN TOWER NO. 44-45, 45-46, 46-47, 47-48.
185	220 KV PG-MEHAL KALAN	7/31/2020	10:00	16:00	14	127	128	TREE CUTTING BETWEEN TOWER NO. 127-128 AND CHECKED THE TIGHTNESS OF FOOTING NUT/BOLT OF BOTH TOWERS
186	220KV R.T.P - G1 Ckt-3, R.T.P.-Bassi	7/31/2020	9:15	19:35	.....	69	73	Tree cutting between span no 69-70,70-71,71-72 and 72-73 is done.

278

187	220kv Himmatpura- Jagraon	7/31/2020	12:50	17:25	52	...	....	flashed suspension discs were changed of R -Ph at tower No.23 and patrolling of line from tower no. 1 to 30
188	400 KV Rajpura-Dhuri CKt-1 & 2	7/31/2020	9:00	16:00	NR	3	3	For checking & tightening the nut bolt of tower's members
189	400 KV Rajpura - 220 KV Ablowal	7/31/2020	9:30	19:10	NR	93	97	For checking vertical and horizontal clearance between towers
190	400 KV Rajpura - 220 KV Ablowal	7/31/2020	9:30	19:10	NR	28	34	For checking vertical and horizontal clearance between towers
191	400 KV Faganmalra-Nabha	7/31/2020	9:30	19:10	NR	50	51	For checking vertical and horizontal clearance between towers
192	132kv KANGRA- PATHANKOT CKT-1&2	8/1/2020	9:20	17:50	.....	389	460	Bamboo cutting between spans.
193	220KV RSD-SARNA CKT -1&2	8/1/2020	9:20	16:10	.....	1	20	Checking of towers
194	132 kv Jandiala-Tangra Line	8/1/2020	8:20	16:05		79	85	Tree Cutting & GMTC
195	132 KV Kotkapura1 Moga	8/1/2020	10:10	14:40	18	s/s gantry	....	hot point attended at Y-ph of wavetrapp
196	400 KV Rajpura - Dhuri line (D.C)	8/1/2020	10:00	16:00	NR	241	242	Checked & tightened of tower structure. Tower No. 242 & 241
197	400 KV Rajpura-Dhuri CKt-1 & 2	8/1/2020	9:10	15:30	NR	4	4	For checking & tightening the nut bolt of tower's members
198	220 kv Khasa Balachak line	8/3/2020	8:35	17:10		20	44	Tree Cutting
199	132 kv Butari Jalandhar	8/3/2020	10:00	16:00		15	22	Tree cutting
200	132KV Hoshiarpur-Mahilpur Line	8/3/2020	11:05	16:50	.....	18	27	Patrolling & tree trimming done
201	132 KV JAMALPUR-SWADDI LINE	8/3/2020	10:10	16:20	NIL	39	44	TREE CUTTING BETWEEN TOWER NO. 39-40, 40-41, 41-42, 42-43, 43-44.
202	400 KV Rajpura - Dhuri line (D.C)	8/3/2020	10:00	16:25	NR	218	219	Checked & tightened of tower structure. Tower No. 218 and 219
203	400 KV Rajla-Banwala and Patran	8/3/2020	8:00	17:20	NR	85	92	For checking vertical and horizontal clearance between towers
204	400 KV Rajpura-Dhuri CKt-1 & 2	8/3/2020	9:30	15:40	NR	5	5	For checking & tightening the nut bolt of tower's members

279

8

205	220Kv RSD-SARNA CKT -3	8/4/2020	9:30	16:30	.....	84	86	ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.Number plates and Acc installed.
206	132Kv KANGRA-PATHANKOT CKT-1&2	8/4/2020	9:10	16:40	.....	235	245	ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.
207	220 kv Civil line-chogawan	8/4/2020	9:05	16:35		25	45	Tree Cutting
208	400 KV Nakodar-Makhu CKT No.2	8/4/2020	9:20	16:00	....	116	131	Ground Maintenance Tower no. 116 to 131.Tree cutting Between T.No.130-129,123-124,118-117-116.
209	132Kv BBMB Jal.-Dhilwan	8/4/2020	12:00	1:12	13	4	5	Tree cutting is done between tower span no.4-5.
210	132KV Phagwara-Banga	8/4/2020	9:10	17:10	.....	65	72	Patrolling & tree trimming done
211	220 KV SAHNEWAL-RAILWAY	8/4/2020	10:15	14:00	NIL	3	3	APPLIED RUBBERSEAL AFTER CLEANING OF STUB ON 1 NO. MAIN LEG OF TOWER NO.3 AS THERE WAS RUST DEPOSITION.
212	400 kv Dhuri-Talwandi Double ckt	8/4/2020	09:30	16:45	NR	200	251	Line patrolled and tree cutting from tower No. 251 to 200
213	400 KV Rajpura-Dhuri CKT-1 & 2	8/4/2020	9:10	16:20	NR	6	7	For checking & tightening the nut bolt of tower's members
214	220 kv Varpal-Balachak line	8/5/2020	8:10	16:55		1	9	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
215	132 kv Varpal-Tarn taran line	8/5/2020	8:10	16:55		18	36	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
216	132Kv KANGRA-SHANAN CKT-1&2	8/5/2020	9:20	16:50	.....	132	193	Bamboo cutting between spans.
217	220Kv RSD-SARNA CKT -3	8/5/2020	9:35	16:20	.....	82	83	ground mtc,tree cutting ,checking of stubs,Number plates and Acc installed.
218	400 KV Nakodar-Moga Line	8/5/2020	9:10	16:40	....	353	370	Ground Maintenance Tower no. 353 to 370. Tree cutting Between T.No.369-370,362-363,359-360.
219	220 KV MOGA-BAGHAPURANA-2	8/5/2020	8:20	20:10	NIL	4	15	ATTENDED THE CONDUCTOR BREAKDOWN OF R-PHASE BETWEEN DEAD END TOWERS NO. 4 TO 15.
220	400 kv Dhuri-Talwandi Double ckt	8/5/2020	09:25	18:00	NR	126	165	Line patrolled and tree cutting from tower No. 126 to 165

280



221	400 KV Rajpura - Dhuri line (D.C)	8/5/2020	09:50	16:05	NR	183	184	Checked & tightened of tower structure. Tower No. 183 and 184	
222	400 KV Rajpura-Dhuri CKT-1 & 2	8/5/2020	9:10	16:20	NR	8	10	For checking & tightening the nut bolt of tower's members	
223	220Kv RSD-SARNA CKT -3	8/6/2020	9:25	16:15	.....	78	81	ground mtc,tree cutting ,checking of stubs,Numper plates and Acc installed.	
224	132Kv KANGRA-PATHANKOT CKT-1&2	8/6/2020	9:15	16:50	.....	333	339	ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.	
225	132 kv Tarn taran-Butari line	8/6/2020	9:05	17:15		50	65	Tree Cutting & GMTC	
226	220 KV Muktsar Bathinda D/C	8/6/2020	9:15	14:00	....	156	96	tree trimming	
227	132 Kv Ferozepur faridkot	8/6/2020	11:55	18:05	...	4	14	tree trimming	
228	132Kv Pims-Science city	8/6/2020	1:12	7:12	7	24	29	Tree cutting is done between towers span no.24-25,27-28,28-29	
229	220kv Bhakra- Mahilpur Line	8/6/2020	9:05	18:05	.....	71	76	Patrolling & tree trimming done	
230	220 KV PG-DHANDARI	8/6/2020	9:50	16:00	NIL	51	62	TREE CUTTING BETWEEN TOWER NO. 51-52, 53-54, 57-58, 58-59, 60-61.	
231	220 KV KOHARA-SAHNEWAL	8/6/2020	10:10	16:10	NIL	....	....	TREE CUTTING BETWEEN TOWER NO. 206/4-206/3, 206-205 210-211, 213-214, 216-217, 225-226, 230-231, 233-234, 235-236. CHECKED THE TIGHTNESS OF NUT BOLTS AT TOWER No.216,217,233 & 234.	
232	400 KV Rajpura - Dhuri line (D.C)	8/6/2020	09:50	16:35	NR	137	138	Checked & tightened of tower structure. Tower No. 137 and 138	
233	400 KV Rajpura-Dhuri CKT-1 & 2	8/6/2020	9:15	16:40	NR	11	12	For checking & tightening the nut bolt of tower's members	
234	132 kv Varpal-Tarn taran line	8/7/2020	8:10	15:50		29	39	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.	
235	132 kv Butari Dhillwan	8/7/2020	10:00	16:00		172	176	Tree cutting	
236	132 KV Ferozepur faridkot	8/7/2020	9:20	17:10	...	22	38	tree trimming	
237	132Kv Pims-Science city	8/7/2020	10:48	3:36	8	19		Replaced flashed disc insulators of B phase at Tw no.19 .	

281

R

238	220 KV PG-PAKHOWAL	8/7/2020	10.00	16.00	NIL	....	....	TREE CUTTING BETWEEN TOWER NO. 27-28, 30-31, 34-35, 37-38, 40-41, 44-45, 47-48. CHECKED THE TIGHTNESS OF NUT BOLTS AT TOWER No.27,38 &45
239	220 KV LALTON-SAHNEWAL	8/7/2020	10.00	16.00	NIL	271	294	TREE CUTTING BETWEEN TOWER NO. 271-272, 275-276, 280-281, 283-284, 288-289, 293-294. attended Hot Point of B-Phase at tower No. 98
240	132KV Kotkore - Ferozshah	8/7/2020	10:30	13:30	64	98		Line patrolled and tree cutting from tower No. 71 to 124
241	400 KV Dhuri-Talwandi Double ckt	8/7/2020	09:30	18:00	NR	71	124	For checking & tightening the nut bolt of tower's members
242	400 KV Rajpura-Dhuri CKT-1 & 2	8/7/2020	9:10	16:10	NR	13	14	Attend hot point at tower no-01 on Bph
243	220 KV Ablawal- Raja	8/7/2020	9:10	16:50	3	1	1	Tree cutting
244	132 kv Batala - kathunangal	8/8/2020	10.00	16.00		741	755	Tree Cutting
245	132 kv mall Mandi GT Road line	8/8/2020	9:30	13:30		1	5	Bamboo cutting between spans.
246	132Kv KANGRA- PATHANKOT CKT-1&2	8/8/2020	9:20	15:00	....	239	251	Ground Maintenance Tower no. 1 to 17. Tree cutting Between T.No.2-3-4,12-13.
247	132 KV Goraya-Noormahal line	8/8/2020	10:00	16:20	....	1	17	Tree cutting is done between towers span no.8-9,9-10,10-11,12-13.
248	132Kv BBMB Jai.-Focal point	8/8/2020	6:00	13:12	17	8	13	TREE CUTTING BETWEEN TOWER NO.27-28. CHECKED THE TIGHTNESS OF NUT BOLTS OF BOTH TOWERS
249	220 KV PG-PAKHOWAL	8/8/2020	10.15	16.20	NIL	27	28	Tree cutting between span no 62-63 and 63-64 was done.
250	220KV R.T.P - G1 Ckt-3, R.T.P.-Bassi	8/8/2020	9:15	17:45	....	62	64	Line patrolled and tree cutting from tower No. 70 to 43
251	400 KV Dhuri-Talwandi Double ckt	8/8/2020	09:20	16:35	NR	43	70	For checking & tightening the nut bolt of tower's members
252	400 KV Rajpura-Dhuri CKT-1 & 2	8/8/2020	9:30	16:40	NR	15	15	Line patrolled and tree pruning between towers
253	400 KV- Rajpura-Ablawal	8/8/2020	9:30	16:40	NR	50	56	Tree Cutting & GMTC
254	220 kv Civil line khasa line	8/10/2020	8:50	15:20		70	81	

282

255	132 kv Batala - kathunangal	8/10/2020	10.00	16.00		756	766	Tree cutting	
256	220 KV Muktsar Bathinda D/C	8/10/2020	9.10	14.00	....	96	68	tree trimming	
257	132 KV Muktsar Kotkapura1	8/10/2020	9.10	15.25	....	319	167+7 LILO towers	tree trimming	
258	132 KV Goraya-Jamalpur line	8/10/2020	8:50	16:10	....	47	63	Ground Maintenance Tower no. 47 to 63. Tree cutting Between T.No.48-49-50.	
259	132kv Kapurthala-Science city	8/10/2020	10.58,	4:48	96	90	107	Attended hot point of R phase clamp at tw no.90 , B phase clamp at Tw no.99 and B phase clamp at tw no.107	
260	132KV Phagwara-Banga	8/10/2020	9:10	16:50	.....	72	80	Patrolling & tree trimming done	
261	220 KV JAMALPUR-GANGUWAL 1	8/10/2020	10.25	16.30	102	28	29	TREE CUTTING BETWEEN TOWER NO. 28-29.	
262	220KV R.T.P - G1 Ckt-3, R.T.P.-Bassi	8/10/2020	21:20	18:00	....	50	59	Tree cutting between span no 50-51,52-53,53-54,54-55,55-56 and 58-59 was done.	
263	400 KV Rajpura-Dhuri Ckt-1 & 2	8/10/2020	9:15	16:30	NR	16	16	For checking & tightening the nut bolt of tower's members	
264	220 KV Rajpura-Ablowal	8/10/2020	9:15	16:30	NR	35	49	Checking & tightening of nut bolts of dead end towers	
265	220 KV Sunam-Patran/Sunam-Bangah	8/10/2020	09:50	16:45	NR	1	40	Line patrolled and tree cutting from tower No. 1 to 40	
266	132 kv Jandiala-Tangra Line	8/11/2020	9:05	16:10		22	40	Tree Cutting & GMTC	
267	132kv KANGRA-PATHANKOT Ckt-1&2	8/11/2020	9:10	17:20	.....	425	428	ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.	
268	220Kv RSD-SARNA Ckt -3	8/11/2020	9:30	16:40	.....	6	9	ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.	
269	220 KV Muktsar Bathinda D/C	8/11/2020	9.15	15.30	51, 52	68	53	tree trimming	
270	220 KV Muktsar Ghubaya s/c	8/11/2020	9.30	16.30	....	47	65	tree trimming	
271	132 KV Phillaur-Jamalpur line	8/11/2020	8:40	16:20	....	30	51	Ground Maintenance Tower no. 30 to 51.	
272	132kv BBMB JAL.-Urban estate	8/11/2020	10.20,	6:00	18	5	17,	Tree cutting is done between towers span no.5-6,14-15,16-17.	

283

273	132KV Nakkian-Nawanshehar	8/11/2020	9:10	18:40	.....	54	78	tree trimming done
274	220 KV JAMALPUR-GANGUWAL	8/11/2020	10:00	16:00	NIL	29	30	TREE CUTTING BETWEEN TOWER NO. 29-30.
275	400 KV Rajpura-Dhuri CKT-1 & 2	8/11/2020	9:30	16:50	NR	17	18	For checking & tightening the nut bolt of tower's members
276	400 KV Rajpura-Ablawal	8/11/2020	9:30	16:50	NR	30	35	Checking & tightening of nut bolts of dead end towers and tree pruning between towers
277	220 kv Sunam-Patran/Sunam-Bangan	8/11/2020	09:58	16:25	NR	41	68	Line patrolled and tree cutting from tower No. 41 to 68
278	400 KV Rajpura - Dhuri line ( D.C)	8/11/2020	09:25	15:30	NR	237	238	Checked & tightened of tower structure. Tower No. 237 and 238
279	220 kv Balachak-Naraingarh Ckt No.1	8/12/2020	13:20	18:58	4	34		Hot Point Removed
280	220 KV-Ablawal - Faganmajra Ckt-2	8/12/2020	8:30	12:10	15	34	34	Attend hot point at 220Kv s/s end gantry on yph
281	132 kv Butari Varpal	8/13/2020	10:00	16:00		230	244	Tree cutting
282	220 Kv Rashiana-Patti line	8/13/2020	8:35	17:20	48			Hot Point Removed on wave Trap patti side
283	132Kv KANGRA-SHANAN CKT-1&2	8/13/2020	9:30	16:45	.....	18	32	Bamboo cutting between spans.
284	220 KV Raahan Jattan-Hoshiarpur	8/13/2020	8:50	16:40	....	64	76	Ground Maintenance Tower no. 64 to 76. Tree cutting Between T.No.66-67-68-69-70-71,73-74.
285	132Kv Kapurthala-Science city	8/13/2020	0:00	7:12	NA	86	99	Tree cutting is done between towers span no.86-87,93-94,96-97,98-99
286	132KV Mahilpur-Banga	8/13/2020	5:00	12:50	92/119	6		replace the B-Phase string on tower no 6.
287	132 KV JAMALPUR-SWADDI LINE	8/13/2020	9:30	17:05	92	116/7	116/7	CHANGED THE FLASHED DISC INSULATOR STRING OF R-PHASE AT STRAIGHT TOWER NO.116/7
288	220 KV JAMALPUR-GANGUWAL 2	8/13/2020	10:00	16:00	1	35	38	TREE CUTTING BETWEEN TOWER NO. 35-36, 36-37, 37-38.
289	220 KV Rajpura-Ablawal	8/13/2020	9:10	16:05	NR	9	30	Checking & tightening of nut bolts of dead end towers and tree pruning between towers

284



290	220 KV Rajpura-Ablowal	8/13/2020	10:30	16:01	NR	9	30	Checking & tightening of nut bolts of dead end towers and tree pruning between towers Line Patrolled from tower No. 1 to 43.
291	400 kV Dhuri-Talwandi Double Circuit	8/13/2020	09:30	17:48	NR	1	43	Line Patrolled from tower No. 1 to 43.
292	132 kv Jandiala-Tangra Line	8/14/2020	9:00	16:10		72	82	Tree Cutting
293	220 KV Muktsar Katorewala	8/14/2020	9:10	15:05	88	3	...	B-phase jumper hot point attended
294	132 KV srainaga kotkapura2	8/14/2020	9:30	16:10	8687	442	413	tree trimming
295	220 KV Reahan Jattan-Hoshiarpur	8/14/2020	9:00	15:10	....	77	91	Ground Maintenance Tower no. 77 to 91.Tree cutting Between T.No.85-84-83,78-77.
296	220Kv Gvk-Bottianwala ckt 1	8/14/2020	6:00	5:16	99	149		Setright freely suspended polymer string of Lower phase(B phase)at tw no.149 .
297	220Kv Patti-Chohla sahib	8/14/2020	0:43	13:12	92	Gantry at Chohla sahib s/s .		Attended hot point of R phase T clamp at Gantry Chohla sahib s/s .
298	132KV MPH2-Tanda/Bhogpur	8/14/2020	9:10	16:50	.....	MB12	MB27	Patrolling & tree trimming done
299	220 KV JAMALPUR-DHANDARI-1	8/14/2020	10:00	16:00	36	2	13	TREE CUTTING BETWEEN TOWER NO. 02-03, 3-4, 4-5, 5-6, 8-9, 9-10, 12-13.
300	220 kv kotkrore-botianwala	8/14/2020	10:25	14:30	-	80/1	-	Jumpers of R, Y & B connected at dead end Tower No 80/1
301	400 KV Rajpura-Dhuri CKT-1 & 2	8/14/2020	9:15	15:50	NR	19	20	For checking & tightening the nut bolt of tower's members
302	400 KV NPL-Rajpura	8/14/2020	9:30	16:05	NR	1	29	Checking & tightening of nut bolts of dead end towers and tree pruning between towers
303	400 KV Rajpura-Railway	8/14/2020	9:30	16:05	NR	1	14	Checking & tightening of nut bolts of dead end towers and tree pruning between towers
304	220 kv Sunam-Patran/Sunam-Bangan	8/14/2020	10:00	17:01	NR	69	95	Line patrolled, Tree Cutting, members missing and Checked Ground Position from tower No. 69 to 95
305	132 KV Muktsar srainaga	8/15/2020	9:15	15:25	....	490	442	tree trimming

285

306	220 kv WG- Varpal	8/17/2020	10:00	16:00		16	26	Tree cutting
307	132 kv WG- SHGP -1&2	8/17/2020	10:00	16:00				Line petrolling
308	220 KV Muktsar Bathinda D/C	8/17/2020	9:15	14:10	....	53	44	tree trimming
309	132 KV Muktsar Kotkapura 1	8/17/2020	9:30	15:40	3744	267	225	tree trimming
310	220 KV Nakodar-Hoshiarpur	8/17/2020	9:40	16:55	....	28	40	Ground Maintenance Tower no. 28 to 40. Tree cutting Between T.No.30-31,32-33.
311	132Kv BBMB Jai.-Dhilwan	8/17/2020	2:24	7:12	19,	22	27	Tree cutting is done between towers span no.22-23,24-25,26-27.
312	132KV Nakkian-Nawanshehar	8/17/2020	9:10	4:10	.....	28	56	Checking of Flash Disc Insulators.
313	220 KV PG-DHANDARI	8/17/2020	10:00	18:10	45	GANTRY	ISOLAT OR	REPAIRED ALL 3 NO.'S JUMPERS FROM GANTRY TO ISOLATOR AT 220KV DHANDARI S/S.
314	220KV R.T.P - G1 Ckt-3	8/17/2020	10:20	14:20	30	.....	.....	attended hot point of R-phase at gantry side on wave trap at 220KV S/S G1
315	220kv Line G2 - G3	8/17/2020	14:40	17:40	91	.....	.....	attended hot point of R-phase at gantry side on wave trap at 220KV S/S G2
316	400 KV Rajpura-Dhurl CKT-1 & 2	8/17/2020	9:15	16:30	NR	21	22	For checking & tightening the nut bolt of tower's members
317	400 KV NPL-Nakoder	8/17/2020	9:15	16:30	NR	1	30	Checking & tightening of nut bolts of dead end towers and tree pruning between towers
318	400 KV Rajpura - Dhurl line (D.C)	8/17/2020	10:00	16:00	NR	236	236	Checked & tightened of tower structure. Tower No. 236
319	220 kv Nabha-Bhawanigarh (D.C)	8/17/2020	09:40	16:20	NR	1	54	Line patrolling is done from Tower no 1 to 54
320	220 kv WG-Sarna-3,4	8/18/2020	10:00	16:00		90	105	Tree cutting
321	220Kv RSD-SARNA CKT -3	8/18/2020	9:35	16:40	.....	40	44	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
322	132Kv KANGRA-PATHANKOT CKT-1&2	8/18/2020	9:30	17:10	.....	270	295	Bamboo cutting between spans.
323	132 kv Civil line Naraingarh line	8/18/2020	8:15	16:30		20	40	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.

286

324	220 KV Muktsar Bathinda D/C	8/18/2020	9:45	14:40	....	44	35	tree trimming
325	132 KV Muktsar faridkot	8/18/2020	14:15	18:20	....	98	53	tree trimming
326	400 KV Nakodar-Rajpura CKT No.2	8/18/2020	9:00	16:50	....	216	229	Ground Maintenance Tower no. 216 to 229.
327	400 KV NPL Nakoder	8/18/2020	9:20	16:10	NR	30	60	Line patrolled and tree pruning between towers
328	220 KV Lehra-Mohabbat-Dhanaula	8/18/2020	09:50	18:35	NR	44	44/40	Line patrolling is done from Tower no 44 to 44/40
329	132 kv Batala -Pakharapur	8/19/2020	8:45	12:05	74	1	20	Hot point attended at Gantary
330	132 kv Butari - Tangra	8/19/2020	10:00	16:00		9	19	Tree cutting
331	132 kv Varpal-Tarn taran line	8/19/2020	8:55	15:50				ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
332	220 KV Muktsar Bathinda D/C	8/19/2020	9:20	14:45	....	35	15	tree trimming
333	132 KV Muktsar faridkot	8/19/2020	9:10	15:45	54	H pole no. 53-01 & T-126-120	....	tree trimming
334	220 KV Kotla Janga-Kartarpur CKT NO.2	8/19/2020	9:20	16:40	....	9	23	Ground Maintenance Tower no. 9 to 23.Tree cutting Between T.No.10-11,13-14.
335	220kv BBMB JAL.-Jamsher D/C	8/19/2020	0:00	0:00	NA	8	32	Tree cutting is done between towers span no.8-9,26-27 and ground maintenance at fw no.32.
336	132kv MPH4-Shri Hargobindpur -2	8/19/2020	9:10	22:20	37	110		R-Phase Hot point attended
337	220 KV PG-DORAHA	8/19/2020	10:05	16:35	NIL	36	63	TREE CUTTING BETWEEN TOWER NO. 36-37, 40-41, 43-44, 47-48, 49-50, 53-54, 57-58, 62-63. CHECKED THE TIGHTNESS OF NUT BOLTS AT TOWERS NO. 36,49,57 & 62
338	220 KV JAGRAON-AJITWAL	8/19/2020	13:20	19:50	48	39/1	39/1	REPAIRED THE BROKEN JUMPER OF R-PHASE AT DEAD END TOWER NO. 39.1
339	400 KV NPL- Nakoder	8/19/2020	9:00	16:40	NR	60	90	Checking & tightening of nut bolts of dead end towers and tree pruning between towers

287

340	220 KV Lehra-Mohabbat-Dhanaula	8/19/2020	09:40	17:15	NR	1	31	Line patrolling is done from Tower no 1 to 31
341	220Kv Varpal -Rashiana	8/20/2020	8:25	15:40	.	1	25	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
342	132 KV Muktsar Interlink ckt.1&2	8/20/2020	12:05	14:15	....	1	9	tree trimming
343	220 KV Nakodar-Hoshiarpur	8/20/2020	9:00	16:30	....	11	27	Ground Maintenance Tower no. 11 to 27,Tree cutting Between T.No.11-12,13-14,19-20,26-27.
344	132KV Hoshiarpur-Mahilpur-2	8/20/2020	5:30	13:50	96	18		replace the R-Phase Flash string on tower no 18
345	220 KV PG-DORAHA	8/20/2020	10:10	16:05	NIL	64	94	TREE CUTTING BETWEEN TOWER NO. 64-65, 68-69, 72-73, 77-78, 83-84, 88-89, 93-94. CHECKED THE TIGHTNESS OF NUT BOLTS AT TOWERS NO. 64,77 & 94
346	400 KV Rajpura - Dhuri line (D.C)	8/20/2020	10:45	17:40	NR	145	146	Checked & tightened of tower structure. Tower No. 145,146
347	220Kv Patti-Algonkothi	8/21/2020	9:20	16:55		50	64	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
348	220KV RSD-SHAHPURKANDI CKT-1&2	8/21/2020	9:20	16:30	.....	1	23	Number plates and ACD installed at tower no.1 to 4,20 to 23
349	220 KV Muktsar Bathinda D/C	8/21/2020	9:50	15:40	....	15	10	tree trimming
350	132 KV Muktsar faridkot	8/21/2020	9:05	16:30	55	120	108	tree trimming in Muktsar Sadiq section
351	132 KV Goraya-phillaur line	8/21/2020	9:30	16:50	....	137	149	Ground Maintenance Tower no. 137 to 149,Tree cutting Between T.No.145-146-147
352	132Kv Kapurthala-Science city	8/21/2020	13:12	9:36	19	107		Replaced flashed disc insulators of R phase at dead end Tw no.107 .
353	220 KV LALTON-DHANDARI	8/21/2020	10:30	16:18	NIL	39	44	TREE CUTTING BETWEEN TOWER NO. 39-40, 40-41, 41-42, 42-43, 43-44.
354	400 KV Rajpura - Dhuri line (D.C)	8/21/2020	09:30	16:20	NR	146	162	Tree cutting/trimming is done between tower no-146 to 162

288



355	132Kv Hakima-Gate-Sakkatri Bagh	8/22/2020	8:40	13:10		1	9	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
356	220Kv RSD-SARNA CKT -3	8/22/2020	9:25	16:45	.....	86	90	ground mtc,tree cutting ,checking of stubs,Number plates and Acc installed.
357	132Kv KANGRA-SHANAN CKT-1&2	8/22/2020	9:20	16:50	.....	106	152	Bamboo cutting between spans.
358	132 kv WG- Batala 1,2	8/22/2020	10:00	16:00		1	12	Tree cutting
359	220 KV Nakodar-Noormahal Line	8/22/2020	9:10	13:50	....	19	41	Ground Maintenance Tower no. 19 to 41.Tree cutting Between T.No.19-20,22-23,30-29,35-34,40-41.
360	220kv Bhakra-Mahipur-1	8/22/2020	9:30	17:15	11/120	115		replace the B-Phase Flash string on tower no 115
361	400 KV Rajpura-Dhuri CKT-1 & 2	8/22/2020	11:10	17:20	NR	23	24	For checking & tightening the nut bolt of tower's members
362	400 KV Rajpura-Dhuri CKT-1 & 2	8/22/2020	9:30	16:10	NR	46	47	For checking & tightening the nut bolt of tower's members
363	400 KV Rajpura - Dhuri line (D.C)	8/22/2020	09:40	16:35	NR	162	180	Tree cutting/trimming is done between tower no-162 to 180
364	132 KV Line Bilaspur - Sihora	8/23/2020	7:15	17:50	38	35	37	01 No.Flashed R-phase Disc insulator string is replaced at tower no. 35 and earth Breakdown is attended between tower no 35 to 37.
365	132Kv Sarna -Gurdapur CKT-1&2	8/24/2020	9:20	17:35	.....	517	626	patrolling of line.
366	132Kv KANGRA-SHANAN CKT-1&2	8/24/2020	9:15	17:30	.....	12	148	checking of retaining walls of tower situated i hilly area.
367	132 kv WG- Batala 3	8/24/2020	10:00	16:00		26	36	Tree cutting
368	220 KV Muktsar Bathinda D/C	8/24/2020	9:15	16:10	....	1	10	tree trimming
369	132 KV Muktsar faridkot	8/24/2020	9:30	17:45	56	84	95	tree trimming in Muktsar Sadiq section
370	400 KV Nakodar-Makhu CKT No.2	8/24/2020	9:20	16:50	....	132	150	Ground Maintenance Tower no. 132 to 150. Tree cutting Between T.No.144-143,147-146,138-139.
371	132KV Nakkian-Nawanshehar	8/24/2020	9:05	17:15	.....	54	72	Checking of Flash Disc insulators.

289

372	220 KV LALTON-HAMBRAN	8/24/2020	10.05	16.00	NIL	3	23	TREE CUTTING BETWEEN TOWER NO. 3-4, 8-9, 13-14, 17-18, 22-23. CHECKED THE TIGHTNESS OF NUT BOLTS OF TOWERS No. 20 & 21
373	220 kv Sunam-Patran/Sunam-Bangan	8/24/2020	09:50	16:20	NR	96	108	Line patrolled, Tree Cutting, members missing and Checked Ground Position from tower No. 96 to 108
374	220KV RSD-SHAHPURKANDI CKT-1&2	8/25/2020	9:50	16:50	.....	1	28	ground mtc, tree cutting between span no. 27/28 and make path for tower no. 28 and checking of towers from 5 to 19
375	132kv KANGRA-SHANAN CKT-1&2	8/25/2020	9:30	15:40	.....	210	213	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
376	132kv varpal-TarnTaran	8/25/2020	9:00	15:50	.....	5	26	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
377	132 KV Muktsar faridkot	8/25/2020	9:10	16.00	57	95	108	tree trimming in Muktsar Sadiq section
378	220 KV Muktsar Katorewala	8/25/2020	9:30	15.15	...	1	25	tree trimming
379	132KV Hoshiarpur-Mahilpur Line	8/25/2020	9:00	17:10	.....	60-70	80-87	Patrolling of Line
380	220 KV LALTON-HAMBRAN	8/25/2020	10.10	16.05	NIL	26	38	TREE CUTTING BETWEEN TOWER NO. 26-27, 29-30, 32-33, 35-36, 37-38. CHECKED THE TIGHTNESS OF NUT BOLTS OF TOWERS No. 30 & 35
381	220kv Line Ganguwal - G2	8/25/2020	9:20	17:00	.....	133	147	Tree cutting between span no 133-134, 135-136, 141-142, 144-145, 145-146 and 146-147 is done.
382	400 KV Rajpura-Dhuri CKT-1 & 2	8/25/2020	10:00	16:30	NR	42	43	For checking & tightening the nut bolt of tower's members
383	220 kv Bhalwan-Dhanaula (D.C)	8/25/2020	09:58	16:00	NR	1	48	Tree Cutting, members missing and Checked Ground Position from tower No. 1 to 48
384	132kv verka-jandiala	8/26/2020	8:55	16.05	.....	12	31	Tree Cutting & General MTC
385	132KV KANGRA-PATHANKOT CKT-1&2	8/26/2020	9:20	18:10	.....	462	479	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.

386	220 kv Butari -Varpal	8/26/2020	10.00	16.00		190	208	Tree cutting
387	220 KV Muktsar Katorewala	8/26/2020	9.10	15.30	...	25	50	tree trimming
388	220 KV Nakodar-Kartarpur CKT No.1	8/26/2020	9:10	16:20	....	64	78	Ground Maintenance Tower no. 64 to 78. Tree cutting Between T.No.67-68,71-72
389	132KV Nakkian-Nawanshehar	8/26/2020	9:05	16:50	.....	72	89	Checking of Flash Disc insulators.
390	220 KV LALTON-FZR RD.	8/26/2020	9.45	16.15	NIL	...	...	TREE CUTTING BETWEEN TOWER NO. 29/2-3, 29/6-7, 29/10-11, 29/12-13-14, 29/17-18. CHECKED THE TIGHTNESS OF NUT BOLTS OF TOWERS NO. 29/10 & 29/18
391	m/	8/26/2020	9:25	17:15	.....	152	177	Tree cutting between span no 152-153,167-168,175-176 and 176-177 was done
392	400 KV Rajpura-Dhuri CKT-1 & 2	8/26/2020	9:30	16:40	NR	54	55	For checking & tightening the nut bolt of tower's members
393	220 kv Dhanuala- Mansa/Lehra Mohabbat	8/26/2020	09:40	17:10	NR	44/86	44/118	Line patrolled, Tree Cutting, members missing and Checked Ground Position from tower No. 44/118 to 44/86
394	220Kv RSD-SARNA CKT -3	8/27/2020	9:30	16:20	.....	73	77	ground mtc, tree cutting ,checking of stubs, Number plates installed.
395	132 kv Butari Dhillwan	8/27/2020	10.00	16.00		130	142	Tree cutting
396	132 KV Muktsar Kotkapura 1	8/27/2020	9.20	16.20	3757	219	222	emergency tree trimming
397	132 KV Muktsar Malout	8/27/2020	9.30	15.10	58	7	8	loose earth wire span tightened
398	220 KV Muktsar Katorewala	8/27/2020	9.30	15.10	...	50	64	tree trimming
399	220 KV Nakodar-Kartarpur CKT No.2	8/27/2020	9:30	16:30	....	32	49	Ground Maintenance Tower no. 32 to 49. Tree cutting Between T.No.35-36,42-43,47-48-49.
400	132KV Nakkian-Nawanshehar	8/27/2020	9:00	19:50	.....	17	27	Checking of Flash Disc insulators.
401	220 KV LALTON-HAMBRAN	8/27/2020	9.40	16.00	NIL	38	57	TREE CUTTING BETWEEN TOWER NO. 38-39, 42-43, 46-47, 47-48, 52-53, 54-55, 56-57. CHECKED THE TIGHTNESS OF NUT BOLTS TOWERS NO.39 & 54

291

R

402	220kV Line Ganguwal - G2	8/27/2020	10:00	16:50	.....	175	176	Tree cutting between span no 175-176 was done.
403	220 kv Sadaq - Ferozpur	8/27/2020	10:30	12:30	97	121	-	Attended Hot point of R-phase at tower 121 and checking of tightness of other phases
404	400 KV Rajpura-Dhuri CKt-1 & 2	8/27/2020	9:10	16:50	NR	127	128	For checking/tightening the nut bolt of tower's members
405	220 kv Patran-Bangan/Sunam-Bangan	8/27/2020	09:55	16:55	NR	14/01	14/36	Line patrolling is done from Tower no 14/1 to 14/36
406	220kv RSD-SARNA CKT-1,2,3	8/28/2020	9:40	17:05	.....	100	109	ground mtc, tree cutting ,checking of stubs,checking of all tower accessories and installed number plates on tower 107 to 109 of rsd-sarna ckt-3 and 100,101 of rsd-sarna ckt-1&2
407	132kv Verka-Katunangal	8/28/2020	9:10	16:05		808	847	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
408	132 KV Muktsar Kotkapura1	8/28/2020	9:15	16:00	3761	209	219	emergency tree trimming
409	220 KV Muktsar Bathinda D/C	8/28/2020	9:30	15:50	58	44	46	emergency tree trimming
410	220 KV Nakodar-Kartarpur CKT No.1	8/28/2020	9:00	16:20	....	79	84	Ground Maintenance Tower no. 79 to 84,Tree cutting Between T.No.28-29,22-21.
411	132KV Hoshiarpur-Mahilpur-1	8/28/2020	5:40	15:35	4	74		Y-Pahse Flash insulator string replace
412	220 KV PG-SAHNEWAL	8/28/2020	10:20	16:15	NIL	242	256	TREE CUTTING BETWEEN TOWER NO. 242-243, 244-245, 247-248, 250-251, 255-256 .
413	220kV Line Ganguwal - G2	8/28/2020	10:15	16:10	.....	180	187	Tree cutting between span no 180-181 was being done
414	400 KV Rajpura-Dhuri CKt-1 & 2	8/28/2020	9:15	16:50	NR	92	93	For checking & tightening the nut bolt of tower's members
415	400 KV Rajpura-Dhuri CKt-1 & 2	8/28/2020	9:15	16:50	NR	108	109	For checking & tightening the nut bolt of tower's members
416	132kv Verka- Jandiiala	8/29/2020	9:00	16:50		32	68	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.

2992



417	220Kv RSD-SARNA CKT -3	8/29/2020	9:25	17:05	.....	3A	18	ground mtc,tree cutting ,checking of stubs from tower no.3A TO 3,3 TO 4 and installed number plates on tower no.7,12,18.
418	132Kv KANGRA- PATHANKOT CKT-1&2	8/29/2020	9:10	17:20	.....	386	458	Bamboo cutting between spans.
419	132 KV Kotkapura2 Panjgrain	8/29/2020	9:20	15:40	58	313	314	Y-ph damaged conductor (already predicted) repaired
420	132 KV Goraya-Noormahal line	8/29/2020	9:20	16:10	....	51	67	Ground Maintenance Tower no. 51 to 67. Tree cutting Between T.No.66-67.
421	132Kv Kartarpur-Beas	8/29/2020	0:00	0:00	NA	48	49	Tree cutting is done between tower span no.48-49 .
422	132Kv Pims-Science city	8/29/2020	12:00	6:00	15	53		Patrolled line after tripping and replaced flashed disc insulators of R,B phase at Tw.no.53 .
423	220 KV RTP-GHULAL	8/29/2020	9:30	16:30	NIL	157	171	TREE CUTTING BETWEEN TOWER NO. 157-158, 161-162, 165-166, 168-169, 170-171.
424	220 KV RTP-GHULAL	8/29/2020	9:25	16:40	NIL	82	103	TREE CUTTING BETWEEN TOWER NO. 82-83, 83-84, 87-88, 89-90, 93-94, 98-99, 102-103 .
425	400 KV Rajpura-Dhuri CKT-1 & 2	8/29/2020	9:25	15:35	NR	25	26	For checking & tightening the nut bolt of tower's members
426	220KV Line G1 ,Rajpura Ckt-2	8/30/2020	8:00	14:55	58	....	....	flashed R-phase Disc insulator replaced on Dead -End tower no 39
427	220Kv RSD-SARNA CKT -1&2	8/31/2020	9:35	16:25	.....	26	41	ground mtc,tree cutting ,checking of stubs,checking of all tower accessories. And installed ACD at tower no.37,35,and checking of towers from 26 to 30
428	132 KV Kotkapura2 Panjgrain	8/31/2020	11:05	16:20	....	373	376	tree trimming
429	220 KV Nakodar-Hoshiarpur	8/31/2020	9:20	16:40	....	1	30	Ground Maintenance Tower no. 1 to 11. Tree cutting Between T.No.10-11,29-30,9-8.
430	132Kv Kartarpur-Beas	8/31/2020	7:12	0:00	NA	66	126	Tree cutting is done between towers span no.66-67, 124-125,125-126.
431	132KV Nakkian-Nawanshehar	8/31/2020	9:00	17:30	.....	136/1	136/37	Checking of Flash Disc insulators.

2023

S

432	132 KV JAMALPUR-SWADDI LINE	8/31/2020	8:00	15:15	14	....	....	CHANGED THE FLASHED DISC INSULATOR STRING OF B-PHASE AT TOWER NO. 116/2
433	400 KV Rajpura-Dhuri CKT-1 & 2	8/31/2020	9:30	17:00	NR	92	93	For checking & tightening the nut bolt of tower's members
434	400 KV Rajpura-Dhuri CKT-1 & 2	8/31/2020	9:30	17:00	NR	100	101	Tree pruning between towers
435	132KV KANGRA- PATHANKOT CKT-1&2	9/1/2020	9:30	16:50	.....	282	306	Ground mtc,tree cutting ,checking of stubs,checking of all tower accessories from 282 to 286 and bamboo cutting in span 305/306
436	220 KV RSD-SARNA CKT-1&2	9/1/2020	9:20	16:20	.....	35	37	Ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.
437	132KV KANGRA- PATHANKOT CKT-1&2	9/1/2020	9:10	17:05	.....	292	298	Ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.
438	220 KV Civil Line-Fatehgarh Churian Line	9/1/2020	9:00	16:50	-	46	21	Tree Cutting
439	220 KV Muktsar Bathinda D/C	9/1/2020	9:15	15:15	....	155	106	tree trimming
440	220 KV Nakodar-Rehana Jattan	9/1/2020	9:20	16:10	....	59	71	Ground Maintenance Tower no. 59 to 71.Tree cutting Between T.No.62-63,66-67,70-71.
441	132KV Nakkian- Nawanshehar-1	9/1/2020	9:05	17:10	74	136/13		R-Pahse Flash insulator string replace
442	400 KV Rajpura-Dhuri CKT-1 & 2	9/1/2020	9:15	16:40	NR	94	95	For checking & tightening the nut bolt of tower's members
443	400 KV Rajpura-Dhuri CKT-1 & 2	9/1/2020	9:15	16:40	NR	96	97	Tree pruning between towers
444	220KV Algonkothi-Patti Ckt No.1	9/2/2020	8:00	17:30	79	38	50	Dead end nut bolt tightening & cleaning of disc
445	220 KV RSD-SARNA CKT-1&2	9/2/2020	9:25	16:30	.....	31	34	Ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.
446	132 KV Urban Estate-Kotta Janga Line	9/2/2020	11:20	13:10	46	23	37	Jumper tightening of T.No. 23,32,37.
447	132Kv Pims-Science city	9/2/2020	10:48	0:00	NA	28	56	Tree cutting is done between tower span no.28-29,52-53,55-56 .
448	132KV Nakkian- Nawanshehar-1	9/2/2020	9:10	16:55	.....	103	105	Tree trimming done

20/11

449	220 KV PG-SAHNEWAL	9/2/2020	9.55	16.00	NIL	258	272	TREE CUTTING BETWEEN TOWER NO. 258-259, 259-260, 262-263, 267-268, 270-271.
450	220kv Line Ganguwal - G2, Ganguwal - Bhari	9/2/2020	9:30	16:35	....	126	132	Tree cutting between span no 126-127,130-131,and 131-132 is done.
451	400 KV NPL - Rajpura	9/2/2020	9:30	15:40	NR	24	25	Checking & tightening of nut bolts of dead end towers
452	220 kv Bhatwan-Chajli	9/2/2020	09:50	16:00	NR	1	35	Line patrolling is done from Tower no 1 to 35
453	132 KV Verka Pakharpura Line	9/3/2020	8:30	17:00		804	820	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
454	220 KV Muktsar Bathinda D/C	9/3/2020	9.15	16.00	....	76	89	tree trimming
455	132 KV Kotkapura2 Panjgrain	9/3/2020	10.30	17.00	....	368	357	tree trimming
456	132 KV Urban Estate-Kotla Janga Line	9/3/2020	11:20	14:05	53	54	77	Jumper tightening of T.No. 54,77,Tree cutting Between T.No.22-23,gantry-22.
457	220Kv Jamsher-Badshahpur	9/3/2020	0:00	7:12	NA	25	33/10	Tree cutting is done between tower span no.25-26,26-27,33/9-33/10 .
458	220kv Bhakra-Mahilpur-1	9/3/2020	8:00	18:10	24/120	53	90	B-Pahse Flash insulator string replace on 71/1
459	220 KV PG-SAHNEWAL	9/3/2020	9.50	16.05	NIL	....	....	TREE CUTTING BETWEEN TOWER NO. 273-274, 282-283, 284-285, 287-288, 290/2-3, 290/6-7, 290/9-10, 290/12-13.
460	400 KV NPL - Rajpura	9/3/2020	9:20	16:00	NR	2	3	Checking & tightening of nut bolts of dead end towers
461	220 kv Bhatwan-Dhanaula (D.C)	9/3/2020	09:40	16:01	NR	49	80	Line patrolling is done from Tower no 49 to 80
462	132KV KANGRA-PATHANKOT CKT-1&2	9/4/2020	9:20	18:40	.....	310	322	Checking of hilly area tower'S after heavy rain.tower no.310,311,321,322,and tower no.05 of mamoon tap.
463	220 KV RSD-SARNA CKT-4	9/4/2020	9:35	16:40	.....	1	19	Scanning of dead end towers with IIR camera
464	132kv Patti- Bhikhiwind	9/4/2020	8:00	17:30		1	18	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.

205

465	220 KV Muktsar Bathinda D/C	9/4/2020	9:15	16:00	....	70	76	tree trimming	
466	132 KV Kotkapura2 Panjgrain	9/4/2020	9:10	18:30	....	357	353	tree trimming	
467	132KV Pims-Science city	9/4/2020	0:00	7:12	NA	51	70	Tree cutting is done between towers span no.67-68,69-70 and ground maintenance of tower at tw no.51 .	
468	132kv Hoshiarpur-Mahilpur-1	9/4/2020	9:00	17:10	11	16	17	R-Pahse Flash insulator string replace	
469	220 KV RTP-GAUNSGARH	9/4/2020	10:00	16:00	26	82	103	TREE CUTTING BETWEEN TOWER NO. 82-83, 87-88, 96-97, 98-99, 102-103.	
470	400 KV NPL- Rajpura	9/4/2020	9:30	16:15	NR	15	16	Checking & tightening of nut bolts of dead end towers	
471	400 KV NPL-Nakoder	9/4/2020	9:15	16:30	NR	90	119	Checking & tightening of nut bolts of dead end towers and tree pruning between towers	
472	220 kv Bhalwan- 220 kv chajli (D.C)	9/4/2020	09:50	16:56	NR	36	65	Line patrolling is done from Tower no 36 to 65	
473	132KV civil Line khanna Paper Mill Line	9/5/2020	9:20	15:05		1	9	Tree Cutting	
474	132KV KANGRA- PATHANKOT CKT-1&2	9/5/2020	9:30	16:50	.....	299	307	Ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.	
475	220 KV RSD-SARNA CKT-3&4	9/5/2020	9:30	16:45	.....	18	22	Ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.	
476	220 KV Muktsar Bathinda D/C	9/5/2020	9:10	15:20	....	76	45	tree trimming	
477	132 KV Goraya-phillaur line	9/5/2020	9:10	16:30	....	189	213	Ground Maintenance Tower no. 189 to 213. Tree cutting Between T.No.190-191,204-205-206.	
478	132kv Hoshiarpur-Mahilpur-1	9/5/2020	10:00	13:50	13	17		R-Pahse Flash insulator string replace	
479	220kv Line Ganguwal - G2, Ganguwal - Bhari	9/5/2020	9:40	18:50	....	....	....	Tree cutting between span no 01-02,03-04,04-05,10-11,131-132 was done	
480	400 KV NPL- Rajpura	9/5/2020	9:30	16:00	NR	4	7	Checking & tightening of nut bolts of dead end towers	
481	220 kv Bhalwan- 220 kv chajli (D.C)	9/5/2020	09:45	16:01	NR	66	90	Line patrolling is done from Tower no 66 to 90	

296

482	132 KV SARNA-GSP CKT-1&2	9/7/2020	9:25	16:25	.....	534	539	Removed the forest vines climbing on towers due to rainy season on tower no.534,536,537,539	
483	132KV KANGRA-PATHANKOT CKT-1&2	9/7/2020	9:20	17:10	.....	239	295	Bamboo cutting between spans.	
484	220KV Balachak-Naraingarh Line	9/7/2020	8:00	15:30		54	24	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.	
485	132 KV Gidderbaha-Malout	9/7/2020	14:10	16:12	001198/02	12	12	To replace disc insulator string at T.No.12 Rphase	
486	132 KV Ferozepur Faridkot	9/7/2020	9:30	16:30	....	84	60	tree trimming	
487	220 KV Muktsar(400 KV s/s) Katorewala	9/7/2020	9:10	15:30	90	50	70	tree trimming	
488	220 KV Nakodar-Hoshiarpur	9/7/2020	9:00	16:50	....	34	44	Ground Maintenance Tower no. 34 to 44.	
489	132Kv Kartarpur-Beas	9/7/2020	12:00	9:36	26	85	96	Tree cutting is done between towers span no.85-86,86-87,95-96	
490	132KV Nakkian-Nawanshehar-2	9/7/2020	9:00	18:30	80	69,77,78		B-Pahse Flash insulator string replace	
491	220KV Line Ganguwal - G2, Ganguwal - Bhari	9/7/2020	9:35	19:10	.....	11	16	Tree cutting between span no 11-12,12-13,13-14,14-15,15-16 was done	
492	220 KV Passiana-Rajla	9/7/2020	9:30	16:00	67	37	38	Attended hot point on gantry between tower 37-38 Rph	
493	400 KV Rajpura-Dhuri CKT-1 & 2	9/7/2020	9:15	16:50	NR	61	62	For checking & tightening the nut bolt of tower's members	
494	220 KV Bhalwan-Dhanaula (D.C)	9/7/2020	09:50	16:45	NR	81	122	Line patrolling is done from Tower no 81 to 122	
495	132KV SHANAN-KANGRA CKT-1&2	7/9/2020	9:10	17:00	.....	151	152	Heavy tree lopping forest area	
496	220KV Chogawan -khasa Line	9/8/2020	8:30	16:50		94	82	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.	
497	132 KV SARNA-GSP CKT-1&2	9/8/2020	8:35	16:40	.....	584	590	Ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.	
498	132KV KANGRA-PATHANKOT CKT-1&2	9/8/2020	9:20	17:20	.....	340	348	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.	

297



499	220 KV Muktsar(400 KV s/s) Katorewala	9/8/2020	9:15	15:45	...	70	78	tree trimming
500	400 KV Nakodar-Makhu Line	9/8/2020	9:20	16:10	....	1	45	Ground Maintenance Tower no. 1 to 45. Tree cutting Between T.No.12-13,16-17,27-28.
501	132Kv Pims- Science city	9/8/2020	4:48	1:12	19	39	69	Tree cutting is done between towers span no.39-40,42-43,63-64,68-69 .
502	132KV Nakkian-Nawanshehar	9/8/2020	9:10	16:50	.....	103-109	117-124	Patrolling & tree trimming done
503	220 KV PAKHOWAL-MAHAL KALAN	9/8/2020	10:05	16:00	NIL	3	23	TREE CUTTING BETWEEN TOWER NO. 3-4, 8-9, 12-13, 14-15, 19-20, 22-23.
504	220 KV JAMALPUR- GANGUWAL	9/8/2020	9:20	16:15	NIL	158	159	TREE CUTTING BETWEEN TOWER NO. 158-159.
505	220KV Line Ganguwal - G2, Ganguwal - Bhari	9/8/2020	9:25	18:55	....	17	19	Tree cutting between span no 17-18,18-19 was done
506	400 KV Rajpura-Dhuri CKT-1 & 2	9/8/2020	9:30	16:15	NR	48	49	Checking & tightening of nut bolts of dead end towers
507	220 kv Bhalwan- 220 kv chajji (D.C)	9/8/2020	09:45	16:15	NR	94/1	94/21	Line patrolling is done from Tower no 90-100 & 94/1-94/21
508	132KV SHANAN-KANGRA CKT-1&2	9/9/2020	9:15	16:50	.....	130	194	Bamboo cutting between spans.
509	132KV Varpal Naraingarh Line	9/9/2020	10:00	17:30		1	31	ground mtc; tree cutting, checking of stubs, checking of all tower accessories.
510	400 KV Nakodar-Makhu Line	9/9/2020	9:25	16:50	....	45	90	Ground Maintenance Tower no. 45 to 90. Tree cutting Between T.No.48-49,56-58,70-71,89-90.
511	132Kv BBMB Jai.-Dhilwan	9/9/2020	10:15,	10:48	23	1	247	Tree cutting is done between towers span no.1-2,225-226,244-245,246-247 .
512	132KV Nakkian-Nawanshehar	9/9/2020	9:10	17:20	.....	136/3	136/22	Checking of Flash Disc insulators.
513	220 KV PAKHOWAL-MAHAL KALAN	9/9/2020	10:05	16:00	NIL	24	43	TREE CUTTING BETWEEN TOWER NO. 24-25, 27-28, 30-31, 34-35, 38-39, 42-43.
514	400 KV Rajpura-Dhuri CKT-1 & 2	9/9/2020	9:00	17:15	NR	56	57	Checking & tightening of nut bolts of dead end towers
515	220 kv Bhalwan-Sunam(D.C)	9/9/2020	09:30	16:10	NR	46/9	46/46	Checked & tightened of tower structure from Tower No 46/9 to 46/46

298

516	132KV SHANAN-KANGRA CKT-1&2	9/10/2020	9:20	17:05	.....	102	128	Bamboo cutting between spans.	
517	220 KV Muktsar Bathinda D/C	9/10/2020	9:15	16:10	....	76	70	tree trimming	
518	220Kv Goraya-Jadla	9/10/2020	12:10	6:00	39	256/5	256/9	Replaced flashed disc insulators of B phase at Tw no. 256/6 and tree cutting is done between towers span no.256/5-256/6,256/8-256/9 .	
519	220kv Bhakra-Mahilpur-1	9/10/2020	9:10	19:20	33:120	41		B-Pahse Flash Insulator string replace	
520	132KV Nakkian- Nawanshehar-1	9/10/2020	9:10	17:10	88	136/13, 136/14	136/17	Replace the flash insulator strings	
521	132 KV JAMALPUR-MOGA- SWADDI	9/10/2020	9:40	16:05	NIL	25	34	TREE CUTTING BETWEEN TOWER NO. 25-26, 27-28, 30-31, 32-33-34.	
522	220 KV PAKHOWAL-MAHAL KALAN	9/10/2020	10:15	16:00	NIL	45	59	TREE CUTTING BETWEEN TOWER NO. 45-46, 48-49, 52-53, 56-57, 58-59.	
523	220KV Line Ganguwal - G2, Ganguwal - Bhari	9/10/2020	9:20	19:00	.....	19	30	Tree cutting between span no 19- 20,20-21,21-22,25-26,26-27,27-28,28- 29,29-30 was done.	
524	220KV Line Ghulial - Jamalpur Ckt 1 and 2	9/10/2020	9:30	17:35	.....	.....	.....	03 No.Rusted stubs Repaired of Tower No.368	
525	400 KV Rajpura-Dhuri Ckt-1 & 2	9/10/2020	9:15	16:45	NR	58	59	Checking & tightening of nut bolts of dead end towers	
526	220 KVFaganmajra-Nabha	9/10/2020	10:10	15:55	-	-	-	scanned Faganmajra end gantry with thermovision camera	
527	220 KVFaganmajra-Rajpura	9/10/2020	10:10	15:55	-	-	-	scanned Faganmajra end gantry with thermovision camera	
528	220 KVFaganmajra-Bhateri	9/10/2020	10:10	15:55	-	-	-	scanned Faganmajra end gantry with thermovision camera	
529	220 KVFaganmajra-Ablawal	9/10/2020	10:10	15:55	-	-	-	scanned Faganmajra end gantry with thermovision camera	
530	220 KV Bhalwan-Sunam(D.C)	9/10/2020	09:40	16:24	NR	46/8	19	Checked & tightened of tower structure from Tower No 46/8 to 19	
531	220 KV RSD-SARNA CKT-3&4	9/11/2020	9:18	16:20	.....	1	6	Ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.from tower no.1 to2,5 to 6.	

299

R

532	132KV Verka Mail-Mandi Line	9/11/2020	8:55	16:00	82	1	9	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
533	132 KV Panjgrain Moga	9/11/2020	9:20	17:25	...	322	351	tree trimming
534	220 KV Muktsar Abohar D/C	9/11/2020	9:10	16:00	...	13	50	tree trimming
535	220 KV Kotla Janga-Jamsher line	9/11/2020	8:00	17:10	...	1	47	Ground Maintenance Tower no. 1 to 47
536	132Kv BBMB Jal.-Focal point	9/11/2020	1:12	0:00	27	7	23	Tree cutting is done between towers span no.7-8, 18-19, 22-23.
537	220kv Bhakra-Mahilpur line	9/11/2020	9:15	17:45	.....	Ganty1	Gantry-2	Tree trimming done
538	220 KV PG-BADHANI LINE	9/11/2020	10:00	16:45	NIL	55	70	TREE CUTTING BETWEEN TOWER NO. 55-56, 58-59, 60-61, 63-64, 68-69, 69-70. CHECKED THE TIGHTNESS OF NUT BOLTS OF TOWERS NO. 58, 68 & 69
539	220kV Line Ghulal - Jamalpur Ckt 1 and 2	9/11/2020	9:45	17:15	.....	.....	.....	03 No. Rusted stubs Repaired of Tower No.374
540	220kV Line Ganguwal - G2, Ganguwal - Bhari	9/11/2020	9:50	12:50	.....	197	218	Tree cutting between span no 204-205, 205-206, 215-216, 216-217, 217-218 was done
541	400 KV Rajpura-Dhuri CKT-1 & 2	9/11/2020	9:45	16:30	NR	60	63	For checking & tightening the nut bolt of tower's members
542	220 KV Bhalwan-chajji (D.C)	9/11/2020	09:45	16:30	NR	94/22	94/47	Line patrolling is done from Tower no 94/22 to 94/47
543	132Kv BBMB Jal.-Dhilwan	9/12/2020	0:00	12:00	28	9	18	Tree cutting is done between towers span no.9-10, 14-15, 15-16, 17-18.
544	220 KV PAKHOWAL-MAHAL KALAN	9/12/2020	10:05	16:35	NIL	62	83	TREE CUTTING BETWEEN TOWER NO. 62-63, 67-68, 70-71, 74-75, 78-79, 82-83.
545	220kV Line Ghulal - Jamalpur Ckt 1 and 2	9/12/2020	9:40	17:35	.....	.....	.....	04 No. Rusted stubs Repaired of tower no.345
546	220kV Line Ganguwal - G2, Ganguwal - Bhari	9/12/2020	9:35	17:50	.....	31	36	Tree cutting between span no 31-32, 33-34, 35-36 was done.
547	400 KV Rajpura-Dhuri CKT-1 & 2	9/12/2020	9:00	15:30	NR	27	28	For checking & tightening the nut bolt of tower's members
548	400 KV NPL-Nakoder	9/12/2020	9:10	15:50	NR	23	58	For checking & tightening the nut bolt of tower's members
549	220 KV Bhalwan-Dhuri (D.C)	9/12/2020	09:20	16:00	NR	60	87	Checked & tightened of tower structure. Tower No.60 to 87

550	220KV Line Ghulal - Jamalpur Ckt 1 and 2	9/13/2020	9:20	17:05	.....	.....	.....	02 No.Rusted stubs Repaired of tower no.340	
551	132KV KANGRA-PATHANKOT CKT-1&2	9/14/2020	9:20	17:10	.....	348	354	Ground mtc.tree cutting ,checking of stubs,checking of all tower accessories.	
552	220 KV Muktsar Abohar D/C	9/14/2020	9:15	16:00	....	50	62	tree trimming	
553	132 KV Panjgrain Moga	9/14/2020	9:25	16:55	....	333	298	tree trimming	
554	132 KV Goraya-Jamalpur line	9/14/2020	11:40	15:25	45	25	44	Ground Maintenance Tower no. 25 to 44.Tree cutting Between T.No.45-44,38-39,33-34.	
555	220kv Alawalpur-Dasuya	9/14/2020	0:00	7:12	NA	224	249	Tree cutting is done between towers span no.224-225,240-241,248-249 and ground maintenance of tower at tw no.224 .	
556	220kv Bhakra-Mahilpur line	9/14/2020	9:15	17:10	.....	49	54	Patrolling & tree trimming done	
557	220 KV RTP-GHULAL	9/14/2020	10:10	16:15	NIL	135	156	TREE CUTTING BETWEEN TOWER NO. 135-136, 138-139, 142-143, 145-146, 149-150, 152-153, 155-156. .	
558	220 KV LALTON-JAGRAON	9/14/2020	9:55	16:00	NIL	42	68	TREE CUTTING BETWEEN TOWER NO. 44-45, 47-48, 52-53, 54-55, 58-59, 60-61, 64-65, 67-68. 44	
559	220 kv Makhu- Dharamkot	9/14/2020	10:40	12:50	81	-	-	Attended Hot point on wave trap at Gantry of R-phase at 220KV S/S dharamkot	
560	400 KV Rajpura-Dhuri CKT-1 & 2	9/14/2020	9:15	18:30	NR	64	65	For checking & tightening the nut bolt of tower's members	
561	220 KV Bhateri-Devigarh	9/14/2020	9:30	16:00	NR	70	80	For checking & tightening the nut bolt of tower's members	
562	220 KV Dhanuata-Mansa	9/14/2020	09:35	18:05	NR	44/15	70	Line patrolling is done from Tower no 44/15 to 70	
563	132KV KANGRA-PATHANKOT CKT-1&2	9/15/2020	9:10	17:20	.....	322	332	checking of hilly area towers, and tower no.04 of mamoon tap	
564	132 KV SARNA-PATHANKOT CKT-1&2	9/15/2020	9:35	16:35	.....	501	503	Heavy tree looping an ground maintenance	
565	220 KV Muktsar Ghubaya s/c	9/15/2020	11:15	16:35	....	10	20	tree trimming	

307  
A

566	132 KV Goraya-Jamalpur line	9/15/2020	12:20	16:15	47	11	25	Ground Maintenance Tower no. 11 to 25. Tree cutting Between T.No.12-13,17-18,21-22.
567	132Kv BBMB Jal-Kahanpur	9/15/2020	7:12	0:00	NA	5	10	Tree cutting is done between towers span no.5-6,8-9,9-10.
568	220kv Bhakra-Mahilpur line	9/15/2020	9:10	17:15	.....	78	85	Patrolling & tree trimming done
569	220 KV LADOWAL-FZR RD.	9/15/2020	9:40	16:15	NIL	...	....	TREE CUTTING BETWEEN TOWER NO. 46/5-6, 46/8-9, 46/11-12, 46/14-15. CHECKED THE TIGHTNESS OF NUT BOLTS TOWERS NO. 46/2 & 46/14
570	220KV Line Ghulal - Jamalpur Ckt 1 and 2	9/15/2020	9:15	17:10	.....	.....	.....	04 No. Rusted stubs Repaired of tower no.336
571	400 KV Rajpura-Dhuri Ckt-1 & 2	9/15/2020	09:30	17:10	NR	66	67	For checking & tightening the nut bolt of tower's members
572	220kv passiana-Rajla	9/15/2020	9:05	16:20	NR	30	30	Attended hot point at tower on Yph
573	220 kv Barnala-Sandhaur (S.C)	9/15/2020	09:40	16:30	NR	162	203	Line patrolling is done from Tower no 203 to 162
574	132KV KANGRA- PATHANKOT Ckt-1&2	9/16/2020	9:20	17:10	.....	323	332	Ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
575	132KV KANGRA- PATHANKOT Ckt-1&2	9/16/2020	9:45	16:30	.....	503	505	Heavy tree looping an ground maintenance
576	132KV Verka Power Colony Line	9/16/2020	9:15	14:45		1	9	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
577	220 KV Muktsar Abohar DIC	9/16/2020	9:15	15:30	....	62	110	tree trimming
578	132 KV Panjgrain Moga	9/16/2020	9:30	16:40	15	334	324	tree trimming
579	220 KV Kotla Janga- Kartarpur line	9/16/2020	9:00	16:45	....	94	41	Ground Maintenance Tower no. 41 to 94. Tree cutting Between T.No.49-50,55-56,78-79,84-83.
580	220Kv Alawalpur-Dasuya	9/16/2020	7:12	3:36	50	183	223	Tree cutting is done between towers span no.183-184,194-195,220-221,222-223.
581	220 kv Dhanuala-Mansa	9/16/2020	10:00	17:40	NR	44/53	44/85	Checked & tightened of tower structure. Tower No. 44/85 to 44/53
582	220Kv Civil Line -fatehgarh Line	9/17/2020	9:05	16:50		1	21	Tree Cutting & GMTC

A 302



583	132KV KANGRA-PATHANKOT CKT-1&2	9/17/2020	9:20	17:20	.....	354	360	Ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.
584	132KV KANGRA-PATHANKOT CKT-1&2	9/17/2020	8:30	18:30	.....	299	422	Scanning of dead end towers with I/R camera
585	220 KV Kotla Janga-Kartarpur line	9/17/2020	9:20	16:10	....	1	40	Ground Maintenance Tower no. 1 to 40.Tree cutting Between T.No.6-7,25-26,30-31.
586	220kv Alawalpur-Dasuya	9/17/2020	0:00	10:48	NA	163	176	Tree cutting is done between towers span no.163-164,164-165,175-176 .
587	132KV Nakkian-Nawanshehar-1	9/17/2020	9:05	16:30	.....	136/9	136/16	Checking of Flash Disc insulators.
588	220 KV LALTON-JAGRAON	9/17/2020	10:05	16:25	NIL	71	93	TREE CUTTING BETWEEN TOWER NO. 71-72, 74-75, 80-81, 81-82, 86-87, 89-90, 92-93.
589	220 KV Rajpura-Railway	9/17/2020	10:00	16:35	NR	1	14	For checking & tightening the nut bolt of tower's members
590	220 kv Barnala-Sandhaur (S.C)	9/17/2020	09:25	16:40	NR	125	162	Line patrolling is done from Tower no 162 to 125
591	220 kv WG- Udoke	9/18/2020	10:00	16:00		32	42	Tree cutting
592	132KV KANGRA-PATHANKOT CKT-1&2	9/18/2020	9:10	16:40	.....	220	228	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
593	132KV Verka Jandiala-Tangra Line	9/18/2020	9:10	16:20		42	68/3	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
594	132 KV Panjgrain Moga	9/18/2020	9:40	16:30	....	299	295	tree trimming
595	220 KV Nakodar-Noormahal Line	9/18/2020	9:35	16:20	....	27	40	Ground Maintenance Tower no. 27 to 40.Tree cutting Between T.No.40-41,30-29,26-27.
596	132KV Nakkian-Nawanshehar-1	9/18/2020	8:50	17:20	91	136/9	136/13	R-Pahse Flash insulator string replace
597	220 KV PAKHOWAL-MAHAL KALAN-2	9/18/2020	9:30	15:00	15	6	6	FIXED THE SUPPORT INSULATOR STRING ON R- PH, BECAUSE STRING WAS DETACHED FROM SUSPENSION CLAMP.
598	220 KV Faganmaira-Rajpura	9/18/2020	9:00	16:25	5/09	-	-	Attended hot point at faganmaira end gantry on Yph
599	220 kv Bhalwan-Nabha (S.C)	9/18/2020	09:30	17:10	NR	1	36	Line patrolling is done from Tower no 1 to 36

303

600	220 KV-Rajpura-mohall	9/18/2020	9:30	16:05	NR	94	105	Checking & tightening of nut bolts of dead end towers and tree pruning between towers
601	132KV Verka Power Colony Line	9/19/2020	9:30	14:30		1	6	Tree Cutting
602	220KV RSD-SHAHPURKANDI CKT-1&2	9/19/2020	9:38	16:20	.....	27	31	Bamboo cutting between spans.
603	220 kv WG-Sarna -1,2	9/19/2020	10:00	16:00		162	172	Tree cutting
604	132 KV Urban Estate-Kotla Janga Line	9/19/2020	9:00	16:10	....	83	69	Ground Maintenance Tower no. 69 to 83.
605	132Kv BBMB Jal.-Kahanpur	9/19/2020	2:24	2:24	35	1	30	Tree cutting is done between towers span no.1-2,4-5,9-10,29-30
606	220 KV SAHNEWAL-DORAH	9/19/2020	9:55	16:00	NIL	3	24	TREE CUTTING BETWEEN TOWER NO. 3-4, 7-8, 10-11, 15-16, 17-18, 19-20, 20-21, 23-24. CHECKED THE TIGHTNESS OF NUT BOLTS OF TOWERS NO.4,17 & 21
607	220KV Line Ghulal - Jamalpur Ckt 1 and 2	9/19/2020	9:05	17:40	....	....	....	04 No. Rusted stubs Repaired of tower no.333
608	220KV Line G2 - Ganguwal	9/19/2020	13:10	15:20	11	....	....	Hot Point attend on Blue Phase at tower no 212
609	220 kv Nabha-Bhawanigarh (D.C)	9/19/2020	09:45	16:20	NR	55	80	Line patrolling is done from Tower no 55 to 80
610	132KV Varpal Naraingarh Line	9/20/2020	9:00	15:40		31	57	Tree Cutting
611	220KV Line Ghulal - Jamalpur Ckt 1 and 2	9/20/2020	9:45	17:30	....	....	....	04 No. Rusted stubs Repaired of tower no. 335
612	132KV Jandiaala Tangra Line	9/21/2020	8:55	16:50		70	85	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
613	132KV KANGRA-PATHANKOT CKT-1&2	9/21/2020	9:15	17:20	.....	386	458	Bamboo cutting between spans.
614	220 kv Udoke to Varpal	9/21/2020	10:00	16:00		1	22	Tree cutting
615	132 KV Muktsar Malout	9/21/2020	9:15	15:45	....	311	239	tree trimming
616	132 KV Panigraha Moga	9/21/2020	9:30	17:10	16	298	300	emergency tree trimming
617	132 KV Goraya-Jamalpur line	9/21/2020	9:35	16:50	....	46	70	Ground Maintenance Tower no. 46 to 70.
618	220kv Bhakra-Mahilpur line	9/21/2020	9:10	17:40	.....	13	17	Patrolling & tree trimming done

304

619	220 KV RTP-GAUNSGARH	9/21/2020	10:05	16:25	NIL	55	61	TREE CUTTING BETWEEN TOWER NO. 55-56, 56-57,57-58,59-60,60-61.
620	220KV Line Ghulal - Jamalpur Ckt 1 and 2	9/21/2020	9:20	17:15	....	....	....	02 No. Rusted stubs Repaired of tower no. 332
621	220 KV Dhantuala-Mansa	9/21/2020	09:40	18:20	NR	81	113	Line patrolling is done from Tower no 81 to 113
622	220 kv Butari- Jalandhar	9/22/2020	10:00	16:00		155	165	Tree cutting
623	220kv Balachak-Khassa	9/22/2020	9:10	17:05		55	75	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
624	132 KV Panjgrain Moga	9/22/2020	9:30	17:25	....	290	274	tree trimming
625	220 KV Nakodar-Noormahal Line	9/22/2020	8:50	15:50	....	40	51	Ground Maintenance Tower no. 40 to 51.Tree cutting Between T.No.44-45,48-49.
626	132KV Hamirpur-Chohal	9/22/2020	9:00	17:10	.....	71-73	155-162	Patrolling & tree trimming done
627	220 KV LALTON-FZR RD.	9/22/2020	9:50	16:10	NIL	....	....	TREE CUTTING BETWEEN TOWER NO. 15-16, 22-23, 23-24, 27-28, 29/5-6, 29/9-10, 29/13-14, 29/16-17, 29/23-24, 29/25-26, 29/29-30. CHECKED THE TIGHTNESS OF NUT/BOLTS OF TOWERS 29/23
628	220 KV SAHNEWAL-DORAHA	9/22/2020	10:00	16:30	NIL	26	36	TREE CUTTING BETWEEN TOWER NO. 26-27, 29-30, 30-31, 34-35, 35-36. CHECKED THE TIGHTNESS OF NUT BOLTS TOWERS 30,34 &35.
629	220KV Line Ghulal - Jamalpur Ckt 1 and 2	9/22/2020	9:20	17:25	....	....	....	04 No.Rusted stubs Repaired of tower no.329
630	220 kv Bangan-chhajji (D. C)	9/22/2020	09:45	17:40	NR	120	151	Line patrolling is done from Tower no 120 to 151
631	132KV KANGRA-PATHANKOT CKT-1&2	9/23/2020	9:05	17:05	.....	505	508	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
632	220 kv Butari-Jalandhar	9/23/2020	10:00	16:00	NIL	116	124	Tree cutting
633	132 KV Panjgrain Moga	9/23/2020	9:35	18:25	....	289	264	tree trimming
634	132 KV Phillaur-Jamalpur line	9/23/2020	9:20	16:50	....	105	89	Ground Maintenance Tower no. 105 to 89.
635	132KV Nakkian-Nawanshehar-1	9/23/2020	9:10	18:30	100	136/10, 136/12	136/12, 136/15	R-Parise Flash insulator string replace

305

636	220 KV PAKHOWAL-MAHAL KALAN-1	9/23/2020	9:55	16:10	21	27	28	TREE CUTTING BETWEEN TOWER NO. 27-28.
637	220KV Line R.T.P - G1 Ckt 1 and 2	9/23/2020	9:50	18:30	.....	121	123	Tree cutting between span no 121- 122,122-123 was done
638	220 KVFaganmajra-Rajpura	9/23/2020	9:30	16:50	NR	40	67	Line patrolled and tree pruning between towers
639	220 kv Bhairwan-Nabha (S.C)	9/23/2020	09:35	16:45	NR	35	55	Line patrolling is done from Tower no 35 to 55
640	220 kv Butari-Jalandhar	9/24/2020	10:00	16:00		128	140	Tree cutting
641	132KV KANGRA- PATHANKOT CKT-1&2	9/24/2020	9:10	17:30	.....	444	479	Patrolling of towers from 444 to 479 and 1 to 4.
642	220kv Balachak-Khassa	9/24/2020	9:00	16:30		72		Wave trap hot point removed
643	132 KV Muktsar Malout	9/24/2020	9:15	15:30	....	62	46	tree trimming
644	220 KV Nakodar-Hoshiarpur	9/24/2020	9:00	16:00	....	12	25	Ground Maintenance Tower no. 12 to 25. Tree cutting Between T.No.13- 14,16-17,19-20,22-23.
645	132KV Mahipur-Banga	9/24/2020	9:05	16:30	.....	1	10	Patrolling & tree trimming done
646	220 KV LALTON-JAGRAON	9/24/2020	10:05	16:05	NIL	82	93	TREE CUTTING BETWEEN TOWER NO. 82-83, 85-86, 87-88, 89-90, 92-93.
647	220 KVFaganmajra-Rajpura	9/24/2020	9:15	17:15	NR	1	39	Checking & tightening of nut bolts of dead end towers and tree pruning between towers
648	220 kv Barnala-Sandhour (S.C)	9/24/2020	09:45	16:30	NR	50	80	Line patrolling is done from Tower no 124-113 & 80-50
649	220 KV RSD-SARNA CKT-3&4	9/25/2020	9:35	16:30	.....	22	25	Ground mtc. tree cutting ,checking of stubs,checking of all tower accessories.
650	220kv Line Ghulal - Jamalpur Ckt 1 and 2	9/25/2020	9:30	17:00	.....	.....	.....	04 No. Rusted stubs Repaired of tower no.327
651	132KV Civil Line-Naraingarh Line	9/26/2020	9:30	14:55	30	18		Maintenance of Hot Point& TREE CUTTING
652	132 kv WG- KSM	9/26/2020	10:00	16:00		1	26	Tree cutting
653	132 KV Muktsar Jalalabad	9/26/2020	9:00	15:30	....	1	25	tree trimming
654	132 KV Muktsar kotkapura1	9/26/2020	9:30	15:40	....	266	260	tree trimming
655	132 KV Urban Estate-Kotla Janga Line	9/26/2020	9:40	15:50	....	37	52	Ground Maintenance Tower no. 37 to 52.
656	132KV Phagwara-Banga	9/26/2020			69	2/2		R-Phase sporting string replace
657	220 KV KOHARA- GAUNSGARH	9/26/2020	9:40	12:30	NIL	196/2	196/12	TREE CUTTING BETWEEN TOWER NO. 196/2-3, 196/5-6, 196/8-9, 196/11- 12.

306

658	220KV Line R.T.P - G1 Ckt 1 and 2	9/26/2020	9:45	15:50	.....	169	181	Tree cutting between span no 169-170,170-171,171-172,178-179,180-181 was done.
659	220KV Line Ghulal - Jamalpur Ckt 1 and 2	9/26/2020	9:35	17:10	.....	.....	.....	04 No. Rusted stubs Repaired of tower no.323
660	220 KV Faganmajra-Bhateri	9/26/2020	9:30	16:30	NR	06/09	100/43	Attended hot point at Faganmajra end Gantry (R-ph & Y-ph)
661	220 KV Bangan-chhajli (D. C)	9/26/2020	09:35	16:00	NR	100/10	100/43	Line patrolling is done from Tower no 100/43 to 100/10
662	220KV Line Ghulal - Jamalpur Ckt 1 and 2	9/27/2020	9:25	5:15	.....	.....	.....	04 No. Rusted stubs Repaired of tower no. 317
663	132KV Varpal-Hakima gate Line	9/28/2020	9:15	16:25	.....	8	18	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
664	220Kv RSD-SARNA CKT -1&2	9/28/2020	9:40	16:55	.....	1	5	Ground mtc,tree cutting ,checking of stubs,checking of all tower accessories.
665	132KV KANGRA-PATHANKOT CKT-1&2	9/28/2020	9:10	17:20	.....	360	367	ground mtc,tree cutting,checking of stubs,checking of all tower accessories.
666	132 KV Muktsar Jalalabad	9/28/2020	9:10	16:10	.....	25	50	tree trimming
667	132 KV Muktsar kotkapura1	9/28/2020	9:50	16:00	.....	263	242	tree trimming
668	132 KV Phillaur-Jamalpur line	9/28/2020	11:50	15:10	58	103	78	Jumper tightening of tower no. 103,104,92,78
669	220kv Mahipur-Rehanajattan	9/28/2020	9:15	16:50	.....	67/18	.....	Patrolling & tree trimming done
670	220 KV KOHARA-GAUNSGARH	9/28/2020	10:00	16:20	NIL	196/13	196/30	TREE CUTTING BETWEEN TOWER NO. 196/13-14, 196/16-17, 196/19-20, 196/24-25, 296-28-29. CHECKED THE TIGHTNESS OF NUT BOLTS TOWERS 196/13 & 196/17
671	220 KV LALTON-JAGRAON	9/28/2020	9:00	16:15	53	85	85	CHANGED THE FLASHED DISC INSULATOR STRING OF Y-PHASE AT TOWER NO.85
672	220KV Line Ghulal - Jamalpur Ckt 1 and 2	9/28/2020	9:30	17:00	.....	.....	.....	07 No. Rusted stubs Repaired of tower no.310 & 312
673	220 kv Rajpura-Devlgarh	9/28/2020	9:15	17:30	NR	86	117	Checking & tightening of nut bolts of dead end towers and tree pruning between towers

307



674	132KV KANGRA- PATHANKOT CKT-1&2	9/29/2020	9:15	16:40	.....	214	230	ground mtc, tree cutting, checking of stubs, checking of all tower accessories from tower no.214 to 219 and 228 to 230.
675	132 kv WG- KSM	9/29/2020	10:00	16:00		23	33	Tree cutting
676	132 KV Muktsar Jalalabad	9/29/2020	9:00	16:20	....	51	100	tree trimming
677	132 KV Panjgrain Moga	9/29/2020	9:30	18:25	20	274	264	tree trimming
678	220 KV Mansa-Refinery2	9/29/2020	10:20	12:45	23	113	113	To Tighten crossarms of T.no.113 Ckt2
679	220 KV Mansa-Refinery2	9/29/2020	13:58	15:35	26	113	113	To Tighten crossarms of T.no.113 Ckt1
680	220 KV Nakodar-Kartarpur line	9/29/2020	9:20	16:40	....	51	63	Ground Maintenance Tower no. 51 to 63. Tree cutting Between T.No.54A-55,57-58,60-59
681	220Kv Sultanpur-Patti	9/29/2020	0:00	10:48	NA	10	28	Tree cutting is done between towers span no.10-11,12-13,27-28
682	132kv Banga-Nawanshehr line	9/29/2020	9:15	16:50	.....	1	2	Patrolling & tree trimming done
683	220 KV KOHARA- GAUNSGARH	9/29/2020	10:05	16:20	NIL	196/32	196/43	TREE CUTTING BETWEEN TOWER NO. 196/32-33, 196/35-36, 196/39-40, 196/42-43.
684	220 kv Rajpura-Devigarh	9/29/2020	9:10	16:50	NR	35	85	Checking & tightening of nut bolts of dead end towers and tree pruning between towers
685	220 kv Bangan-chhajli (D. C)	9/29/2020	09:40	16:50	NR	100/10	119	Line patrolling is done from Tower no 100/10 to 119
686	220 KV RSD-SARNA CKT-3&4	9/30/2020	9:30	16:10	.....	25	28	ground mtc, tree cutting, checking of stubs, checking of all tower accessories.
687	132KV KANGRA- PATHANKOT CKT-1&2	9/30/2020	9:10	17:20	.....	389	444	Patrolling of towers from 444 to 479 and 5 to 8
688	132 KV Muktsar kotkapura1	9/30/2020	9:30	16:50	....	238	208	tree trimming
689	132 KV Goraya-phillaur line	9/30/2020	11:10	15:30	61	138	151	Jumper tightening of tower no. 138,144,146,151
690	220Kv Sultanpur-Patti	9/30/2020	3:36	0:00	NA	66	82	Tree cutting is done between towers span no.66-67,70-71,81-82.
691	220Kv Gvk-Sultanpur	9/30/2020	0:00	0:00	NA	10	29	Tree cutting is done between towers span no.10-11,21-22,28-29.
692	132kv Hoshiarpur-Mahilpur-1	9/30/2020	9:10	16:40	44	29,30	84-85	R-phase flash string replace on tower no 29, 30. tree trimming 84-85

308

f

693	220 KV LALTON-PG-2	9/30/2020	10:15	16:15	NIL	3	11	TREE CUTTING BETWEEN TOWER NO. 3-4, 6-7, 8-9, 10-11.
694	133 KV Moga - Cholla Kalan	9/30/2020	0:15	8:30	37	21	-	Suspension flashed string of R-phase replaced at tower No.21
695	220 KV Bhateri-Devigarh	9/30/2020	9:10	17:25	NR	67	86	Checking & tightening of nut bolts of dead end towers and tree pruning between towers
696	220 KV Bhalwan-Nabha	9/30/2020	09:35	15:15	NR	45	65	Line patrolling is done from Tower no 45 to 65

309

**ANNEXURE. NO. D**  
**TRAINING NEED ASSESSMENT**

↓ 310





**PUNJAB STATE TRANSMISSION CORPORATION LIMITED**

Regd. Office: PSEB Head Office, The Mall Patiala-147001, Punjab, India.

**Corporate Identity Number: U40109PB2010SGC033814 (www.pstcl.org)**

(O/o CAO/Finance & Audit(Commercial & Regulatory Cell, 3<sup>rd</sup> Floor, Shakti Sadan Patiala.)

**Fax/Ph.No.0175-2970183 Email : fa@pstcl.org**

To

*Special Post*

Secretary,  
Punjab State Electricity Regulatory Commission,  
Site No. 3, Sector 18-A, Madhya Marg,  
Chandigarh.

Memo No. 2658 /FA/Comml.-23/Vol.-9

Dated 29-10-2020

**Subject: Compliance Status of Directive No. 5.8: Employee Training Need Assessment.**

Please refer to the above cited subject. In continuation to this office Memo No. 2472 dated 23.10.2020, please find enclosed Compliance Status in relation to Directive No. 5.8 issued in the Tariff Order for FY 2020-21 for the consideration of the Hon'ble Commission.

DA/As above

*[Signature]*  
CAO/Finance & Audit,  
PSTCL, Patiala.

*[Handwritten]* 311



**COMPLIANCE STATUS OF DIRECTIVE NO. 5.8 ISSUED IN  
TARIFF ORDER FOR FY 2020-21**

Sr. No.	Issues	PSERC Comments & Directive	PSTCL's Reply
5.8	<b>Employee Training Need Assessment</b>	PSTCL is directed to prepare a detailed Training Need Assessment (Technical, IT, Soft Skills, Finance etc.) for the employees at various level including the new recruits and submit the same for the approval of the Commission within 9 months from the date of issuance of the order.	Enclosed shortlisted online courses (Technical IT, Soft Skills, Finance etc.) through SWAYAM ( <a href="https://swayam.gov.in">https://swayam.gov.in</a> ) a program initiative by MHRD, Govt. of India for the employees at various levels (including the new recruits) to fulfil the gaps between current performance level and department/organizational objectives.  Apart from the above approved courses, any other online/offline training as required by PSTCL employees from time to time will also be arranged.

↓

Sr.No.	Name of Course Offered on Swayam Website	Course (Category)
1	Advanced Concrete Technology	Technical
2	Advanced Materials and Processes	Technical
3	Advances in UHV Transmission and Distribution	Technical
4	Advances in welding and joining technologies	Technical
5	Basic Electrical Circuits	Technical
6	Basics of Materials Engineering	Technical
7	Big Data Analytics For Smart Grid	Technical
8	Building cost estimation simplified	Technical
9	Concrete Technology	Technical
10	DC Microgrid and Control System	Technical
11	Design Of Reinforced Concrete Structures	Technical
12	Earth Sciences For Civil Engineering	Technical
13	Earthquake Resistant Design of Foundations	Technical
14	Electrical Equipment and Machines	Technical
15	Electricity & Safety Measures	Technical
16	Energy conservation and waste heat recovery	Technical
17	Energy Economics And Policy	Technical
18	Fundamental Concepts of Electricity	Technical
19	Fundamentals of Electrical Engineering	Technical
20	Industrial Safety Engineering	Technical
21	Introduction to Smart Grid	Technical
22	Irrigation and Drainage	Technical
23	Power system analysis	Technical
24	Power System Protection	Technical
25	Power System Protection and Switchgear	Technical
26	Solar Energy Engineering and Technology	Technical

*AR/12*

*3/2*

*3/2*

313

*↓*

Sr.No.	Name of Course Offered on Swayam Website	Course (Category)
1	Advanced C++	IT
2	An Introduction to Coding Theory	IT
3	Analog communication	IT
4	Applied Optimization for Wireless	IT
5	Artificial Intelligence Search Methods	IT
6	Bandit Algorithm (Online Machine Learning)	IT
7	Basics of software defined Radios and Practical	IT
8	Big Data Computing	IT
9	C and C++	IT
10	C Programming and Assembly Language	IT
11	Cloud computing	IT
12	Computer Aided Design	IT
13	Computer Aided Power System Analysis	IT
14	Computer architecture and organization	IT
15	Computer Fundamentals	IT
16	Computer Graphics	IT
17	Computer Methods Of Structural Analysis	IT
18	Computer Networks	IT
19	Course in Information Technology	IT
20	Cyber Security	IT
21	Data Base Management System	IT
22	Data Science for Engineers	IT
23	Data Structure and algorithms using Java	IT
24	Database and Content Organisation	IT
25	Design and Analysis of algorithms	IT
26	Digital Circuits	IT
27	Digital Library	IT
28	Engineering drawing and computer graphics	IT
29	Fundamentals Of Artificial Intelligence	IT
30	Fundamentals of Computer Systems	IT
31	Google Cloud Computing Foundations	IT
32	HTML	IT
33	Introduction to Computer Networks & Internet	IT
34	Introduction to Information Technology	IT
35	Introduction to Cyber Security	IT
36	Introduction to Programming in C	IT
37	Java	IT
38	Java Business Application	IT
39	Linux Operating System	IT
40	Operating Systems	IT
41	PHP and MySQL	IT
42	Problem solving through Programming In C	IT
43	Programming in C++	IT
44	Programming in Java	IT
45	Programming, Data Structures And Algorithms	IT
46	Software Engineering	IT
47	Software Testing	IT
48	Web Content Management	IT
49	Web Based Technologies and Multimedia	IT

*Handwritten signatures and initials*

Sr.No.	Name of Course Offered on Swayam Website	Course (Category)
1	Accounting for Managerial Decisions	Finance
2	Cost Accounting	Finance
3	Direct Tax - Laws and Practice	Finance
4	Financial Accounting	Finance
5	Financial Accounting and Analysis	Finance
6	Financial Management	Finance
7	Fundamentals of Financial Management	Finance
8	Introduction to GST	Finance

*Handwritten marks:*  
A circle with a checkmark and the date 11/4/20  
The number 32  
A signature

*Handwritten mark:*  
A downward-pointing arrow

Sr.No.	Name of Course Offered on Swayam Website	Course (Category)
1	Communication Skills	Soft Skills
2	Soft skills	Soft Skills
3	Body language: Key to professional Success	Soft Skills
4	Critical Thinking	Soft Skills
5	Developing Soft Skills and Personality	Soft Skills
6	Fundamentals of Office Management & Methods	Soft Skills

*Handwritten initials/signature*

*Handwritten signature*

*Handwritten mark*

Sr.No.	Name of Course Offered on Swayam Website	Course (Category)
1	Data Entry Operations	Miscellaneous
2	Document Processing and Organisation	Miscellaneous
3	ENTREPRENEURSHIP DEVELOPMENT	Miscellaneous
4	Event Planning	Miscellaneous
5	Human resource development	Miscellaneous
6	Human Rights and Humanitarian Law	Miscellaneous
7	Information Sources and Library	Miscellaneous
8	Information Sources and Library Services	Miscellaneous
9	Introduction to NGO Management	Miscellaneous
10	Library & Information Science	Miscellaneous
11	Management of Human Resources	Miscellaneous
12	Organizational Behaviour	Miscellaneous
13	Project Analysis	Miscellaneous
14	Right to Information and Good Governance	Miscellaneous
15	Stress Management	Miscellaneous

*Handwritten signature and initials*

*Handwritten signature*

*Handwritten mark*



