



PUNJAB STATE TRANSMISSION CORPORATION LIMITED

Regd. Office:- PSEB Head Office, The Mall, Patiala – 147001, Punjab, India

O/o SE/Planning, PSTCL, Patiala

Fax/Ph:- 0175-2205502, Email:- se-planning@pstcl.org

CIN-U40109PB2010SGCO33814

To,

Amendment No: 30/2023-24

- 1) Dy. CE/Grid Construction, PSTCL, Ludhiana.
- 2) Dy. CE/TS (Design), PSTCL, Patiala.
- 3) Dy. CE/Civil Works, PSTCL, Patiala.
- 4) Dy. CE/TLSC, PSTCL, Patiala.

Memo No. 26/29/PI-397

Dated: 15-01-2024

Subject: Regarding Augmentation/Addition of 100/160 MVA P/T/Fs at various PSTCL Substations.

The scope of work is as follows:

Sr. No.	Name of Sub-Stations	Scope of work	Estimated cost of work (in Crore)	Remarks
1	220kV S/S MGG-2	Augmentation of 1 no. 100 MVA 220/66kV Transformer with 160 MVA at 220kV Sub-station MGG-2	14.15	1) These works has been planned as per various FCC decisions. 2) Estimated cost has been considered as per Cost data 2023-24 furnished by O/o TS-Design.
2	220kV S/S Rajpura	Augmentation of 1 no. 100 MVA 220/66kV Transformer with 160 MVA at 220kV Rajpura.	14.15	3) These works shall be included in the Transmission works for the FY 2023-26. 4) Expenditure of these works shall be booked to Sr.no 69 (Augmentation/additions of T/fs at 220/132/66kV S/Stns. of PSTCL) of Annexure-3 of MYT 2023-2026.
3	220kV S/Stn. Bassi Pathana	Augmentation of 1 no. 100 MVA 220/66kV Transformer with 160 MVA	14.15	5) Total estimated cost after including EC @ 15 % and IDC @

		at 220kV Bassi Pathana.		9.5 % (FY 2023-24) shall be Rs. 88.08Cr.
4	220kV S/Stn. Hambran	Augmentation of 1 no. 100 MVA 220/66kV Transformer with 160 MVA at 220kV Hambran.	14.15	6)This work is subject to ratification by BODs of PSTCL & subsequent approval of PSERC for revision in allocated budget under head (Augmentation/additions of T/fs at 220/132/66kV S/Stns. of PSTCL) of Annexure-3 of MYT 2023-2026.
5	220kV S/Stn. Dhanaula	Augmentation of 1 no. 100 MVA 220/66kV Transformer with 160 MVA at 220kV Dhanaula.	14.15	7)The work may be taken in hand only after the requisite approval of PSERC.
		Total	70.75	

This issues with the approval of Technical Committee of PSTCL.


Sr. XEN/Planning-1,
PSTCL, Patiala.

CC: -

30/35
15-01-2024

Dated: 15/01/2024

- 1) Director/Technical, PSTCL, Patiala.
- 2) Chief Engineer/TS, PSTCL, Patiala.
- 3) Chief Engineer/P&M, PSTCL, Ludhiana.
- 4) Chief Engineer/Planning, PSPCL, Patiala.
- 5) Dy. Chief Engineer/P&M, PSTCL, Patiala.
- 6) Dy. Chief Engineer/P&M, PSTCL, Ludhiana.