



PUNJAB STATE TRANSMISSION CORPORATION LIMITED
Regd. Office:- PSEB Head Office, The Mall, Patiala – 147001, Punjab, India
O/o SE/Planning & Communication, PSTCL, Patiala
Fax/Ph:- 0175-2205502, Email:- se-planning@pstcl.org
CIN-U40109PB2010SGCO33814

Amendment No: 03 /LSW/2022-23

To

1. Dy. CE/Grid Construction, PSTCL, Ludhiana.
2. Dy. CE/TS (Design), PSTCL, Patiala.
3. Dy. CE/Civil Works, PSTCL, Patiala.
4. SE/TLSC, PSTCL, Patiala.

Memo No. 169/72 /P-I/366

Dated: 12.05.2022

Subject: Regarding augmentation of 100 MVA, 220/66 KV T/Fs to 160 MVA T/Fs (FCC Cases).

The scope of the work is planned as follows:

Sr. No.	Name of Sub-stations	Scope of work	Estimated Cost of Work (in lakhs)	Remarks
1	220 KV S/S Sahnewal	Augmentation of 1 no. 100 MVA Transformer at 220 kV Sahnewal Sub-station to 160 MVA	952.73	1) The work has been planned to reduce loading of 220 KV Sahnewal, Bajakhana & Ghulal sub-stations. 2) Estimated cost has been considered as per Cost Data 2021-22 furnished by O/o of TS –Design 3) This work will be considered as new work and taken in hand only after obtaining due approval of PSERC. This work will not be charged to Sr. No. 29 of Table 17 of PSTCL MYT 2020-23 as expenditure allocated to this accounting head is almost exhausted 4) This work shall be included in the transmission works for the FY 2022-23. 5) Total estimated cost after including EC@ 15% and IDC @ 10.37% (FY 2020-21) shall be Rs. 35.596 Cr 6) 160 MVA T/F being long delivery item. This amendment is issued with 2 no. T/Fs to be allocated in FY 2022-23 and 1 no. T/F to be allocated in MYT 2023-26.
2	220KVS/S Bajakhana	Augmentation of 1 no. 100 MVA Transformer at 220 KV Bajakhana Sub-station to 160 MVA	952.73	
3	220KVS/S Ghulal	Augmentation of 1 no. 100 MVA Transformer at 220 KV Ghulal Sub-station to 160 MVA	952.73	
TOTAL			2858.19	

The break-up of the proposed expenditure is as below:

Particulars of expenditure	Provision in MYT 2020-23 (Rs. in Crores)	
	FY 2022-23	Spill over (MYT 2023-26)
Expenditure proposed on the above said work	23.596	12.0

This issue with the approval of Technical Committee of PSTCL.



SE/Planning
PSTCL, Patiala.

CC: - 173/78 /P-I/366

Dated: 12.05.2022

1. Director/Technical, PSTCL, Patiala.
2. Chief Engineer/TS, PSTCL, Patiala.
3. Chief Engineer/P&M, PSTCL, Ludhiana.
4. Chief Engineer/Planning, PSPCL, Patiala.
5. Dy. CE/P&M Circle, PSTCL, Bathinda, Jalandhar & Amritsar.
6. SE/Civil Design, PSTCL, Patiala.