

pstcl

PUNJAB STATE TRANSMISSION CORPORATION LIMITED  
Regd. Office:- PSEB Head Office, The Mall, Patiala - 147001, Punjab, India  
O/o Dy. CE/Planning, PSTCL, Patiala  
Fax/Ph:- 0175-2205502, Email:- [se-planning@pstcl.org](mailto:se-planning@pstcl.org)  
CIN-U40109PB2010SGCO33814

To,

1. Dy. CE/TS (Design),  
PSTCL, Patiala.
2. SE/Grid Construction,  
PSTCL, Ludhiana.
3. Dy. CE/Civil Works Circle,  
PSTCL, Patiala.

Amendment No: 6 /LSW/2020-21

Memo No. 320-322 /P-II / 70A

Dated: 22/1/2020

Subject:- Regarding planning for augmentation of existing 66KV interconnecting Bus Bar 'C' from single to double and Up gradation of main isolator of 66KV Bus Bar 'C' from 1200A to 2000A at 220KV S/S Katorewala (Malout)

The scope of work is planned as follows:-


Sr. No.	Name of Work	Scope of Work	Est. Cost Rs. Lacs.	Remarks
1	220KV S/s Katorewala (Malout)	1) Augmentation of existing 66KV Interconnecting Bus Bar 'C' from single to double bus bar.  2) Up gradation of main isolator of 66KV Bus Bar 'C' from 1200A to 2000A	50.00 (40+10 lacs)	(i) This work has been planned as per the requirement received from the office of Dy. CE/ P&M Circle, PSTCL, Bathinda vide his letter no. 5901 dt. 24.10.19 (ii) This work has been planned for smooth operation and in order to improve reliability of the supply. (iii) The scope of work is furnished by O/o SE /Grid Const., Circle, PSTCL, Ludhiana and Dy. CE/ TS Design, PSTCL, Patiala resp. (iv) Tentative cost has been considered as furnished by SE /Grid Const., Circle, PSTCL, Ludhiana and as per telephonic discussion cost (for up gradation of main isolator of 66KV Bus Bar 'C' from 1200A to 2000A) with ASE/Grid Const., Div., Moga dt. 19.6.2020 (v) The expenditure shall be charged to the head "Augmentation of Bus Bars, extension in control room building, providing room for second source for battery etc." , Sr. No. 69 of MYT 2020-23 as per provision of Approved Capital Investment Plan for the year 2020-21. <ul style="list-style-type: none"><li>• Expenditure allocated for the control period 2020-21: Rs. 7.80 Crore.</li></ul>

				<ul style="list-style-type: none"> <li>• Expenditure already booked via amendments till date: <b>1.87 Crore</b></li> <li>• Expenditure to be booked for this amendment: <b>Rs. 0.50 Crore</b></li> <li>• Balance expenditure for the control period 2020-21: <b>Rs. 5.43 Crore</b></li> </ul> <p>(v) This work shall be included in the transmission works for the year 2020-21.</p>
--	--	--	--	--

The break up of the provision in the MYT and the proposed expenditure is as below:

Particulars of expenditure	Provision in MYT 2020-23 (in Rs. Crores)		
	FY 2020-21	FY 2021-22	FY 2022-23
Expenditure approved for the head "Augmentation of Bus Bars, extension in control room building, providing room for second source for battery etc" (Sr. No. 69 of MYT 2020-23 )	7.80	8.24	7.11
Expenditure already booked via amendments till date	1.87	0.5	-
Expenditure proposed on the above said work	0.50	-	-
<b>Balance</b>	<b>5.43</b>	<b>7.74</b>	<b>7.11</b>

This issues with the approval of worthy CMD, PSTCL.

  
Dy. CE / Planning,  
PSTCL., Patiala.

323-229  
22/12/2020  
CC:

1. Director/Technical, PSTCL, Patiala.
2. Chief Engineer/TS, PSTCL, Patiala.
3. Chief Engineer/P&M, PSTCL, Ludhiana.
4. Chief Engineer/Planning, PSTCL, Patiala.
5. Dy. Chief Engineer P&M Circle PSTCL, Bathinda
6. Dy. CE/TLSC Circle, PSTCL, Patiala.