



PUNJAB STATE TRANSMISSION CORPORATION LIMITED
Regd. Office:- PSEB Head Office, The Mall, Patiala - 147001, Punjab, India
O/o SE/Planning & Communication, PSTCL, Patiala
Fax/Ph:- 0175-2205502, Email:- se-planning@pstcl.org
CIN-U40109PB2010SGCO33814

Amendment No: 09/2023-24

To

- 1) Dy. CE/TS (Design), PSTCL, Patiala.
- 2) Dy. CE /Grid Construction, PSTCL, Ludhiana.
- 3) Dy. CE /Civil Works, PSTCL, Patiala.
- 4) Dy. CE /TLSC, PSTCL, Patiala.

Memo No. 404/407 /P-II/70A/76

Dated: 13/07/2023

Subject: Planning of 1 No. 66 kV bay 220 kV Barnala (Handiaya) for 66 kV Barnala (2nd ckt) as required by PSPCL.

The scope of work is planned as following:

Sr. No.	Name of Substation	Scope of Work	Est. Cost (in Cr.)	Remarks
1	220 KV S/S Barnala (Handiaya)	1 No. 66 kV line bay for 66 kV Barnala (2 nd ckt) at 220 kV S/S Barnala (Handiaya) by utilizing spare 66 kV Thikriwal bay.	= 0.345 [0.34+ 0.005(civil works)]	<ol style="list-style-type: none">1) This work is being planned on the basis of Sr. No. 79/B/SZ of TWL 2022-23 issued by PSPCL.2) Work is being planned as per the confirmation of space availability by ASE/TS(VII), PSTCL, Patiala vide memo No. 1331 dated 13.12.22.3) Estimated cost for 66 kV Bay Barnala at 220 kV Barnala (Handiaya) has been considered as informed by ASE/Grid construction division, PSTCL, Patiala vide his office memo No. 1795 dated 16.06.23 i.e. 0.34 Cr. and Sr. Xen/Civil works division, PSTCL, Patiala vide memo No. 1184 dated 26.06.23 i.e. 0.005 Cr.4) The expenditure shall be charged to the head "<u>Additional 220/132/66 kV line bays</u>", Sr. No. 70 of Annexure 3 of MYT 2023-26 as per provision of Approved Capital Investment Plan for the year 2023-26. Expenditure allocated upto control period upto March 24: Rs. 11.90 Crore. Expenditure already booked via amendments till date: Rs. 0.54 crore Expenditure to be booked for this amendment: Rs. 0.413 Crore (including EC & IDC) Balance expenditure for the control period 23-24: Rs. 10.947 Crore5) This work shall be included in the transmission works for the FY 2023-26.6) The work is subject to the ratification by BODs.

This issues with the approval of Technical Committee of PSTCL comprising Director/Technical and Er. Anil Kaplush, Independent Director of PSTCL.

Md 13/7/23
Sr. Xen/Planning-2
O/o Dy. CE/Planning
PSTCL, Patiala.

cc: - 408/414 /P-II/70A/76

Dated: 13/7/2023

- 1) Director/Technical, PSTCL, Patiala.
- 2) Chief Engineer/TS, PSTCL, Patiala.
- 3) Chief Engineer/Planning, PSPCL, Patiala.
- 4) Chief Engineer/P&M, PSTCL, Ludhiana.
- 5) Chief Engineer/P&M, PSPCL, Ludhiana.
- 6) Dy. CE/Transmission Planning, PSPCL, Patiala.
- 7) Dy. CE /P&M Circle, PSTCL, Patiala.