



PUNJAB STATE TRANSMISSION CORPORATION LIMITED

Regd. Office: - PSEB Head Office, The Mall, Patiala – 147001, Punjab, India

O/o SE/Planning, PSTCL, Patiala.

Fax/Ph: - 0175-2205502, Email: - se-planning@pstcl.org

CIN - U40109PB2010SGCO33814

To

CAO/F &A,
PSTCL, Patiala

Memo No.: 24 /P-1/275


Dated: 01.02.2023

Subject: PSERC Directives in the Tariff Order for FY 2022-23: Quarter ending December-2022.

Enclosed please find herewith compliance status of PSERC directive Sr. No. 4.4 (Reactive Compensation) in the Tariff Order for FY 2022-23 for the quarter ending December-2022 as Annexure-A. Annexure A shall be uploaded on PSTCL website www.pstcl.org.

This issues with the approval of Chief Engineer/TS.

DA: As Above


Sr.XEN/Planning-1,
PSTCL, Patiala.

CC:-

25/26
1.2.23

1. Chief Engineer/TS, PSTCL, Patiala
2. ASE/Tech. to Director/Tech, PSTCL Patiala

P SERC Directive Sr. No. 4.4 (Reactive Compensation)

Quarter ending December-2022

Capacitor Banks:

PSTCL has floated Tender Enquiry for the procurement of various rating of Capacitor Banks around the capacity of 700 MVAR for the planned works and as per the requirement of the P&M wing and is under process.

Further, the PSTCL has started the installation of available 132kV Capacitor Banks at the various S/Stn. of PSTCL are being under installation.

Bus-Reactors:

- a) PSTCL has placed order for the supply and installation of 1 no. 125MVAR, 400kV Bus-Reactor at 400kV S/S Dhuri and 2 nos. 25MVAR, 220kV Bus-Reactors at 400kV S/S Dhuri and Nakodar one at each.
- b) 1 no. 220kV 25MVAR reactor has been commissioned at 400kV sub-station Dhuri.
- c) 1 no. 400kV 125 MVAR Bus-Reactor for 400kV S/S Dhuri and 1 no. 220kV 25 MVAR Bus-Reactor for 400kV S/S Nakodar have been received at site and testing is under process and are expected to be commissioned by 28.02.2023.