



**PUNJAB STATE TRANSMISSION CORPORATION LIMITED**

(A Punjab Government Undertaking) H.O- PSEB Head Office, The Mall, Patiala

**OFFICE OF THE CHIEF ENGINEER/P&M, P.S.T.C.L, LUDHIANA**  
**OFFICE ORDER**

Office Order No- 205

Date- 29/9/15

**Subject-** Formulation of standard procedure for reporting to NRLDC by Punjab STU under section 5.9 of IEGC

In case of all trippings at 400 KV sub-stations, the indication on relays along with DR & EL records should be sent to centralized e-mail address by concerned Sr XEN/ASE/P&M for further transmission to NRLDC within 24 hours as per section 5.9.5 of IEGC. The detailed report as per section 5.9.6 of IEGC will be submitted to NRLDC by ASE, Protection Division, Ludhiana who is looking after the protection work of 400 KV System of PSTCL, within 15 days of the occurrence of the event.

In case of 220 KV elements (i.e transmission lines & Transformers), the indication on relays along with preliminary report be sent to centralized e-mail address by Sr XEN/ ASE/P&M for giving preliminary information to NRLDC within 24 hours as per section 5.9.5 of IEGC. But if it is a case of multiple element trippings i.e two or more than two simultaneous trippings, mal-operation or non-operation of required relays or delayed clearance of faults as per section 5.9.5 of Indian Grid Code, the detailed report should be send by the concerned Sr XEN/ASE/Protection to centralized e-mail address for onward submission to NRLDC as per section 5.9.5 of IEGC.

The centralised e-mail addresses for sending such information is srxen-prot2-lhdh@pstcl.org & xenprotectionludhiana@yahoo.in as already intimated by C.E/P&M vide probable memo no- 3430/37/DRP-23, Dated 23-4-14 to all Dy C.E's/P&M and NRLDC, New Delhi. **This will be standard procedure for reporting to NRLDC by Punjab STU under section 5.9 of IEGC.**

This issues with the approval of Worthy Director/Technical, PSTCL, Patiala.

Endst No-

Date-

9546/89.

29/9/15

1. All S.E's/dy C.E's under P&M Zone, Ludhiana
2. All Sr XEN's/ASE's/P&M under P&M Zone, Ludhiana
3. All Sr XEN's/ASE's/Protection under P&M Zone, Ludhiana

1. ASE/Tech to Director/Technical, PSTCL, Patiala

9590  
29/9/15 CC

A.S.E. 29/9/15  
On behalf of C.E/P&M  
PSTCL, Ludhiana.