

To

Amendment No: 27/LSW/2021-22

- 1) Dy. CE/Grid Construction, PSTCL, Ludhiana.
- 2) Dy. CE/TS (Design), PSTCL, Patiala.
- 3) Dy. CE/Civil Works, PSTCL, Patiala.
- 4) SE/TLSC, PSTCL, Patiala.

Memo No. **533-536** /P-1/364 Dated: **09-12-21**

Subject: LILO of 220 KV Mohali-1-Lalru line at 220 KV Mohali-2.

The scope of work is planned as follows:-

Sr. No.	Name of Sub-station	Scope of work	Estimated Cost of Work (in crores)	Remarks
1	220K S/S Mohali-2	1) LILO of 220 KV Mohali-1-Lalru at 220 KV Mohali-2 (Line length- 1 KM, 0.4sq" conductor)- Stringing of LILO line. 2) 2 no. 220 KV bays at 220 kV Mohali-2	0.2622 2.3268	1) The work is being planned on the basis of proposal submitted through 3rd interim report by Committee constituted by Director Technical vide Letter no. SPL-1 dated:- 21-07-2021 2) Estimated cost has been considered as per Cost Data 2021-22 furnished by O/o of TS-Design 3) This is a new work and it will be taken in hand only after obtaining due approval of PSERC. 4) This work shall be included in the transmission works for the FY 2021-22. 5) Towers are already present on site and to block ROW this work should be expedited at the earliest. 6) Total estimated cost after including EC@ 15% and IDC @ 10.37% (FY 2020-21) shall be Rs. Cr 3.132
	TOTAL		2.589	

The breakup of the proposed expenditure is as below:

Particulars of expenditure	Provision in MYT 2020-23 (To be approved) Rs.in Crores
	FY 2022-23
Expenditure proposed on the above said work	3.132

This issues with the approval of committee of Director/Technical and independent Director of PSTCL.


 Dy. CE/Planning,
 PSTCL, Patiala.

CC:- 530-542 /P-1/364 Dated 09-12-21

- 1) Director/Technical, PSTCL, Patiala.
- 2) Chief Engineer/TS, PSTCL, Patiala.
- 3) Chief Engineer/P&M, PSTCL, Ludhiana.
- 4) Chief Engineer/Planning, PSPCL, Patiala.
- 5) Dy. CE/P&M, PSTCL, Patiala.