



PUNJAB STATE TRANSMISSION CORPORATION LIMITED
 (Regd. Office: PSEB Head Office, The Mall, Patiala)
 Office of Chief Engineer /Transmission System,
 B-2, Shakti Vihar, Patiala.

NOTIFICATION NO. 11/TS/ST-6016/Vol-II

Dated: 19.10.2012

It is hereby notified that Punjab State Transmission Corporation Ltd. (here-in-after called the PSTCL) proposes to undertake the following schemes/transmission works necessary for the dispersal/distribution of power for the improvement of the transmission and distribution system of the Punjab State Transmission Corporation Ltd.

TRANSMISSION WORKS FOR THE YEAR 2012-13

Sr. No.	Name of Work.	Scope of work, Approx. Length of line in Kms.	Size of conductor in Sq. inch.	Approx. cost (Rs in Lacs)
1.	Revised Route of 220KV Goindwal Sahib-Bottianwala line TL No.1 to 5.	1.350	0.4	49.13
2.	Revised Route of LILO of One Ckt. of 220KV Patran-Rajla at 220KV Kakrala TL 10 to Gantry.	3.214	0.4	116.96
3.	Revised Route of 220KV RSD-Sarna D/Ckt. line Ckt. 5-6 from TL No. 26 to 28(Shifting of TL No.27).	0.448	0.5	19.57
4.	Revised Route of Shifting of 220KV RSD-Sarna line (Circuit 1&2) TL No. 1&2.	0.877	0.5	38.31
5.	Revised Route of LILO of 220KV Lehra Mohabbat-Mansa at Talwandi Sabo (TL 39-41).	29.862	0.4	1086.68
6.	Revised Route of 220KV Rajpura-Devigarh line from 400KV S/S Rajpura (TL No. 1 to 8A).	36.944	0.4	1344.39
7.	Revised Route of LILO of 220KV D/Ckt. RTP-Sahnewal line at Ghulal from TL-20 to Ghulal S/Stn. Gantry & cross profile of 66KV Ghulal to Saluja Cotex line between TL-20-21.	25.535	0.5	1115.37
8.	Revised Route of 220KV Rajpura- Lalru line (Rajpura S/Stn. Gantry to TL No.2) and cross profile of proposed line with 400KV Rajpura Dhuri line between TL 1A-2.	29.385	0.4	1069.32

Dy. CE/TS (Design),
 PSTCL, Patiala.

9.	132KV line Single Circuit link to connect 132KV Substation Dharmot to 132KV Sub-Station Dhaleke.	4.704	0.2	82.88
10.	Revised Route for 220KV DC line from 400KV Rajpura to 220KV S/Stn. Lalru line (TL No. 90-93). Due to Non clearance of feasibility from Railway Deptt. Between OHE 217/7 & 217/8.	29.380	0.4	1069.14
11.	Revised Route of 220KV D/Ckt. line from 400KV Nakodar (chak vandal) to 220KV S/Stn. Kartarpur (T.L. No. 1 to 3).	27.381	0.4	996.39
	Deposit works			
12.	Raising of existing 132KV GNDTP Bathinda-IGC Bathinda Line.	0.90	0.2	18.82
13.	Raising of existing 132KV IGC Bathinda-Maur line.	0.90	0.2	18.82
14.	Revised Route of 66KV Line from TL-14 to M/s KSM Gantry, Village Mandyalam Kalan.	2.131	0.2	33.99

It is hereby notified that the PSTCL is undertaking and executing the sanctioned scheme and shall have the powers for placing of any Wires, Poles, Stays, Apparatus and Appliances for the Transmission and Distribution of Electricity or for Transmission of telegraphic or telephonic communications necessary for proper coordination of the works of PSTCL for the areas indicated above which the Telegraph Authority possess under Part-III of the Telegraphs Act. 1885 (XIII of 1885) in respect of telegraphs established or maintained and the provisions of section 12 to 16, 18 and 19 of the Indian Electricity Act 1910 shall not apply to the same and therefore no separate notice of the scheme of PSTCL is required to be given.

This notification has been issued with reference to the relevant clauses of Indian Electricity Act 1910 alongwith latest statutory amendments, modifications upto date over riding enactments if any and the provisions made under Section 164 of the Indian Electricity Act 2003. Notice is hereby given that any person may raise objection if any/and or make any representation against the above scheme/transmission works within two month of issue of this notification. Thereafter no objection and or representation will be entertained and all schemes/transmission works will be deemed to be sanctioned with or without modifications as approved by the PSTCL. Necessary plans showing the tentative route of the Transmission Lines may be seen on any working day in the office of Dy. CE/TLSC, PSTCL, Patiala. Objections and/or representations in respect of the above schemes if any should be sent to the undersigned.

Dy. CE/TS (Design),
PSTCL, Patiala.

Chief Engineer/TS,
Pb. State Trans. Corp. Ltd.,
B-2, Shakti Vihar, Patiala.

Dy. CE/TS (Design),
PSTCL, Patiala.