



PUNJAB STATE TRANSMISSION CORPORATION LIMITED

Regd. Office:- PSEB Head Office, The Mall, Patiala – 147001, Punjab, India

O/o SE/Planning, PSTCL, Patiala

Fax/Ph:- 0175-2205502, Email:- se-planning@pstcl.org

CIN-U40109PB2010SGCO33814

To

Amendment No: 32/2023-24

- 1) Dy. CE/TS (Design), PSTCL, Patiala.
- 2) Dy. CE/Civil Works, PSTCL, Patiala.
- 3) Dy. CE/TLSC, PSTCL, Patiala.
- 4) Dy. CE/Grid Construction, PSTCL, Ludhiana.

Memo No. 62/65/PI-401


Dated: 23-01-2024

Subject: - Regarding augmentation of existing conductor of 400kV Banvala(Patran)-220kV Patran D/C line with equivalent HTLS Conductor.

The scope of work is planned as follows: -

Sr. No.	Scope of Work	Est. Cost (Rs.)	Remarks
1.	Augmentation of existing conductor of 400kV Banvala (Patran)-220kV Patran D/C line with equivalent HTLS conductor	Rs. 11.01 crore (approx.) (cost of replacement of existing conductor with HTLS)	<ol style="list-style-type: none">1. This work is being planned to deload high loading of 400kV Banvala(Patran)-220kV Patran line & eventual enhancement of ATC/TTC limits of Punjab.2. The cost has been considered as intimated by ASE/TS-1, PSTCL, Patiala vide memo no. 45 dated 09.01.2024.3. This work shall be considered as new work and taken in hand only after obtaining due approval of PSERC.4. Total estimated cost after including EC@15% & IDC @ 9.5% shall be Rs. 13.71 crores.5. This work is subject to the ratification of BODs of PSTCL.
	Total	11.01 crores	

This issues with the approval of Technical Committee of PSTCL.


Sr. XEN/Planning-1,
PSTCL, Patiala.

cc: -

66/70

Dated: 23-01-2024

- 1) Director/Technical, PSTCL, Patiala.
- 2) EIC, Commercial, PSPCL, Patiala.
- 3) Chief Engineer/TS, PSTCL, Patiala.
- 4) Chief Engineer/Planning, PSPCL, Patiala.
- 5) Dy. Chief Engineer/P&M Circle, PSTCL, Patiala.