



**PUNJAB STATE TRANSMISSION CORPORATION LIMITED**  
 (Regd. Office: PSEB Head Office, The Mall, Patiala)  
 Office of Chief Engineer /Transmission System,  
 3<sup>rd</sup> Floor, Shakti Sadan, Patiala.

**NOTIFICATION NO. 17 /TS/ST-6016/Vol.-II**

**Dated: 30.10.2013**

It is hereby notified that Punjab State Transmission Corporation Ltd. (here-in-after called the PSTCL) proposes to undertake the following schemes/transmission works necessary for the dispersal/distribution of power for the improvement of the transmission and distribution system of the Punjab State Transmission Corporation Ltd.

**TRANSMISSION WORKS FOR THE YEAR 2013-14**

Sr. No.	Name of Work.	Scope of work, Approx. Length of line in Kms.	Size of ACSR conductor Nominal Aluminium Area in mm <sup>2</sup>	Approx. cost (Rs in Lacs)
1.	LILO of 220KV Malerkotla – Gobindgarh line at 220KV Sub-Station Ikolaha.	6.672	420	400.25
2.	220KV line from 220KV Sub-Station Nabha Focal Point to 220KV Sub-Station Naraingarh S/C line on D/C towers.	23.930	420	1168.26
3.	220KV line from 400KV Sub-Station Makhu to 220KV Sub-Station Dharamkot DC line.	21.266	420	1275.75
4.	220KV line from 400KV Sub-Station Moga to 220KV Sub-Station Mehal Kalan DC line.	52.180	420	3130.28
5.	Revised Route of 220 KV D/C line from 400KV Mukatsar to 220KV Abohar T.L. 01 to 07.	43.391	420	2603.03
<b>DEPOSIT WORK</b>				
6.	Revised Route from T.L. No. 51 to 58 of 220 KV line from Rajpura to 220 KV Sub-Station Lalru. ( D/C line on D/C Towers)	2.418	420	145.06

It is hereby notified that the PSTCL is undertaking and executing the sanctioned scheme and shall have the powers for placing of any Wires, Poles, Stays, Apparatus and Appliances for the Transmission and Distribution of Electricity or for Transmission of telegraphic or telephonic communications necessary for proper coordination of the works of PSTCL for the areas indicated above which the Telegraph Authority possess under Part-III of the Telegraphs Act. 1885 (XIII of 1885) in respect of telegraphs established or maintained and the provisions of section 12 to 16, 18 and 19 of the Indian Electricity Act 1910 shall not apply to the same and therefore no separate notice of the scheme of PSTCL is required to be given.

This notification has been issued with reference to the relevant clauses of Indian Electricity Act 1910 alongwith latest statutory amendments, modifications

upto date over riding enactments if any and the provisions made under Section 164 of the Indian Electricity Act 2003. Notice is hereby given that any person may raise objection if any/and or make any representation against the above scheme/transmission works within two month of issue of this notification. Thereafter no objection and or representation will be entertained and all schemes/transmission works will be deemed to be sanctioned with or without modifications as approved by the PSTCL. Necessary plans showing the tentative route of the Transmission Lines may be seen on any working day in the office of Dy. CE/TLSC, PSTCL, Patiala. Objections and/or representations in respect of the above schemes if any should be sent to the undersigned.

(Er. Shashi Prabha)  
Chief Engineer/TS,  
Pb. State Trans. Corp. Ltd.,  
3<sup>rd</sup> Floor, Shakti Sadan, Patiala.