

**ANNEXURE. NO. A**  
**LOADING STATUS ENDING SEPTEMBER 2020**

J

184



Annexure - A

S. No. 5.3 (Loading status of PSTCL Trans. Lines & Sths.)

2<sup>nd</sup> Quarter (ending September-2020)

Sr. No.	P & M Circle	Name of Transmission Line	% loading as compared with the standard design Parameters of Conductor i.e. 45°C ambient temperature and 75°C conductor temperature	Remarks of P&M Organization	Proposal/Remedial Action by Planning
<b>A) Loading status of PSTCL Transmission Lines</b>					
Patiala	220kV Faggan majra-Bahadurgarh	640 A at 36 °C ambient temperature (114%)	Due to Paddy season this value is normal	High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 668.72 A at 36 °C). Also, the loading is expected to reduce with the advent of Rajpura-Bassi Pathana link.	
	220kV Rajpura - Faggan majra	560 A at 35 °C ambient temperature (100%)	Due to Paddy season this value is normal	High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 675.15 A at 35 °C). <b>No remedial action required.</b>	
	220kV Mohali 1 - Kharar	570 A at 32 °C ambient temperature (102%)	Existing Load	High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 694.44 A at 32 °C). <b>No remedial action required.</b>	
	220KV N/Garh-Mohali1-Ckt-I	582 A at 29 °C ambient temperature (104%)	Due to paddy season/Peak load	High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 713.73 A at 29 °C). <b>No remedial action required.</b>	
	220KV N/Garh-Mohali1-Ckt-II		Due to paddy season/Peak load		
	220 KV Patran-Banvala ckt2	559 A at 31 °C ambient temperature (100%)	TEMPORARY/BECAUSE LARGE AMOUNT OF POWER DRAWN BY 220KV S/S SUNAM AND 220KV S/S BANGAN	High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 700.87 A at 31 °C). <b>No remedial action required.</b>	

		220 KV Sunam-Bhalwan-1	564 A at 36 °C ambient temperature (101%)	LARGE AMT. OF POWER DRAWN DURING NIGHT TIME, BECAUSE SOLAR SYSTEM INSTALLED AT JHUNIR AND MANSA REMAIN OFF DURING NIGHT TIME.	<p>High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 668.72 A at 36 °C).</p> <p><b>No remedial action required.</b></p>
		220 KV Sunam-Bhalwan-2			
		132 KV Nakkian-Ropar	390 A at 31 °C ambient temperature (102.36%)	Due to Plant Outage of Nakkian Power House and due to Paddy	High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 450.17 A at 31 °C).
2.	Jalandhar	220 KV PGCIL-Kartarpur CKT-1	618 A at 36 °C ambient temperature (110.36%)	Existing	<p>High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 668.72 A at 36 °C).</p> <p><b>Also, augmentation of existing conductor of both circuits with HTLS conductor of min 1200 A capacity already planned in MYT 2017-20.</b></p>
		220 KV PGCIL-Kartarpur CKT-2	628 A at 36 °C ambient temperature (112.14%)	Existing	<p>High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 668.72 A at 36 °C). Also,</p> <p><b>augmentation of existing conductor of both circuits with HTLS conductor of min 1200 A capacity already planned in MYT 2017-20.</b></p>
		220 KV Kotla Junga-Kartarpur CKT-1	612 A at 36 °C ambient temperature (109.29%)	Existing	<p>High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 668.72 A at 36 °C). Also, the loading is expected to improve with augmentation of 220 KV PGCIL-Kartarpur circuits to HTLS which is already included in MYT 2020-23.</p>

		220 KV Kotla Junga-Kartarpur CKT-2	635 A at 36 ° C ambient temperature (113.39%)	Existing	High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 668.72 A at 36 ° C). Also, the loading is expected to improve with augmentation of 220 KV PGCIL-Kartarpur circuits to HTLS which is already included in MYT 2020-23.
		132 KV Mahilpur-Banga	396 A at 38 ° C ambient temperature (103.94%)	DUE TO INCREASE IN LOAD OF 132 KV SUB STATION BANGA DURING PADDY/SUMMER SEASON	High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 421.26 A at 38 ° C). No remedial action required.
3.	Bathinda	220 kV Muktsar-Katorewala ckt. (From 400 kV S/S Shri Muktsar Sahib)	614.06 A at 29 ° C ambient temperature (109.65%)	Load increases daily. At approx. 580A PC Patiala sheds its load	High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 713.73 A at 29 ° C). No remedial action required.
		220 KV Moga-Bajakhana	565 A at 31 ° C ambient temperature (100.89%)	Temperory (Due to PTW on Baghapurana Ckt-01 & 02. Load of 220 KV S/S Baghapurana is fed from 220 KV S/S Bajakhana. So, due to this 220 KV Moga-Bajakhana Line is Overloaded) <b>Normal Maximum Load 339 dt 10.07.2020 time 21:00, % Loading = 60.53</b>	High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 700.87 A at 31 ° C). No remedial action required.
		132 kV Ferozeshah - Kotkaror	333 A at 38 ° C ambient temperature (104.06%)	Line is overloaded in paddy season due to small size of conductor	High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 369.8 A at 38 ° C). Expected to be relieved with advent of 220 kV Dhalleke.
4.	Ludhiana	220 KV Sahnewal-PGCIL	636 A at 32 ° C ambient temperature (100.79%)	Normal Existing Load (only in Paddy)	High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 786.24 A

				at 32 °C). <b>No remedial action required.</b>
220 KV PGCIL-Lalton Ckt.-3	740 A at 37 °C ambient temperature (117.2%)	Temporary (Due to fault in RTP-Ghulal line)		High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 749.84 A at 37 °C). <b>No remedial action required.</b>
220 KV Dhandari-PGCIL	606 A at 33 °C ambient temperature (108.2%)	Normal Existing load (only in paddy)		High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 688.01 A at 33 °C). <b>No remedial action required.</b>
220 KV Ajitwai-PGCIL Moga	588 A at 36 °C ambient temperature (105%)	Normal Existing load (only in paddy)		High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 668.72 A at 36 °C). <b>No remedial action required.</b>
220 KV PGCIL-Doraha	619 A at 35 °C ambient temperature (110.53%)	Normal Existing load (only in paddy)		High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 675.15 A at 35 °C). <b>No remedial action required.</b>
132 kV Ferozeshah - Kotkaror	333 A at 38 °C ambient temperature (104.06%)	Line is overloaded in paddy season due to small size of conductor		High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 369.8 A at 38 °C). Expected to be relieved with advent of 220 kV Dhalleke.
220 KV Line G 01 - Rajpura Ckt 01	630 A at 33 °C ambient temperature (112%)	Temporary (Due to Ckt no 02 is faulty)		High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 688.01 A at 33 °C). Also, replacement of existing conductor of 220 kV Gobindgarh - 400kV Rajpura (DC) with HTLS of suitable capacity already planned in MYT

				2020-23.
	220 KV Line G 01 - Rajpura Ckt 02	570 A at 29 ° C ambient temperature (102%)	Temporary (Only 1 No. Generating unit working at RTP end)	High loading is within permissible thermal limit corresponding to ambient temperature (i.e. 713.73 A at 29 ° C). Also, replacement of existing conductor of 220 kV Gobindgarh - 400kV Rajpura (DC) with HTLS of suitable capacity already planned in MYT 2020-23.

5. Amritsar

NIL

B) Loading status of power transformers of PSTCL substations

Sr. No.	P & M Circle	Name of Substation/ Transformer Identification	% loading as compared with the standard design Parameters	Remarks of P&M Organization	Proposal/Remedial Action by Planning
1.	Patiala			NIL	
2.	Jalandhar			NIL	
3.	Bathinda	220 kV Ferozepur/ T-3 (132/66 kV, 40/50 MVA)	103.34%	66 kV System is over-loaded at 220 kV S/S, Ferozepur	PSPCL has been repeatedly requested to carry out the necessary load shifting of 66 kV load at Ferozepur substation as due to space constraints there is no possibility of additional transformer installation/augmentation at 220 kV Ferozepur. Possibility of new 220 kV substation Jhoke Harihar is also being explored and is under study.
		220 kV Ferozepur/ T-4 (132/66 kV, 50 MVA)	100.60%		
4.	Ludhiana			NIL	
5.	Amritsar			NIL	

189

2



**ANNEXURE. NO. B**

**TRIPPING DETAILS FROM 01.04.2020 TO 30.09.2020**

J

190

**Detail Of Tripping / Breakdown of Transmission Lines affecting the power supply For the quarter Ending June-2020.**

Sr.No.	Name of the Line	Length of Line in KM	From	To	Duration	Relay Indication	Cause of Tripping / Breakdown and Remedial Measures Taken
1	132 KV Moga-Panigrain Kalan	31.5	02-04-2020 00:42	03-04-2020 01:06	0:24	RN-Φ, DPR & E/F 29.081 KM & E/F	Transient Fault
2	132 KV Moga-Panigrain Kalan	31.5	03-04-2020 05:26	03-04-2020 05:40	0:14	YN-Φ, DPR & 15.16 KM & E/F	Breaker not installed.
3	132KV Verka-Kathunangal	15.500	05-04-2020 20:35	05-04-2020 21:48	1:13	Dir, O/C, E/F 87N, 86	Transient Fault
4	132KV Verka-Pakharpura	20.000	05-04-2020 20:36	05-04-2020 20:47	0:12	Dir, O/C, E/F 67N, 86	Due to Heavy Windstorm
5	132KV Batala-Kathunangal	22.000	05-04-2020 20:36	05-04-2020 21:46	1:10	L3 Pickup,E/F, Distance trip.Zone-1 Master Trip 86	Tripped
6	132 KV Moga-Panigrain Kalan	31.5	05-04-2020 01:36	05-04-2020 02:03	0:27	RY-Φ, DPR & E/F	Breaker not installed.
7	132KV Verpal-Hakima Gate Ckt-1	9.940	06-04-2020 18:01	06-04-2020 18:16	0:15	B-Y Phase Highset	Transient Fault
8	132KV Verpal-Hakima Gate Ckt-2	9.940	06-04-2020 18:01	06-04-2020 18:16	0:15	B-Y Phase Highset	DP Zone-1 Razoa Trip ABC
9	Ablowal-Fagganmajra Ckt 1	10.330	07-04-2020 15:15	07-04-2020 15:55	0:40	No indication	No trip.
10	Ablowal-Fagganmajra Ckt 2 [A-6]	10.330	07-04-2020 15:15	07-04-2020 15:55	0:40	No indication	No trip.
11	Ablowal-Rajla (A-6)	30.290	07-04-2020 15:15	07-04-2020 15:55	0:40	No indication	No trip.
12	132 KV Moga-Panigrain Kalan	31.5	08-04-2020 00:40	08-04-2020 00:52	0:12	B-Φ DPR 18.988 KM O/C + E/F	Breaker not installed.
13	132 KV Moga-Panigrain Kalan	31.5	08-04-2020 03:07	08-04-2020 03:20	0:13	B-Φ DPR 24.089 KM O/C + E/F	Transient Fault

191

14	132 KV Moga-Panjgrain Kalan	31.5	08-04-2020	04:15	08-04-2020	17:06	12:51	R-Φ DPR 24.089 KM O/C + E/F	Breaker not installed.	Branch of tree touched the R phase and Tree cutting between Tower No. 285 To 286 was done.
15	132 KV Moga-Gholian Kalan	16.200	08-04-2020	05:28	08-04-2020	05:50	0:22	R-Φ O/C+E/F ON 10.3 KM		Temporary fault occurred due to flash over disc insulators.
16	132 KV Panjgrain Kalan-Srainaga	25	09-04-2020	03:45	09-04-2020	03:55	0:10	Breaker not installed.	B-Φ O/C + E/F	Transient Fault
17	132 KV Panjgrain Kalan-Srainaga	25	09-04-2020	04:40	09-04-2020	04:58	0:18	Breaker not installed.	B-Φ O/C + E/F Z1 12.67 KM	Transient Fault
18	132 KV Kolkaror - Ferozeshah Line	18.6	09-04-2020	07:35	09-04-2020	07:43	0:08	Y phase E/F	E/F	Transient Fault After tripping, switch yard & first pole of 132 KV Ferozeshah Line was checked by S/S Satti & was found ok. So, the line was energised.
19	132 KV Ferozeshah-Mana Singh Wala Line	10	09-04-2020	07:35	09-04-2020	07:43	0:08	O/C E/F L2T IP>2T IE>2T		Transient Fault After tripping, switch yard & first poles of both 132 KV lines were checked by S/S Satti & found ok. So, the lines were energised.
20	132 KV Sri Muktsar Sahib-Srainaga Line	12.73	09-04-2020	07:05	09-04-2020	07:20	0:16	RPh, O/C, E/F Rph, Z-1, 6.2 km	Transient Fault	
21	132 KV Moga-Panjgrain Kalan	31.5	10-04-2020	06:10	10-04-2020	16:13	10:03	YN-Φ DPR Z1 12.54 KM	Breaker not installed.	Disc String Faulty on Y-phase of Tower No.275 & 282.
22	132 KV Nakkian-Ropar	33.935	10-04-2020	15:15	10-04-2020	15:35	0:20	Not Tripped	RY-phase, zone-1, 9.5 KM	Temporary fault occurred due to flash over disc insulators.
23	132 kv Nakkian Power House	1.365	10-04-2020	16:15	10-04-2020	15:44	0.29	Not Tripped	RY-phase, zone-1, 29.775 KM	Temporary fault occurred due to flash over disc insulators.

192

24	220KV Majithia-Civilline	14.616	11-04-2020	3.30	11-04-2020	4.00	0.30	86 Breaker not tripped	Due to Protection System Operate of 220KV Bus-Bar at 220KV Majithia
25	220KV Majithia-Fatehgarh Churian	19.466	11-04-2020	3.30	11-04-2020	4.00	0.30	86 Breaker not tripped	Due to Protection System Operate of 220KV Bus-Bar at 220KV Majithia
26	132 KV Sarainaga-Muktsar Line	12.73	11-04-2020	01:10	11-04-2020	01:26	0:15	O/C+E/F,R-Phase, Zone-1,D=5.920 KM	O/C+E/F,R-Phase Transient Fault , Try taken as per PC Instructions
27	132 KV Sarainaga-Muktsar Line	12.73	11-04-2020	3.02	11-04-2020	3.20	0:18	O/C+E/F,R-Phase, Zone-1,D=5.936 KM	O/C+E/F,R-Phase Transient Fault
28	132 KV Sarainaga-Muktsar Line	12.73	11-04-2020	5.04	11-04-2020	17.35	12:31	O/C+E/F,R-Phase, Zone-1,D=6.018 KM	Disk Break of R Phase at tower no 247 & Break the Jumper of R Phase at tower no. 290
29	132 KV Muktsar-Jalalabad Line	33	12-04-2020	05:57	12-04-2020	06:10	0:13	O/C+E/F,B-Phase, O/C, E/F	Line Is Isolator controlled
30	132 KV Sri Muktsar Sahib-Sarainaga Line	12.73	12-04-2020	5:55	12-04-2020	6:10	0:15	BPH, O/C, E/F	Transient Fault
31	220KV Majithia-Civilline	14.616	13-04-2020	14.40	13-04-2020	16.20	1.40	86 Breaker not tripped	Due to Y Phase LA Damaged of 220KV Bus-Bar at 220KV Majithia
32	220KV Majithia-Fatehgarh Churian	19.466	13-04-2020	14.40	13-04-2020	16.20	1.40	86 Breaker not tripped	Due to Y Phase LA Damaged of 220KV Bus-Bar at 220KV Majithia
33	132 KV Moga-Panigrain Kalan	31.5	13-04-2020	08:13	13-04-2020	15:46	7:33	YN-Φ DPR Z1 20.096 KM	Disc String Faulty on Y-Phase of Tower No.306.

193

34	220KV Verpal-Rashiana	21.700	15-04-2020	15.52	16-04-2020	1.10	9.18	86, DPR, MICOM Broken Conductor	Breaker not tripped	Due to Y Phase Discs flashed at 220KV verpal(gantry to gantry)
35	132KV TarnTaran-Verpal	14.480	15-04-2020	15.52	15-04-2020	17.10	1.18	E/F, DMT 86	Supply failed at Verpal End(No Indication)	Due to Fault in 220KV Systn Verpal.
36	132 KV Sarainaga-Moga Line	25	16-04-2020	11:25	16-04-2020	16:50	5:25	QIC+E/F, Y-Phase, Zone-1,D=11.95 KM	(Kothapura-2 S/S) Isolator controlled	Transient Fault
37	132Kv Kapurthala-Science city	6.684,	16-04-20	12.42	16-04-20	12.50	00:08	Not Tripped	Dpr, YN, O/C R phase,Z-3.	Due to Tripping of 132KV Kapurthala-Rcf line.
38	132 KV Moga-Gholian Kalan	15	17-04-2020	23:29	18-04-2020	00:23	0:54	DPR RN-Φ Z1 ON	ON	Transient Fault
39	132 KV Kolkaror - Ferozeshah Line	18.6	17-04-2020	23:30	18-04-2020	00:14	0:44	Master Relay O/C E/F L2T IP>2T IE>2T	O/C E/F L2T IP>2T IE>2T	Duo to tripping of 132 KV Sosan Line
40	132 KV Ferozshah- Mana Singh Wala Line	10	17-04-2020	23:28	17-04-2020	23:44	0:16	QIC E/F IE>2T	No Tripping	Duo to Tripping of 132 KV Sosan Line
41	132 KV Muktsar-Jalalabad Line	33	17-04-2020	23:10	18-04-2020	14:13	15:03	O/C+E/F,R-Phase, & High Set O/C Relay	Line is Isolator controlled	Transient Fault Takes try After taking clearance certificate from AOTL Muktsar that Line Get Hold
42	132KV Batala-Dhoriwal Ckt-1	19.000	18-04-2020	2.10	18-04-2020	7.05	4.55	L-E/F,Pickup, Numerical,E/F	O/C, R Phase E/F 86	Duo to Red Phase Bus-Bas PT Blast
43	132KV Batala-Dhariwal Ckt-2	19.000	18-04-2020	2.10	18-04-2020	7.05	4.55	L-E/F,Pickup, Zone-1	O/C, R Phase E/F 86	Duo to Red Phase Bus-Bas PT Blast
44	132Kv Kartarpur-Beas	27.00	18-04-20	2.16	18-04-20	2.40	00:24	Dpr,AB Phase Z-1,FI-3.8km	Not Tripped	Due to earth wire breakdown between the towers span no.57-58-59,

194

45	132 KV HOSHIARPUR-CHOHAL	10.600	18-04-20	16.35	18-04-20	18.65	02:20	E/F	Y- PHASE O/C	132 KV RED PHASE BUS BAR PT DAMAGED AT 132 KV HOSHIARPUR END
46	132 KV HOSHIARPUR-BOPPUR	27.087	18-04-20	16.35	18-04-20	19.35	03:00	BREAKER NOT TRIPPED	DPR RYB PHASE ZONE 2ND	132 KV RED PHASE BUS BAR PT DAMAGED AT 132 KV HOSHIARPUR END
47	132 KV MAHILPUR-HOSHIARPUR CKT NO2	25.500	18-04-20	16.35	18-04-20	18.48	02:13	DPR RED PHASE E/F ZONE 2ND	BREAKER NOT TRIPPED	132 KV RED PHASE BUS BAR PT DAMAGED AT 132 KV HOSHIARPUR END
48	132-Ghulai- Doraha-Bilaspur-Sihora	37	18-04-2020	0.55	18-04-2020	1.20	0.25	E/F	Not Trip	Due to Heavy Storm
49	132 kv Naikian Power House	1.365	18-04-2020	15.58	18-04-2020	16.15	0.17	Not Tripped	over current,R-phase,zone-1, 29.775 KM	At tower no. 25 R-Phase 06 no disc insulator flashed due to lightning and at gantry 01 between Tower Span no. 74-75 R-Phase 02 no disc insulator flashed
50	132 kv Ropar	33.935	18-04-2020	15.58	18-04-2020	16.08	0.10	Not Tripped	Phase-AN,zone-1, 21.3 KM	At tower no. 25 R-Phase 06 no disc insulator flashed due to lightning and at gantry 01 between Tower Span no. 74-75 R-Phase 02 no disc insulator flashed.
61	132 KV Moga-Panjgrain Kalan	31.5	19-04-2020	05:30	19-04-2020	17:02	11:32	BN-Φ DPR Z1 30.2 KM	Breaker not installed.	Disc String Faulty on Y-Phase of Tower No.338 & 335.
52	132 KV Kotkarni- Feroze Shah Line	16.6	19-04-2020	16:40	19-04-2020	17:15	0:35	O/C EIF R-phase Highset	O/C EIF R-Phase	Due to damage of 132 kV LA of R Phase of Power T/F at 132 kV SS, Mans Singh Wala

105

C

53	132 KV Ferozshah-Mana Singh Wala Line	10	19-04-2020	16:40	19-04-2020	16:55	0:15	OIC E/F R-Phase	-	Due to damage of 132 KV LA of R Phase of Power TF at 132 KV S/S, Mana Singh Wala.
54	132 kv Ropar	33.935	19-04-2020	9.35	19-04-2020	10.14	0.39	Not Tripped	Phase AN zone- 1,21.3 km	At tower no. 25 R-Phase 06 no disc insulator flashed due to lightning and at gantry 01 between Tower Span no. 74-76 R-Phase 02 no disc insulator flashed.
55	132 kv Nakkhan Power House	1.365	19-04-2020	16.58	19-04-2020	10.21	0.46	Not Tripped	over current,R-phase-zone-1, 11.026 KM	Patrolling of line is done from tower no 15-55 and 72-85 and found that at tower no. 25 R-Phase 06 no disc insulator flashed due to lightning and at gantry 01 between Tower Span no. 74-75 R-Phase 02 no disc insulator flashed due to birdage .
56	132 kv Ropar	33.935	19-04-2020	12.08	19-04-2020	18.3	6.22	Not Tripped	Phase AN zone- 1,10.7 km	Patrolling of line is done from tower no 15-55 and 72-85 and found that at tower no. 25 R-Phase 06 no disc insulator flashed due to lightning and at gantry 01 between Tower Span no. 74-75 R-Phase 02 no disc insulator flashed due to birdage .
57	132 KV Megar Panjgrain Kalan	31.5	20-04-2020	02:48	20-04-2020	15:57	13:09	YB-Φ DPR Z1 14.9 KM	Breaker not installed.	Disc String Faulty on Y-Phase of Tower No. 27 & 279.

196

58	132 KV Moga-Panjgrain Kalan	31.5	20-04-2020	18:12	20-04-2020	21:13	3:01	BN-Φ DPR Z1 27.254 KM	Breaker not installed.	Transient Fault Line Charged on Msg of TL Muk.
59	132 KV Moga-Panjgrain Kalan	31.5	24-04-2020	02:43	24-04-2020	18:25	15:42	BN-Φ DPR Z1 10.09 KM	Breaker not installed.	Disc String Faulty on B- Phase of Tower No. 279 & Y-Phase of Tower No. 252.
60	132KV Batala-Dharowal Ckt-1	19.000	26-04-2020	15:58	26-04-2020	16:40	0:42	Master Trip,86 O/C, Red Phase 86 Master Trip		Duo to Heavy Wind Storm and Rain
61	132KV Gurdaspur - Dharowal Ckt-1	16.000	26-04-2020	15:58	26-04-2020	16:14	0:16	F, Master Trip, Breaker Not Tripped		Due to Tripping of 132KV Batala End.
62	132KV Gurdaspur - Dharowal Ckt-2	16.000	26-04-2020	15:58	26-04-2020	16:14	0:16	F, Master Trip, Breaker Not Tripped		Due to Tripping of 132KV Batala End.
63	132KV Gurdaspur-Sarna Ckt-1	30.000	26-04-2020	15:58	26-04-2020	16:11	0:13	Master Trip, ER Breaker Not Tripped		Due to Tripping of 132KV Dharowal End.
64	220Kv BBMB-JAL,- Alawalpur	13.407	28-04-20	5.53	28-04-20	13:32	07:39	Dpr, YN-Z- 1,F1-9.444Km 4.238Km		Dpr, YN-Z-1,F1- 4.238Km The disc Insulators of Y phase at Tw no. 257 were found flashed due to which line was tripped and same were replaced with new disc Insulators.
65	132KV TarnTaran-Verpal	14.480	29-04-2020	10:03	29-04-2020	10:30	0:27	Phase E/F, DN Blue phase O/C, highset, Zone-1		Due to some transient fault
66	132 KV Moga-Panjgrain Kalan	31.5	29-04-2020	02:44	29-04-2020	03:07	0:23	R-Φ DPR E/F Z1 19.112 KM	Breaker not installed.	Transient Fault
67	132 KV Sarainaga-Moga Line	25	29-04-2020	6:20	29-04-2020	6:42	0:22	O/C+E/F,Y- Phase B, Z-2, D=48.56 KM	Line isolator controlled (at kpp-2 end)	Transient Fault
68	220KV Udoke-Verpal	40.525	02-05-2020	22:34	02-05-2020	23:41	1:07	Dir, O/C, Blue Phase Zone- 1	Breaker Not Tripped	Due to some transient fault
69	220KV Verpal-BaisChak Ckt-1	1.972	02-05-2020	22:34	03-05-2020	0:46	2.12	86		Due to some transient fault
70	220KV Verpal-Patti	37.62	02-05-2020	22:34	03-05-2020	2:10	3:36	AB Phase E/F	Dir, O/C,86	Due to some transient fault

197

641

71	132 KV Muktsar-Jahalabad Line	33	02-05-2020	23:32	03-05-2020	07:55	8:23	O/C+E/F,B-Phase, D=0.0 KM	Line is isolator controlled	Take try after Removing the bird nest on tower No. 8 by AOTL.
72	132 KV Ghulai - Jamalpur Ckt-1	21.000	02-05-2020	22.14	02-05-2020	23.30	1.16	Directional Earth Fault	Y Phase Z-2 E/F	Temporary fault occurred
73	132 KV Ghulai - Jamalpur Ckt-2	21.000	02-05-2020	22.14	03-05-2020	14.32	16.18	Directional Earth Fault	Y Phase Z-2 E/F	Temporary fault occurred due to flash over disc Insulators.
74	132 KV Swadhi - Jamalpur	38.000	02-05-2020	21.52	03-05-2020	3.45	5.53	YN Phase KM	Y Phase,Z-1 43.2 KM	Temporary fault occurred due to flash over disc Insulators.
75	132 KV Swadhi - Moga	42.000	02-05-2020	21.52	03-05-2019	6.15	10.23	BN Phase	BN Phase Z-1 10.6 KM	Y Phase Disc Flashed at Tower no 131
76	220 KV Sandhwan - Bajakhana Line	50	03-05-2020	16.39	03-05-2020	18:01	1:22	DPR Main-1 operated R-phase	DPR Main-2 operated R-phase	Due to heavy flow of wind & storm.
77	220 KV Moga - Baghapurana Ckt-1	10	03-05-2020	16.39	03-05-2020	18:22	1:43	Master Relay	Backup Protection Operated	Due to Damage of Y-Φ Wavetrap (Half Portion Fell on ground) & B/D of R-Φ Jumper at Baghapurana Ckt-2.
78	220 KV Baghapurana - Bajakhana Ckt-2	34.5	03-05-2020	16.39	03-05-2020	19:34	2:55	O/C+E/F Backup Protection Operated	Main-1 & 2 DPR-R φ	Due to Heavy Storm in the region.
79	220KV Makhu-Dharmkot Ckt- 1 & 2	21.500	03-05-2020	16.39	03-05-2020	17.37	0.58	Power System Faulty	Not Trip	220 kv bus bar tripped
80	220 KV Moga - Baghapurana Ckt-2	10.00	03-05-2020	16:39	06-05-2020	19:43	75.4	Y-Φ E/F & DPR Z1 0.468 KM	Backup Protection Operated	Due to Damage of Y-Φ Wavetrap (Half Portion Fell on ground) & B/D of R-Φ Jumper
81	132 KV Moga-Ghollan Kalan	15	03-05-2020	17:15	03-05-2020	18:23	1:08	E/F & DPR R-Φ Z1 7.9 KM	ON	Due to Heavy Storm in the region.

198

82	132 KV Moga- Ghullan Kalan	15	03-05-2020	19:19	07-05-2020	20:20	97.01	DPR B-Φ Z1 ON 2.6 KM			132 KV Tower Collapsed near voltage singhwala.
83	132 KV Muktsar-Sarainaga Line	12.73	04-05-2020	0.55	04-05-2020	1.10	0:15	BPh, O/C, E/F			Transient Fault
84	132KV Mall-Mandi-GT Road	0.700	05-05-2020	13.01	05-05-2020	13.06	0.07	No Indication			Due to some transient fault.
85	132 KV Moga-Panigrain Kalan	31.5	05-05-2020	05:21	05-05-2020	05:42	0:21	R-Φ, DPR Z1 18.937 KM	Breaker not installed.		Transient Fault
86	132 KV Sarainaga-Moga Line	28.5	06-05-2020	18:32	06-05-2020	18:52	0:20	O/C+E/F,R-Phase Z-1 D=25.01 KM	Line is isolator controlled (at Kotkapura-2 SIS)		Transient Fault
87	132KV Ferozpur-Fairidkot Line	41	06-05-2020	18:15	06-05-2020	18:45	0:30	CN phase Zone -1, Location 25.4 km	Isolator controlled; No Breaker installed		Due to bad weather condition (Storm & rain)
88	132 KV Moga-Panigrain Kalan	31.5	07-05-2020	01:21	07-05-2020	01:40	0:19	Y-Φ, DPR Z1 22.738 KM	Breaker not installed.		Transient Fault
89	220KV Jamsher-Jadia	69.572	10-05-20	7.01	10-05-20	8.30	01:29	Dpr, YN,Z-1,Fl-1,Fl-19.2Km	Dpr, YN,Z-1,Fl-30.16km		Due to Heavy Storm and lightning.
90	220 KV BAKHRA-MAHILPUR CKT NO.1	51.096	10-05-20	6.50	10-05-20	9.45	02:55	BREAKER NOT TRIPPED	O/C RYB PHASE		DUE TO HEAVY STORM BUS BAR SIDE 3 NO. POST INSULATOR BREAK
91	220 KV BAKHRA-MAHILPUR CKT NO.1	51.096	10-05-20	6.50	10-05-20	9.50	03:00	RYB PHASE ZONE 1ST	BREAKER NOT TRIPPED		DUE TO HEAVY STORM 220/132 KV 100 MVA T-5POWER T/F HV SIDE RED PHASE BUS BAR SIDE 3 NO POST INSULATOR BREAK
92	220 KV MAHILPUR - REHANA JATTAN	26.708	10-05-20	6.50	10-05-20	9.40	02:50	BREAKER NOT TRIPPED	RYB PHASE E/F ZONE 1ST		DUE TO HEAVY STORM 220/132 KV 100 MVA T-5POWER T/F HV SIDE RED PHASE BUS BAR SIDE 3 NO POST INSULATOR BREAK

199

93	220 KV MAHILPUR-JAMSHER	47.375	10-05-20	6.50	10-05-20	9.30	02:40	RYB PHASE	BREAKER NOT TRIPPED	DUE TO HEAVY STORM 220/132 KV 100 MVA T-POWER T/F HV SIDE RED PHASE BUS BAR SIDE 3 NO. POST INSULATOR BREAK			
94	132KV Verka-Kathunangal	15.500	10-05-2020	5.40	10-05-2020	6.18	0.38	Dir,OIC,E/F		Due to Heavy Wind Storm and Rain			
95	132KV Verka-Pakharpara	20.000	10-05-2020	5.40	10-05-2020	6.14	0.34	Dir,OIC,E/F		Due to Heavy Wind Storm and Rain			
96	132KV Batala-Wadala Granthian Ckt-2	7.000	10-05-2020	5.40	10-05-2020	6.35	0.55	Dir,OIC,E/F,M aster Trip 86	BREAKER NOT Tripped	Due to Heavy Wind Storm and Rain			
97	132KV Batala-Wadala Granthian Ckt-3	8.000	10-05-2020	5.40	10-05-2020	6.35	0.55	Dir,OIC,E/F,M aster Trip 86	BREAKER NOT Tripped	Due to Heavy Wind Storm and Rain			
98	132KV Batala-Dhariwal Ckt-1	19.000	10-05-2020	5.40	10-05-2020	6.50	1.10	Dir,OIC,E/F,M aster Trip 86		Due to Heavy Wind Storm and Rain			
99	132KV Batala-Dhariwal Ckt-2	19.000	10-05-2020	5.40	10-05-2020	6.50	1.10	Dir,OIC,E/F,M aster Trip 86		Due to Heavy Wind Storm and Rain			
100	132KV Batala-Pakharpara	17.600	10-05-2020	5.40	10-05-2020	6.48	1.08	OIC,E/F,M aster Trip Distance Protection		Due to Heavy Wind Storm and Rain			
101	132KV Wadala Granthian-Batala Ckt-1	7.000	10-05-2020	5.40	10-05-2020	6.35	0.55	Dir,OIC,E/F	Dir, OIC, inverse type	Due to Heavy Wind Storm and Rain			
102	132 KV Moga-1 (Interlink Ckt-1)	7.5	10-05-2020	00.50	10-05-2020	09.99	0.19	RYB-Φ DPR Z1	ON	Transient Fault			
103	132Kv Kartarpur-Beas	27.00	10-05-20	7.55	10-05-20	10.45	02:50	Dpr, ACN,Z-1	Not tripped	The disc insulators of R phase at Tw no. 128 were found flashed due to which line was tripped and same were replaced with new disc insulators.			

200

104	132 KV MAHILPUR-HOSHIARPUR CKT NO2	25.500	10-05-20	6.50	10-05-20	9.05	02-15	BREAKER NOT TRIPPED	E/F	DUE TO HEAVY STORM 220/132 KV 100 MVA T-SPOWER T/F HV SIDE RED PHASE BUS BAR SIDE 3 NO. POST INSULATOR BREAK AT 220 KV MAHILPUR END
105	132 KV Swadhi - Jamalpur	38.000	10-05-2020	8.40	10-05-2020	13.57	5.17	BN-Phase, Z-1 , 31.1 KM	YN-Phase , Z-1 , 4.31 KM	Temporary fault occurred due to flash over disc insulators.
106	132 KV Swadhi - Moga	42.000	10-05-2020	8.50	10-06-2020	9.25	0.35	Not Trip	Not Trip	Due to Tripping of 132 KV Singhawala -Moga Line
107	132 Kv Doraha - Billaspur - Shhora	23.000	10-05-2020	9.40	10-05-2020	9.58	0.18	E/F	Not Trip	Temporary fault occurred due to flash over disc insulators.
108	220 Kv Ajitwal - Moga	21.700	11-05-2020	23.45	12-05-2020	2.35	2.50	Prot. Operate ON Z-1, RYB Phase, S.7	ON	Transient Fault
109	220 Kv Jagraon - Ajitwal	14.300	11-05-2020	23.45	12-05-2020	10.47	11.02	Trip RYB Phase Z-1,2,3 Prot. Operate	RYB Phase , Phase Z-1,2,3 Prot. Operate	Temporary fault occurred due to flash over disc insulators.
110	220 KV Makhu-Dharmkot ckt-1	21.600	11-05-2020	23.11	12-05-2020	0.12	1.01	Main -1 Operate B - Phase , 1.25 KM	Not Trip	Bus Bar No-2 Relay operate
111	220 KV Makhu-Dharmkot ckt-2	21.500	11-05-2020	23.11	11-05-2020	23.51	0.40	Main -1 Operate , 86 KM	Not Trip	Bus Bar No-2 Relay operate
112	220 KV G-1 - RTP Ckt-1	61.000	12-05-2020	1.05	12-05-2020	3.10	2.05	R Phase , O/C	Not Trip	Transient fault, Supply Restore After the Instruction of PC Patiala
113	220 Kv G-1 - Bassi Pattiha	23.000	12-05-2020	1.05	12-05-2020	3.17	2.12	REL-670 , O/C , R Phase	ON	Transient fault, Supply Restore After the instruction of PC Patiala

201

C

114	220 Kv Bassi Pathana-RTP	53.000	12-05-2020	1.05	12-05-2020	1.46	0.41	R Phase, Z-2 ON Trip 86	Transient fault, Supply Restore After the instruction of PC Patiala
115	220 Kv Bassi Pathana-RTP	53.000	12-05-2020	2.01	12-05-2020	2.18	0.17	R Phase Z-2 ON	Transient fault, Supply Restore After the instruction of PC Patiala
116	220 KV Amlah - G-1	10.000	12-05-2020	2.00	12-05-2020	2.56	0.56	E/F, OIC ON	Transient fault, Supply Restore After the instruction of PC Patiala
117	220 Kv G-1 - Rajpura Ckt-1	31.790	12-05-2020	1.05	13-05-2020	17.39	40.34	REL 670, RYB Phase Z-1, Trip 86	R Phase Limb Damage of Breaker
118	132 KV Ghulai-Shamspur- Sehe	17.713	12-05-2020	4.20	12-05-2020	4.55	0.35	E/F Not Trip	Transient fault, Supply Restore After the instruction of PC Patiala
119	132 KV Kollapura-Muktbar Line	28.4	13-05-2020	02:10	13-05-2020	02:24	0:14	O/C+E/F, Y Phase, D=62.65 KM	Transient Fault
120	132 KV Kotkapura-Moga Line	34.6	13-05-2020	02:10	13-05-2020	02:24	0:14	O/C+E/F, Y Phase	Breaker not tripped
121	132 Kv Ghulai-Chamkaur Sahib	29.000	15-05-2020	1.05	15-05-2020	1.25	0.20	E/F	Temporary fault occurred due to flash over disc Insulators.
122	132 Kv Ghulai-shamspur- Sehe	17.71	15-05-2020	1.05	15-05-2020	1.30	0.25	E/F	Temporary fault occurred due to flash over disc Insulators.
123	132 KV Muktsar-Sarainaga Line	12.73	16-05-2020	4.02	16-05-2020	6.25	2:23	RPh, O/C, E/F	RPh, O/C
124	132 KV Sarainaga-Moga Line	28.5	16-05-2020	05:55	16-05-2020	06:25	0:30	O/C+E/F, B Phase Z-1 D=16.27 KM	Breaker not tripped
125	132 KV Moga-Panjgrain Kalan	31.5	16-05-2020	03:14	16-05-2020	03:35	0:21	RY-Φ, DPR Z1 14.502	Transient Fault
126	132 KV Moga-Panjgrain Kalan	31.5	16-05-2020	05:57	16-05-2020	06:09	0:12	R-Φ DPR Z2 50.99 KM	Breaker not installed.

202

127	132 KV Muktsar-Jalalabad Line	33	17-05-2020	20:58	17-05-2020	21:09	0:11	O/C+E/F, B Phase D=0.0 KM	Line Is Isolator Controlled	Transient Fault
128	132 KV Moga-Panigrain Kalan	31.5	17-05-2020	02:06	17-05-2020	02:20	0:14	RY-Φ DPR Z1 19.321 KM	Breaker not installed.	Transient Fault
129	132 KV Moga-Panigrain Kalan	31.5	17-05-2020	05:14	17-05-2020	07:04	1:50	RN-Φ DPR Z1 26.919 KM	Breaker not installed.	Transient Fault Line charged on msg of AEETL, Muktsar.
130	132 KV Moga-Panigrain Kalan	31.5	18-05-2020	03:31	18-05-2020	03:47	0:16	B-Φ DPR Z1 26.08 KM	Breaker not installed.	Transient Fault
131	132 KV Muktsar-SaraiNaga Line	12.73	21-05-2020	2:05	21-05-2020	2:15	0:10	RPh, O/C, E/F	-	Transient Fault
132	132Kv Khera mandir-Sultanpur	12.00	21-05-20	5.22	21-05-20	5.27	00:05	Not tripped	Dpr, RN_2-1	The disc Insulators of R phase at Tw no.49 were found flashed due to which line was tripped and same were replaced with new disc insulators.
133	132KV Verpal-TarnTaran	14.480	22-05-2020	23:08	23-05-2020	5.19	6:11	E/F, Highset,86	B-Phase E/F, DMT Master Trip	Due to 132KV Breaker damaged of 132KV TarnTaran-Patti Line at TarnTaran end.
134	132KV TarnTaran-Patti	24.500	22-05-2020	23.02	02-06-2020	18.40	259.38	Bluse Phase , Dir, O/C, E/F, 67B, 67N 86	*****	Due to 132KV Breaker damaged of 132KV TarnTaran-Patti Line at Tarn Taran end.
135	132 KV S/S Ropar	31.935	22-05-2020	12.26	22-05-2020	15.42	03:17	L3,L3 Zone-1, RY-phase,Earth 8.8 Km	R.Y-phase,Earth Fault zone-1,FT-1, master trip 23.00 Km	during patrolling found that line tripped due to stuble burning b/w span no 33-34
136	220KV Fatehgarh Churian-Kotli Surat Malhi	22.000	23-05-2020	15.25	23-05-2020	15.57	0.32	Main-1 DPR Start Trip	Due to Some Transist fault in line	

203

C

137	220KV Kotli Surat Malhi-Wadala Granthian	29.670	23-05-2020	15.25	23-05-2020	16.07	0.42	Main-1 Protection operated Auto Recloser	Main-1 any Trip	Due to Some Transist fault in line
138	132Kv Pims-Science city	18.756	23-05-20	19.15	23-05-20	19.21	00:06	Not tripped. Dpr, O/C Earth fault		During patrolling of this line it is found that illegal construction of building between tower span no.50, 51 and Clearance from line is maintained by removing first floor of that building and now line is cleared.
139	132 KV Ghulai- Jamalpur Ckt-2	21.000	23-05-2020	17.02	23-05-2020	17.43	0.41	Not Trip	Master Trip	Transient fault . Supply Restore After the Instruction of PC Patiala
140	132 KV Ghulai- Jamalpur Ckt-1	21.000	23-05-2020	17.02	24-05-2020	16.15	23.13	E/F, O/C , B Phase	Y Phase Conductor Breakdown of Gantry at Jamalpur End	Y Phase , Z-1 0.9 KM
141	132 KV Nakkiyan Power house	1.365	23-05-2020	17.04	23-05-2020	17.40	00:36	Not Tripped	B-Phase,zone-1	Duo to tripping of Nakkiyan- Ropar line
142	132 KV S/S Ropar	33.936	23-05-2020	17.04	23-05-2020	17.16	00:12	Not Tripped	CN-Phase,zone- 1, FT-1,	During patrolling from L.no 1-27 it found that safeda touched the conductor from 17 mtr in span no 22-23
143	132 KV S/S Ropar	33.935	23-05-2020	17.22	23-05-2020	20.15	02:53	Not Tripped	BN-Phase,zone- 1, FT-1,33.6 Km	During patrolling from L.no 1-27 it found that safeda touched the conductor from 17 mtr in span no 22-23
144	132 KV Doraha- Bitaspur - Sihora	23.000	26-05-2020	21.27	26-05-2020	4.54	7.27	O/C , B Phase	Not Trip	B Phase CT Damage at Doraha End

204

145	132 KV Ferozpur-Mana Singh Wala	11.6	26-05-2020	12:37	26-05-2020	12:48	0:11	O/C Ip>2T, AB Phase	No tripping	Due to tripping of 132 KV Ferozeshah Kotkaror Line & 66 KV Mallanwala Line from 132 KV S/S, Ferozeshah
146	132 KV Kotkaror-Ferozeshah Line	18.6	26-05-2020	12:37	26-05-2020	13:02	0:25	O/C Highset RY Phase, E/F	No tripping	Due to tripping of 66 KV Mallanwala Line at 132 KV S/S, Ferozeshah
147	132KV Ferozeshah-Mana Singh Wala Line	18.6	26-05-2020	12:35	26-05-2020	13:00	0:25	O/C AB Phase	No tripping	Due to tripping of 66 KV Mallanwala Line
148	132 KV NAWANSHAHAR-BANGA	14.00	26-05-20	0.35	26-05-20	1.16	00:41	RYB PHASE ZONE 2ND TRIPPED	BREAKER NOT TRIPPED	132 KV Y&B PHASE CT DAMAGED OF 132 KV BANGA-PHAGWARA LINE AT 132 KV BANGA S/STN END
149	132 KV BANGA-PHAGWARA	20.00	26-05-20	0.35	26-05-20	1.25	00:50	Y&B PHASE	Y&B PHASE	132 KV Y&B PHASE CT DAMAGED OF 132 KV BANGA-PHAGWARA LINE AT 132 KV BANGA S/STN END
150	132 KV MAHILPUR-BANGA	27.80	26-05-20	0.35	26-05-20	1.25	00:50	RYB PHASE ZONE 2ND	BREAKER NOT TRIPPED	132 KV Y&B PHASE CT DAMAGED OF 132 KV BANGA-PHAGWARA LINE AT 132 KV BANGA S/STN END
151	220 KV Kotkaror - Sadiq Line	37.4	27-05-2020	12:45	27-05-2020	17:23	4:38	DPR Zone 2, RY&B phase	O/C RYB, DPR Zone 1, location 1.025 km	Transient Fault
152	220 KV Ferozpur Road - Lalton	18.46	28-05-2020	18.23	28-05-2020	19:30	1:07	Z-4, RYB Phase 6.3 KM	Not Trip	66 KV Earth Wire Broken at FZR Road S/Stn Yard
153	220 KV Ferozpur Road - Laddowal	27.416	28-05-2020	18.23	28-05-2020	20:41	2:18	Z-1 RYB Phase 8.4 Km	Main 1 & 2 BC Phase Z-2	Temporary fault occurred due to flash over disc insulators.
154	220kv sunam-Bhalwan ckt no-1	29.18	28-05-2020	17.41	28-05-2020	18:56	01:15	DPR-2 Zone-4 RPhi Dist/ 15002km	Not Tripped	Due to heavy storm

205

10

165	220kv sunam-Bhalwan ckt no-2	29.18	26-05-2020	17:41	28-05-2020	18:57	01:16	DPR-2 Zone-4 RΦ Dist/1654km	Not Tripped
156	220kv sunam-Patran	35.65	28-05-2020	17:41	28-05-2020	'23:42	06:01	DPR Main-1 & 2 RYB φ Zone-2 dist-3/25km, Main-2 RB φ Zone-2 dist-30/90km	Due to heavy storm
157	132 KV Balluan-Bathinda	19.15	28-05-2020	17:02	28-05-2020	18:30	1:25	R-phase O/C Z-1, dpr distance 11.03km	strongs winds
158	132 KV HOSHIARPUR-CHOHAL	10.800	28-05-20	14.32	28-05-20	14.45	00:13	BREAKER O/C Y&B-PHASE	Transient Fault
159	132 KV HAMIRPUR-CHOHAL	66.650	28-05-20	14.32	28-05-20	14.45	00:13	BREAKER O/C B-PHASE	Transient Fault
160	132 KV HOSHIARPUR-CHOHAL	10.600	28-05-20	14.32	28-05-20	14.45	00:13	BREAKER O/C Y&B-PHASE	Transient Fault
161	132 KV Saranaga-Moga Line	28.5	30-05-2020	05:10	30-05-2020	05:24	0:14	O/C+E/F, B Phase Z-1 D=18.65 KM	Breaker OFF
162	132 KV NAWANSHAHAR-BANGA	14.000	30-05-20	17.10	30-05-20	19.10	02:00	R-PHASE ZONE 2ND	Transient fault DUE TO STORM & HEAVY RAIN
163	132 KV BANGA-PHAGWARA	20.000	30-05-20	17.10	30-05-20	18.02	00:52	R-PHASE ZONE 2ND TRIPPED	Transient fault DUE TO STORM & HEAVY RAIN
164	132 KV Ghulai-Samtspur-Sehe	17.713	30-05-2020	18.55	30-05-2020	19.16	0.21	E/F Master Trip	Temporary fault occurred due to flash over disc insulators.
165	132 Kv Ghulai - Chamkaur Sahib	29.000	30-05-2020	18.55	30-05-2020	19.15	0.20	E/F ,Master Trip	Temporary fault occurred due to flash over disc insulators.
166	132 KV Muktsar-Jalandhar Line	33	31-05-2020	23:17	31-05-2020	23:41	0:24	O/C+E/F, B Phase Z-1,D=12.7 KM	Line Is Isolator Controlled

206

157	132Kv Kapurthala- Science city	6.68	31-05-20	6.45	31-05-20	17.15	10:30	Not Tripped	Dpr, BN,Z-3	The disc insulators of B phase and Y phase at Tw no.96 were found flashed due to which line was tripped and same were replaced with new disc insulators.
168	132 KV Moga- Panigrain Katian	31.5	01-06-2020	23:31	01-06-2020	23:43	0:12	DPR YN-Φ Z- 1 22.161 KM	Breaker not installed.	Transient Fault
169	132 KV Moga-Dhalleke	14	01-06-2020	04:30	01-06-2020	14:05	9:35	DPR B-Φ Z-1 10.3 KM	Breaker not Installed at dhalleke.	Branch of tree fallen between Tower No.:09 & 10, near Bukan wala Village.
170	132 KV Multsar- Jalalabad Line	33	01-06-2020	04:52	01-06-2020	14:55	10:03	O/C+E/F , B Phase Z- 1,D=12.7 KM	Line Is Isolator Controlled	Transient Fault
171	132 KV Moga-1- Jamalpur Line	75	02-06-2020	20:32	05-06-2020	13:41	6:5:09	DPR R-Φ Z1 29.9 KM	OFF	Transient Fault Patrolling Between Tower No. 110 To 132 by AOTL Ludhiana. Line Charged on Msg of AOTL Ludhiana.
172	132 KV Sarainaga- Muktsar Line	12.73	02-06-2020	01:02	02-06-2020	01:07	0:05	E/F & Master Relay	Breaker not tripped	Transient Fault Try Taken after the permission of PC Patiala
173	132 KV Sarainaga- Muktsar Line	12.73	02-06-2020	03:08	02-06-2020	15:15	12:07	E/F & Master Relay	Breaker not tripped	after patrolling the yard at 6:00 ,02 no tower of Sarainaga line jumper
174	132 KV Sarainaga- Moga Line	28.5	03-06-2020	13:34	03-06-2020	13:52	0:18	O/C+E/F , R&B Phase Z- 1,D=2.05 KM	Line Is isolator controlled	Transient Fault Take try with the permission of SSE and PC Patiala
175	132kv Chohali- Hoshiarpur	10.600	03-06-20	17:40	03-06-20	19.25	25:45	BREAKER OPEN	ONG BLUE PHASE	B-PHASE 132 KV CT DAMAGED AT 132 KV CHOHAL END

207

B-PHASE 132 KV CT DAMAGED AT 132 KV CHOHAL END									
176	132 KV HAMIRPUR-CHOHAL	66.650	03-06-20	17.40	03-06-20	20.25	02-45	BREAKER NOT TRIPPED	EF
177	220 KV Muktsar-Ghubaya Line	40.304	04-06-2020	15:53	04-06-2020	19:20	3:27	Over current Earth fault, tripped. Over current DPR zone-2,FL-35.5KM	Y-B Phase operated' FL-2.2KM, Zone-1 Transient Fault
178	132KV Verpal-Mal Mandi	11.650	04-06-2020	0.51	04-06-2020	1.06	0.15	E/F, Master Trip	Breaker Not Tripped Due to some transient fault
179	132kv Verpal-Hakimata Ckt.2	9.940	04-06-2020	19.01	04-06-2020	23.40	4.39	High Set B Phase E/F	DPR TN Master Trip 86 Due Heavy wind storm
180	132 KV Moga-Panjgrain Kalan	31.5	04-06-2020	03:03	04-06-2020	03:15	0:12	DPR YN-Φ Z-1 12.337 KM	Breaker not installed. Transient Fault
181	132 KV Saranaga-Moga Line	28.5	04-06-2020	18.46	04-06-2020	18.58	0:12	O/C+E/F, Y-Phase φ,Z-1,0-31.31 KM	Line is isolator controlled Transient Fault ,Take try with the permission of SSE
182	132KV Batala Pakharpura	17.600	06-06-2020	8.05	06-06-2020	8.15	0.10	Dir O/C E/F Master Trip 86	Breaker Not Tripped Due Heavy wind storm
183	132KV Verka Pakharpura	20.000	06-06-2020	8.05	06-06-2020	8.26	0.21	Dir O/C E/F Master Trip 86	Breaker Not Tripped Due Heavy wind storm
184	132 KV Moga-Interlink Ckt-01	7.5	06-06-2020	13:22	06-06-2020	13:42	0:20	B-Φ O/C+E/F ON	Transient Fault
185	132 KV Moga-Dhalleke Dharmkot Line	16	06-06-2020	13:22	06-06-2020	13:30	0:08	O/C+E/F ON	Transient Fault
186	132 KV Moga-Panjgrain Kalan	31.5	07-06-2020	02:55	07-06-2020	03:05	0:10	DPR BN-Φ Z1 18.511 KM	Breaker not installed. Transient Fault
187	132KV Verpal-Mal Mandi	11.650	09-06-2020	10.10	09-06-2020	10.24	0.14	E/F Highset	Breaker Not Tripped Due to some transient fault
188	132kv Verpal-Hakimata Gate Ckt.1	9.940	11-06-2020	21.20	11-06-2020	21.47	0.22	n Set R Phase Y Phase Zone 1	Due to some transient fault
189	132kv Verpal-Hakimata Gate Ckt.2	9.940	11-06-2020	21.20	11-06-2020	23.01	1.41	Set Y Phase Df Y Phase Master Trip 86	Due to some transient fault
190	132kv Verpal-Hakimata Gate Ckt.1	9.940	12-06-2020	14.01	12-06-2020	14.24	0.23	n Set Phase E	Breaker Not Tripped Due Heavy wind storm

191	132 KV Moga-Panjgrain Kalan	31.5	12-06-2020	21:51	12-06-2020	22:21	0:30	DPR BN-Φ Z1 22.093 KM	Breaker not installed.	Transient Fault
192	220 Kv Shahnewal - Ghulal	21.188	13-06-2020	12.02	13-06-2020	12.48	0.46	Bus Bar Protection Operate	On	220 kv Bus Bar 1&2 Tripped
193	220 Kv Gaunagarh - RTP	77.071	13-06-2020	12.02	13-06-2020	13.07	1.05	General Trip Zone-1,B,1,B-Phase Phase	General	Temporary fault occurred due to flash over disc insulators.
194	132kv Batala-Dharianwali Ckt 1	19.000	13-06-2020	14.22	13-06-2020	14.55	0.33	O/C EF	Breaker Not Tripped	Due to some transient fault
195	132kv Batala-Dharianwali Ckt 2	19.000	13-06-2020	14.22	13-06-2020	14.55	0.33	O/C EF	Breaker Not Tripped	Due to some transient fault
196	132kv Kangra Mmoon	63.000	13-06-2020	14.50	13-06-2020	15.10	0.20	O/C EF	Breaker Not Tripped	Due Heavy wind storm
197	132kv Kangra Mmoon	83.000	13-06-2020	15.58	13-06-2020	16.03	0.06	O/C EF	Breaker Not Tripped	Due Heavy wind storm
198	132kv Pathankot Sarna Ckt.2	7.00	13-06-2020	14.50	13-06-2020	15.10	0.20	O/C Y Phase Z-.....	.....	Due to Heavy wind storm and Tree fall on 132kv Sarna Gurdaspur line
199	132kv Gurdaspur Sarna ckt. 2	30.000	13-06-2020	14.50	14-06-2020	0.15	9.25	Razza STN Z-2	.....	Due to Heavy wind storm and Tree fall on 132kv Sarna Gurdaspur line
200	132kv Gurdaspur Sarna ckt. 2	30.000	13-06-2020	14.26	13-06-2020	14.36	0.10	Razza STN Z-2	No indication	Due to some transient fault
201	132 KV Moga-Panjgrain Kalan	31.5	13-06-2020	17:04	13-06-2020	17:12	0:08	DPR BN-Φ Z1 12.423 KM	Breaker not installed.	Transient Fault
202	132 KV Ghulal-Shamaspur- Seh	17.713	13-06-2020	12.25	13-06-2020	20.02	7.37	Distance E/F	Earth Breakdown Between Tower No 45 to 50	
203	132 KV Multisar Link Ckt-1	1.6	14-06-2020	22:20	14-06-2020	22:45	0.25	O/C+EF, B Phase D=3.4 KM	Breaker not tripped	Due to Breakdown of 132 kv Saraihaga line and Take try with the permission of SSE

209

6

204	132 KV Muktsar Link Ckt-2	1.6	14-06-2020	22:20	14-06-2020	22:48	0:28	O/C+E/F, B Phase,D=3.4 KM	Breaker not tripped	Due to Breakdown of 132 kV Sarainaga line and Take try with the permission of SSE
205	132 KV Muktsar- Sarainaga Line	12.73	14-06-2020	22.20	15-06-2020	14.15	15:55	BPh, OIC, EIF	-	<b>BREAKDOWN OF B-Ph CONDUCTOR B/W TOWER NO. 489 TO 490.</b>
206	132 KV Kotkapura 1- Muktsar Line	28.4	14-06-2020	22:20	14-06-2020	22:54	0:34	OIC+E/F, B Phase,Z- 3,D=32.26 KM	Breaker not tripped	Transient Fault , Take try with the permission of SSE
207	1321 KV Kotkapura- Mega Line	47.1	14-06-2020	22:20	14-06-2020	22:38	0:18	OIC+E/F, B phase	Breaker not tripped	Transient Fault , Take try with the permission of SSE
208	220 kv Himmatpura - Bachni Kalan	18.48	18-06-2020	18.58	19-06-2020	12.09	17.13	Main - 1&2, RYB- Phase,LBB Operate,Bus Bar Protection,Z- 1 R-Phase,Z- 2 R-Phase	LBB Protection- 1, Auto Reclose,LBB Protection,OPCD	Mal functioning of relay
209	132kv Patti - Bhikhilwind	19.37	18-06-2020	19.25	20-06-2020	19.23	47.58	ractional O/c	****	Due to conductor Broken Between tower 27-28
210	220kv Civil Line Fatehgarh Churian	19.466	19-06-2020	17.40	19-06-2020	22.53	5.13	RYB Phasse Zone 2	Main1 Protection Failure Dir EIF	At civil Line End wave Trap Caught Fire
211	220kv Wadala Grantian Fateh Gargh Churian	33.480	19-06-2020	17.10	19-06-2020	19.02	1.52	Main 1, ABC Trip Auto Reclose 186 A 186B EIF	Main2 RN T970 1971 T973 Dir Protection Operated	Due to Heavy wind storm
212	220kv KSM WG	29.670	19-06-2020	17.09	19-06-2020	18.22	1.13	Dir O/C Backup Master Trip 86	Breaker not tripped	Due to Heavy Wind storm

210

213	132 KV Muktsar-Jalandhar Line	33	19-06-2020	03:55	19-06-2020	04:05	0:10	O/C+E/F, R&Y Phase:Z- 1,D=26.3 KM	Line is isolator controlled	Transient Fault , Take try with the permission of SSE
214	132 KV Saranaga-Moga Line	28.5	19-06-2020	05:20	19-06-2020	05:30	0:10	O/C+E/F, R&Y Phase:Z- 1,D=24.93 KM	Line is isolator controlled	Transient Fault Take try with the permission of SSE
215	132 KV MAHILPUR-HOSHARPUR CKT NO2	25.500	19-06-20	18.08	19-06-20	19.59	01:51	B-PHASE E/F ZONE 1ST	(Flash over temporary fault) DUE TO STORM &HEAVY RAIN	
216	132KV KOT KAROR LINE	18.6	19-06-2020	15:50	19-06-2020	16:20	0:30	L2T IP>2T	No tripping	Due to overload
217	132Kv BBMB JAL- Dhiliwan	37.000	19-06-20	17.50	19-06-20	15.22	21:32	Dpr, BN,Z- 1,FI-14.59km	Not tripped	The disc insulators of B phase at Tw no.256 were found flashed due to which line was tripped and same were replaced with new disc insulators.
218	132Kv Focal point-Kartarpur	12.00	19-06-20	17.50	19-06-20	15.05	21:15	Dpr, RN,Z- 2,FI-8.6km	Dpr, RN,Z-1	The disc insulators of R phase at Dead end Tw no.556 were found flashed and also breakdown of earthwire is found between tw no.555- 556 due to which line was triped and same were replaced with new disc insulators.
219	132Kv Khera mandir-Sultanpur	12.00	19-06-20	18.10,	19-06-20	19.38	01:28	Dpr, YN,Z-1	Breaker Tripped.	The disc insulators of Y phase at Tw no.49 were found flashed due to which line was tripped and same were replaced with new disc insulators.

211

220	132 KV BHOGPUR-HOSHIARPUR	27.087	19-06-20	17.40	19-06-20	19.05	01:25	B-PHASE ZONE 1ST	B-PHASE E/F	(Flash over temporary fault& transient fault) DUE TO STORM & HEAVY RAIN
221	132 KV MAHILPUR-HOSHIARPUR CKT NO2	25.500	19-06-20	18.08	19-06-20	19.59	01:51	B-PHASE E/F O/C B-PHASE ZONE 1ST	(Flash over temporary fault& transient fault) DUE TO STORM & HEAVY RAIN	
222	132 KV HAMIRPUR-CHOHAL	66.650	20-06-20	21.04	20-06-20	21.30	00:26	BREAKER NOT TRIPPED	Y-PHASE ZONE1,2,3&4TH	(Flash over temporary fault& transient fault) LINE CHARGE FROM HAMIRPUR END
223	220 Kv Sahnewal - Railway ckt-2	3.5	21-06-2020	23.26	22-06-2020	0.12	0.46	Zone1 &2, BRC,G-Trip,67A,67C	Not Trip	Due to heavy Storm
224	132kv Patti - Bhikhwind	19.37	21-06-2020	18.06	21-06-2020	19.46	1.14	Dir o/c E/F Master Trip 86 RB Phase 67N	*****	Due to Heavy wind storm
225	132kv Gurdaspur Dharial Ckt.1	16.00	21-06-2020	21.13	22-06-2020	8.40	11.27	Dir E/F Master Trip 86 DPR Razoa Operated	Breaker Not Tripped	Due to Heavy wind storm Tree Fall between tower No: 656 & 657
226	132kv Gurdaspur Dharial Ckt.2	16.00	21-06-2020	21.13	21-06-2020	23.40	2.27	Razoa TN Zon	Breaker Not Tripped	Due to Heavy wind storm Tree Fall between tower No: 656 & 657
227	132kv Batala Dharial Ckt 1	19.00	21-06-2020	22.20	22-06-2020	6.35	8.15	F Master Trip	Breaker Not Tripped	Due to Heavy wind storm
228	132kv Batala Dharial Ckt 1	19.00	21-06-2020	22.20	22-06-2020	6.35	8.16	DPR L1B Phase E/F Master Trip 86	Breaker Not Tripped	Due to Heavy wind storm
229	132 KV Muktsar-Sarainaga Line	12.73	21-06-2020	20.32	21-06-2020	22.50	1.18	RPh, O/C, E/F	RPh, O/C, E/F	Transient Fault
230	112 KV Muktsar Link	1.6	21-06-2020	0.46	21-06-2020	1.35	0.49	R & Y Ph, O/C, Z-3	R & Y Ph, O/C, Z-4	Transient Fault

212

231	132 KV Muktsar Link Ckt-2	1.6	21-06-2020	0.46	21-06-2020	1.14	0:28	E/F	-	Transient Fault , TAKE TRY AFTER CONSULT WITH SSE AND PC PATIALA
232	132 KV Kotkapura 1- Muktsar Line	28.4	21-06-2020	00:46	21-06-2020	01:57	1:11	OIC+E/F, R-Phase,Z-3,D=39.06 KM	.....	Transient Fault Take try with the permission of PC Patiala
233	132Kv BBMB JAL.- Dhiwan	37.00	21-06-20	20.57	21-06-20	21.31	00:34	Dpr,CN,Z-1,F1; Not Tripped 10.72Km	The disc Insulators of B phase at Tw no.37A were found flashed due to which line was tripped and same were replaced with new disc insulators.	
234	132Kv Focal point- Kartarpur	12.00	21-06-20	21.12	21-06-20	22.47	01:35	Dpr, BN,Z-1,F1-2.2km	Due to heavy storm and lightning.	
235	132Kv Pms-Science city	18.76	21-06-20	21.12	21-06-20	22.40	01:28	Not Tripped Dpr, B phase,Z-1,F1-8.4Km	The disc Insulators of B phase at Tw no.61 were found flashed due to which line was tripped and same were replaced with new disc insulators.	
236	132kv Wadala Granthian Sh. Hargibindpur Ckt.1	25.04	22-06-2020	4.43	22-06-2020	6.19	1.36	Razoa RTN Z6	132kv C/Bnk B Phase Conductor Fall on Bus Bar no. 2	
237	132kv Wadala Granthian Sh. Hargibindpur Ckt.2	25.04	22-06-2020	4.43	22-06-2020	6.20	1.37	DPR Razoa RSTN Zone 234	132kv C/Bnk B Phase Conductor Fall on Bus Bar no. 2	
238	132kv Wadala Granthian Batala ckt 1	7.00	22-06-2020	4.43	22-06-2020	6.12	1.29	E/F Master Tri	Numerical Relay L1 Master trip 86 Conductor Fall on Bus Bar no. 2	
239	132kv Wadala Granthian Batala ckt 2	8.00	22-06-2020	4.43	22-06-2020	6.13	1.30	E/F Master Tri	Numerical Relay L1 Master trip 86 Conductor Fall on Bus Bar no. 2	
240	132 KV Moga- Panjgrain Kalian	31.5	23-06-2020	01:34	23-06-2020	03:46	0:12	DPR RN-Φ Z1 11.465 KM	Breaker not Installed.	

213

241	132 KV Moga-Panigrain Kalan	31.5	23-06-2020	06:56	23-06-2020	08:40	1:44	DPR RN-Φ Z1 6.057 KM	Breaker not installed.	Transient Fault Line Charged on Msg of ACTL Muktsar.
242	132 KV Saralnaga-Moga Line	28.5	25-06-2020	10:05	25-06-2020	10:13	0:08	O/C+E/F, R Phase Z-1, D=41.26 KM	Line Is isolator controlled	Transient Fault Take try with the permission of SSE
243	132 KV Bilaspur-Sihora	13.494	25-06-2020	18.15	25-06-2020	18.45	0:30	E/F,O/C,Trip 86	Trip	Due to tripping of 11 kv Laesala feeder
244	132 KV Moga-Panigrain Kalan	31.5	26-06-2020	22:39	26-06-2020	22:44	0:05	DPR RN-Φ Z1 9.923 KM	Breaker not installed.	Transient Fault
245	132 kv Muktsar-Sarlana LIne	12.73	26-06-2020	12.02	26-06-2020	12.53	0:51	BPh, O/C, E/F KM	BPh, Z-1, 4.09 KM	Transient Fault
246	132kv Pathankot Kangra Ckt 2	89.00	28-06-2020	21.30	29-06-2020	10:05	12:35	F Master Trip	.....	Conductor Broken Due to Heavy wind storm
247	132kv Pathankot Sarna Ckt.1	7.00	28-06-2020	21.30	28-06-2020	21.50	0.20	Master Trip 86	.....	Conductor Broken Due to Heavy wind storm
248	132 KV NAKKIAN-NAWANSHAHAR CKT.NO.1	80.271	28-06-20	23.35	28-06-20	2.02	02:27	DPT RELAY TRIPPED	BREAKER NOT TRIPPED	132 KV BLUE PHASE LA OF 132 KV BUS BAR DAMAGED (DUE TO BAD WEATHER &HEAVY LIGHTNING, STORM & RAIN)
249	132 KV NAKKIAN-NAWANSHAHAR CKT.NO.2	57.997	28-06-20	23.35	28-06-20	2.03	02:28	RYB PHASE ZONE 1ST	BREAKER NOT TRIPPED	132 KV BLUE PHASE LA OF 132 KV BUS BAR DAMAGED (DUE TO BAD WEATHER &HEAVY LIGHTNING, STORM & RAIN)
250	132 KV NAVANSHAHAR-GORYA	32.000	28-06-20	23.25	28-06-20	1.55	02:30	B -PHASE ZONE 1ST	B -PHASE ZONE 1ST	132 KV BLUE PHASE LA OF 132 KV BUS BAR DAMAGED (DUE TO BAD WEATHER &HEAVY LIGHTNING, STORM & RAIN)
251	220 kv Bhan-Ganguwai	68.023	29-06-2020	0.17	29-06-2020	1.51	1.34	DPR,Main-2,Directional E/F,O/C,67/67 N	DPR,Main-1, REL 670 ,DPR , Main- 2, MR 3VG,38F,38A, PC- 1,PC-85,86	Temporary fault occurred due to flash over disc insulators.

214

252	220 KV G-2 -Ganguwali	74.000	29-06-2020	0.20	29-06-2020	21.18	20.58	DPR,R,YB-Phase,86	DPR,Main-2,ABC-Phase,Zone-2,E/F,86	Earth Breakdown between Tower No.-173 To 180
253	132kv Verka Kathunangal	15.50	29-06-2020	1.40	29-06-2020	1.55	0.15	C E/F Master 1	Breaker Not Tripped	Due to Heavy wind Storm
254	132kv Basala Kathunangal	22.00	29-06-2020	1.40	29-06-2020	2.25	0.46	L 1 Pick Up E/F pick up Zone 1	Breaker Not Tripped	Due to Heavy wind Storm
255	132kv Wadala Granthian Sh. Hargibindpur Ckt.1	25.04	29-06-2020	3.48	29-06-2020	4.52	1.04	O/C E/F	*****	Due to 132kv Bus Coupler R Phase CT Damage
256	132kv Wadala Granthian Sh. Hargibindpur Ckt.2	25.04	29-06-2020	3.48	29-06-2020	4.53	1.05	O/C E/F	*****	Due to 132kv Bus Coupler R Phase CT Damage
257	132Kv BBMB JAL,- Dhillwan	37.00	29-06-20	4.09	29-06-20	16.05	11.56	DPR,RN,Z-1,FI	Not Tripped	During heavy wind pressure a branch of Forest tree between tower span no.215-216 fall on line side due to which line was tripped and same was cleared.
258	132 KV Ghulat- Shamaspur- Seh	17.713	29-06-2020	0.17	29-06-2020	1.33	1.16	Directional E/F	Temporary fault occurred due to flash over disc insulators.	
259	132KV KOT KAROR LINE	18.6	30-06-2020	21:03	01-07-2020	19:25	22.22	O/C E/F B phase and Y Phase	O/C, E/F YB phase Highset TL between Tower No. 126 & 127 of Blue phase	
260	132 KV Sri Multsar Sahib-Sarnnaga Line	12.73	25-04-2020	7:20	25-04-2020	7:38	0:18	O/C+E/F,B- Phase	O/C+E/F,B- Phase, Z-1,D=5.961 KM	Transient Fault

Chief Engineer/P- & M.  
P.S.T.C.L., Ludhiana.

X

✓

✓

215

Detail of Tripping/Breakdown of Transmission lines affecting the power supply for the quarter ending Sep-2020.										
Sr.No	Name of Transmission Line/Transformer	Length of the line Km	Date	From	Date	To	Duration	Relay Indication	Cause of Tripping/breakdown	
1st End	2nd End									
1	132kV BBMB JAL-Dhiliwan	37.00	01-07-20	12:38	-01-07-20	13:02	00:24	Dpr, CN, Z-1,Fl-15.91km	The disc Insulators of B phase at Twp no.254 were found flashed due to which line was tripped and same were replaced with new disc insulators.	
2	132kV Mukatsar-Saranaga Line	12.73	7/2/2020	11:46	7/2/2020	12:33	0:47	YPh, O/C, E/F	Transient Fault	
3	132 KV GND TP-MES Cantt.	11.23	7/2/2020	20:54	7/3/2020	11:35	14:41	DPR BN-ph 2-2 FT1 Trip ABC	132 KV CT damaged at MES Cantt. end.	
4	132 KV Ferozshan-Kotkaror Line	18.6	7/2/2020	16:03	7/2/2020	16:06	00:03	O/C, E/F Blue	Transient Fault	
5	132kV Mahipuri-Banga Line	27.800	02-07-20	21:45	2/7/2020	22:05	00:20	NO INDICATION	(Flash over temporary fault & transient fault)	
6	132 KV Saranaga -Moga (KKP2)Line	28.5	7/3/2020	2:50	7/3/2020	3:05	0:15	O/C+E/F , B Phase, Z-1,D=18.79 Km	Breaker NOT TRIPPED Isolator controlled at 132 kv KKP-2 end	
7	220kV Wadala Granthian-Kotli Surat Malhi	29.670	7/4/2020	20:01	4.7.20	21:50	01:49	Main-1 185A, 186B Any trip Zone-1&2	Breaker No Tripped Due to Heavy wind Storm and rain	
8	220kV Fatehgarh Chunian -Kotli Surat Malhi	22.000	7/4/2020	20:01	4.7.20	22:05	02:05	Main-1 Trip	Breaker No Tripped Due to Heavy wind Storm and rain	
9	132kV Verka-Pakharpura	20.000	7/4/2020	19:40	4.7.20	20:10	00:30	Dir, O/C E/F 86 67N	Breaker not tripped Due To Heavy wind Storm and rain	
10	132KV Kathunangal-Verka	15.500	7/4/2020	19:45	4.7.20	21:25	01:40	O/C, E/F B Phase	Directional O/C E/F, 67 N. Master Trip Directional O/C E/F, 67 rain	
11	220 KV Sandhwan-Shri Muktsar Sahib Line	3.8	7/4/2020	22:27	7/4/2020	23:00	0:33	DPR Main -I&II, ZONE - I, Starting phase CN, tripped phase C, fault location 379.2 mtr	Due to storm & heavy flow of wind Try was taken after concerning with SSE.	
12	220 KV Sadiq-Ferozepur Line	37.70	7/4/2020	21:53	7/4/2020	23:01	01:08	DPR Main operated, Fault Location 38.1 km, carrier received auto-reclose blocked: Main-II, BN Phase, Zone-II location 45.20 km	No tripping Due to bad weather conditions, Line energized after clearance certificate given by AO TL Mastewal.	
13	220 KV Sadiq-Moga Line	70.5	7/4/2020	21:55	7/5/2020	19:15	21:20	O/C Y-Phase, DPR Zone-1	Due to breakdown of conductor from Y-Phase Wave Trap	
14	132 KV Saranaga -Moga (KKP2)Line	28.5	7/4/2020	20:35	7/4/2020	20:45	0:10	O/C+E/F , R Phase, Z-1,D=25.09 Km	Transient Fault	

276

15	132 KV Sarainaga -Moga (KKP2)Line	28.5	7/4/2020	22:20	7/4/2020	22:35	0:15	O/C+E/F , R Phase,Z- 1,D=24.90 Km	Transient Fault
16	132 KV Moga- Panigrain Kalan	31.5	04-07-2020	18:51	04-07-2020	19:01	0:17	DPR BN-Φ Z-1	Breaker not installed.
17	132 KV Moga- Panigrain Kalan	31.5	04-07-2020	20:53	04-07-2020	21:52	0:28	DPR BN-Φ Z-1	Breaker not installed.
18	132 KV Moga- Sosan	19.5	04-07-2020	20:54	04-07-2020	21:53	0:59	DPR YN-Φ Z2	ON
19	132 KV Sosan-Kolkaror Line	8.2	04-07-2020	20:52	05-07-2020	10:29	13:37	O/C+E/F & DPR B- Φ	Heavy Storm & Bad weather
20	220 kv Amlech -G-1	10.000	7/4/2020	22:56	4/7/2020	23:23	0:27	O/C, E/F	Earth Brakedown between Tower No. 94 & 95,Heavy Storm & Bad weather.
21	220 kv Amlech -Malerkolla	43.000	7/4/2020	22:56	4/7/2020	23:51	0:55	O/C, E/F	Due to 66 kv Bhadso & Vimal Alloy Line
22	220 kv Ajitwai-PGCIL Moga	21.700	7/4/2020	21:20	5/7/2020	14:10	16:50	Zone-C,R-Phase	Due to 66 kv Bhadso & Vimal Alloy Line
23	132 Kv Moga-Sosan line	19.532	7/4/2020	22:52	05-07-2020	13:36	14:44	Y-ph O/C+E/F	Temporary fault occurred due to flash over disc insulators.
24	132Kv Khera mandir-Sullanapur	12.00	04-07-20	20:20,	04-07-20	22:30	0:10	Not tripped.	Y-Phase jumper broken at Tower no. 54 due to heavy storm and and weather
									The disc insulators of Y phase at Tw no. 42 were found flashed due to which line was tripped and same were replaced with new disc insulators.
25	132Kv Kapurthal-B-RCF	8.00	04-07-20	20:30	04-07-20	23:20	0:50	Dpr, YN	Breaker tripped.
26	132KV MPH2-Tanda Line	50.000	04-07-20	20:22	5/7/2020	12:45	15:23	BREAKER NOT TRIPPED	R-phase jumper breakdown at tower no 7/11
27	132KV Tanda-Bhogpur Line	26.000	04-07-20	20:22	4/7/2020	22:01	01:39	BREAKER NOT TRIPPED	RYB-Phase.
28	132 KV BHOGPUR- HOSHJARIPUR	27.087	04-07-20	23.20	04/07/2020	0:30	0:10	BREAKER NOT TRIPPED	Y-PHASE 132 KV PT BUS BAR DAMAGED AT 132 KV BHOGPUR END
29	220kV Patran Banwala Ckt-1	39.20	7/4/2020	5:09	04-07-2020	8:15	0:06	RYB Phase O/C, Zone-4, R-10.86, B- 7.85,C-10.68, SOFT	Not tripped
30	220kV Patran Banwala Ckt-2 A4	39.20	7/4/2020	5:09	04-07-2020	8:16	0:07	RYB Phase,Zone- 1, Dist. 24.24Mr., R-10.711, B-8.85,C- 10.44, SOFT	O/C(RYB)Phase,R- 11.28KAMP,Y- 11.21KAMP,B- 1.91KAMP,Distance: 32. 3km
31	220 KV Patran-Sunam	35.60	7/4/2020	5:09	04-07-2020	6:09	0:100	O/C(RYB)Phase,zo	No indication No Trip

2/17

32	220kV Patran-BANGA	16.30	7/4/2020	5:09	04.07.2020	6:05	00:56	O/C(RYB)Phase,20 ne-4,R- 3.84Kamp,Y- 702.Amp,8-63Amp	No indication No Trip	Due to L & E switch of 220kv Patran-banwala Ckt-2 comes in induction zone because of strong wind
33	132 KV Sarainaga -Moga (KKP2)Line	28.5	7/5/2020	3:25	7/5/2020	7:32	04:07	O/C+EF , R Phase, D=25.25 Km	Transient Fault	
34	132 KV Moga -Gholian Kalan	15	05-07-2020	2:41	05-07-2020	3:17	0:11	DPR RN-Φ 21 6.0 KM	Transient Fault	
35	132 KV Moga -Gholian Kalan	15	05-07-2020	18.06	05-07-2020	18.25	0:12	DPR YB-Φ Z2 14.9 KM	B-Phase Jumper of LILO Tower No.03 Near Ghola. S/S is damaged.	
36	132 KV Gholian-Smadrh Bhai	5.6	05-07-2020	18.06	05-07-2020	18.30	00:24	E/F	Breaker not installed.	B-Phase Jumper of Moga-Gholia LILO Tower No.03 Near Ghola S/S is damaged.
37	132 KV Gholian-Smadrh Bhai	5.8	05-07-2020	18.53	05-07-2020	19:03	00:10	E/F	Breaker not installed.	B-Phase Jumper of Moga-Gholia LILO Tower No.03 Near Ghola S/S is damaged.
38	132 KV Sarainaga -Moga (KKP2)Line	28.5	7/6/2020	18.56	7/6/2020	19:03	00:07	O/C+EF , R Phase,Z- 1,D=16.92 Km	Transient Fault	
39	132 KV Malout-Abchar	29.6	7/6/2020	11:03	7/6/2020	11:13	0:10	E/F R PH, Z-1, 13.35 KM	Breaker not available	
40	132 KV Moga- Panigrain Kalan	31.5	06-07-2020	4:37	06-07-2020	4:50	0:37	DPR BN-Φ Z-1 26.749 KM	Breaker not installed.	Transient Fault
41	132 KV Moga- Panigrain Kalan	31.5	07-07-2020	3:03	07-07-2020	3:13	00:08	DPR RN-Φ Z-1 20529 KM	Breaker not installed.	Transient Fault
42	132 KV Swadhi -Moga	42.000	7/7/2020	0.44	7.7.2020	12.08	11:25	RYB- Phase, E/F , Protection Operate,85 Trip R-Phase,E/F , Zone-1, 1.7 km	RYB- Phase, E/F , OIC,36.3 km	Temporary fault occurred due to flash over disc insulators.
43	132 KV Swadhi -Jamalpur	38.000	7/7/2020	0.44	7.7.2020	1:14	00:30	R-Phase,E/F , Zone-1, 1.7 km	R-Phase, Zone-2	Temporary fault occurred due to flash over disc insulators.
44	132 KV Pathankot -Mammon	6.000	7/10/2020	18.13	10.7.20	18.37	00:24	RY PHASE Z-1	Bkr. not tripped and no indication.	TREE FELL ON 132 KV PATHANKOT SARNA CKT NO- 1,BETWEEN THE TOWER NO 511 & 512
45	132 KV PATHANKOT KANGRA CKT NO-2	89.000	7/10/2020	18.13	10.7.20	18.37	00:24	RY PHASE Z-1	Bkr. not tripped and no indication.	PATHANKOT SARNA CKT NO- 1,BETWEEN THE TOWER NO 511 & 512
46	132KV Pathankot -Sarna	7.000	7/10/2020	18.13	11.7.20	7.35	13:22	RYB PHASE, DPR trip 86	RYB PHASE Master ZONE-1,86 Relay	Due to Tree Fall on Between Tower No. 510 -511
47	132Kv Pims-Science city	18.756,	10-07-20	20.25	10.07.20	21.20,	00:55	Not tripped	Dpr.BN Z-2,FI-18.9km	Due to heavy storm and lightning.
48	220kV Kotli Surat Malhi-Wadala Granthian	29.670	7/11/2020	23.52	12.7.20	9.27	05:35	Main 1 Any Trip ABC 186A 186B Zone 2 Main 2 RYB Phase SOFT Operated Zone 2	286A,286B,67N, E/F	Due to 220kv Kotli Surat Malhi Isolator Disc Break

218

49	220kV Fatehgarh Chunian -Kotli Surat Malhi	22.000	7/11/2020	23.57	12.7.20	1.57	02:00	Distance protection Operated Star trip	Breaker No Tripped	Due to Heavy wind Storm and rain
50	220kV Algon Kotli-Patti Ckt-1	20.500	7/11/2020	23.18	12.7.20	0.08	00:50	Zone-1 Red Phase	Breaker No Tripped	Due to Heavy wind Storm and rain
51	220kV Algon Kotli-Patti Ckt-2	20.500	7/11/2020	23.18	12.7.20	0.05	00:47	86	Breaker No Tripped	Due to Heavy wind Storm and rain
52	132kV Verka-Kainuanagai	15.500	7/11/2020	23.36	12.7.20	2.06	02:41	Dir, O/C, E/F M/T	Breaker not tripped	Due to Heavy wind Storm and rain
53	132kV Batala-Kathunangai	22.000	7/11/2020	23.52	12.7.20	2.10	02:18	DPR L2 Pickup E/F Pick upne 2	Breaker not tripped	Due to Heavy wind Storm and rain
54	132kV Batala-Wadala Granthian Ckt-3	8.000	7/11/2020	23.52	12.7.20	1.51	01:59	Dir, O/C, E/F M/T L2 Pickup E/F pickup	Breaker not tripped	Due to Heavy wind Storm and rain
55	132kV Batala-Wadala Granthian Ckt-2	7.000	7/11/2020	23.55	12.7.20	1.49	01:54	Dir, O/C, E/F L-2 Pickup E/F pickup	Breaker not tripped	Due to Heavy wind Storm and rain
56	132 kV Doraha-Bilaspur -Sihora	23.000	7/11/2020	8.22	11.7.2020	10.10	01:48	DPR,Razza,Zone-1&3		Temporary fault occurred due to flash over disc insulators.
57	132 KV Sarainaga -Moga (KKP2)Line	28.5	7/12/2020	0:35	7/12/2020	0:50	0:15	O/C+E/F, R Phase,Z-1,D=25.16 Km		Transient Fault
58	132 KV Sarainaga -Moga (KKP2)Line	28.5	7/12/2020	21:15	7/12/2020	21:22	0:07	O/C+E/F B PHASE,Z1, DPR D=18.75KM		Transient Fault
59	132 KV Sosan-Kotkaror Line	8.2	12-07-2020	23:59	13-07-2020	0:56	0:057	DPR B-Φ Z-1.4.6 KM		Transient Fault
60	132 KV Sosan-Moga Line	19.5	12-07-2020	23:59	13-07-2020	0:20	0:21	DPR B-Φ O/C+E/F ON		Due to 132 kV Sosan Kotkaror Line
61	132 KV Multksar-Jalalabad Line	33	7/13/2020	5.22	7/13/2020	5.39	0.17	O/C+E/F RN Phase,Z-1:D=0.3 KM		Transient Fault try taken after concerned with SSE
62	132 KV Gidderbaba-Ballana	19	7/13/2020	2:32	7/13/2020	2:40	0:08	dpr z1 AN 16.9km 77% rph=6.546ka,yph=152.9 a,bph=166.8a	pdpl ckt2	Due to pdpl ckt2 trip
63	132 KV Swachhi -Jamalpur	38.000	7/13/2020	5.01	13.7.2020	5.23	0:22	Not Trip	Trip MCOM,ABF ,Zone-1,28km	Temporary fault occurred due to flash over disc insulators.
64	132 kV Mahilpur-Hoshiarpur ckt-1	25.002	15-07-20	16.55	16/7//2020	17.45	24:05	O/C R-Phase, Zone-2,	BREAKER NOT TRIPPED	Due to 132/11 KV 12.5/16 MVAP-T/F T1 damage at Hoshiarpur end
65	132 kV Mahilpur-Hoshiarpur ckt-2	25.500	15-07-20	16.55	16/7//2020	17.46	24:05	O/C R-Phase, Zone-2,	BREAKER NOT TRIPPED	Due to 132/11 KV 12.5/16 MVAP-T/F T1 damage at Hoshiarpur end
66	132kV Bhogpur-Hoshiarpur Line	27.087	15-07-20	16.55	15/7//2020	23:24	06:29	R-Phase, Zone-2,	BREAKER NOT TRIPPED	Due to 132/11 KV 12.5/16 MVAP-T/F T1 damage at Hoshiarpur end
67	132 kv Ghulsi-Doraha	14.000	7/16/2020	17.47	16.7.2020	18.27	00:40	DPR,C-Phase, E/F Z-1,SSBR3V	Not Trip	Temporary fault occurred due to flash over disc insulators.
68	132 kv Ghulsi-Samsapur-Sehe	17.713	7/16/2020	17.47	16.7.2020	18.15	00:28	E/F,O/C,B-Phase	-	Temporary fault occurred due to flash over disc insulators.

210

69	132kV Mukatsar -Kotkapura-1 Line	28.4	7/17/2020	23.07	7/17/2020	23.13	00:06	YPh, O/C, E/F	E/F	Transient Fault
70	132 KV Kotkapura-Moga Line	34.6	7/17/2020	23.07	7/17/2020	23:28	0:21	O/C+E/F, Y Phase	O/C+E/F, Y Phase,Z- 1,D=36.7 KM	Transient Fault
71	132 KV Sarainaga-Muktsar Line	12.73	7/17/2020	23.48	7/17/2020	23:58	0:10	O/C+E/F, B- O/C+E/F, B Phase	O/C+E/F, B- Phase,z-1,D=3.141 KM	Transient Fault
72	132 KV Moga- Panjgrain Kalan	31.5	17-07-2020	7:42	17-07-2020	7:53	0:11	DPR Y-Φ Z-1	DPR Y-Φ Z-1	Breaker not installed.
73	132 KV Kotkaror-Ferozeshah Line	18.6	7/17/2020	23.44	7/18/2020	0:14	00:30	O/C RYB Phase Highset	O/C B-Phase	Due to bad weather conditions; Try taken with permission of PC Patiala and AO TL 400 kV Mastewal
74	132 KV Ferozepur - Manna Singh Wala	11.6	7/17/2020	23.45	18.07.2020	0:05	00:20	O/c E/F, B-ph location 14.5 Km	O/c E/F	Due to bad Weather and Heavy Storm
75	132kV Mukatsar -Kotkapura-1 Line	28.4	7/18/2020	1:21	7/18/2020	1:39	0:18	YPh, O/C, E/F	E/F	Transient Fault
76	132 KV Kotkapura-Moga Line	34.6	7/18/2020	1:21	7/18/2020	12:45	11:24	O/C+E/F, Y Phase,Z- 1,D=38.7 KM	O/C+E/F, Y Phase,Z- 1,D=38.7 KM	Transient Fault , so try taken after clearance certificate given by AOTL
77	132 KV Sarainaga -Moga (KKP2)Line	28.5	7/18/2020	4:03	7/18/2020	4:11	00:08	O/C+E/F B Phase,Z- 1,D=43.85 KM	O/C+E/F B Phase,Z- 1,D=43.85 KM	Transient Fault
78	220 KV Sandhwan-Shri Muktsar Sahib Line	38	7/19/2020	18:50	7/19/2020	19:32	0:42	DPR Main-II, ZONE-I, Starting phase CN, tripped phase C,fault location 330.7 mtr	B-phase Zone-4 Main-II Prot. Optd.	due to storm & heavy flow of wind. Try was taken after concerning with SSE.
79	132 KV Sarainaga - Moga (KKP2)Line	28.5	7/19/2020	18:48	7/19/2020	18:58	0:10	O/C+E/F R Phase,Z- 1,D=25.47 KM	Line is isolator controlled	Transient Fault
80	132 KV Sarainaga -Moga (KKP2)Line	28.5	7/19/2020	19:05	7/19/2020	19:20	0:15	O/C+E/F R Phase,Z- 1,D=25.40 KM	Line is isolator controlled	Transient Fault
81	132 KV IGC- GNDTP Bathinda	16.76	7/19/2020	19:40	7/20/2020	13:40	18:0	No tripping	DPR B-Ph, 1, L=5.7 KM	A Tree fell on line near Govt. Polytechnic College Bathinda.
82	132 KV Moga- Panjgrain Kalan	31.5	18-07-2020	17:46	19-07-2020	17:58	00:08	DPR R-Φ Z-1, 6.109 KM	DPR R-Φ Z-1, 6.109 KM	Breaker not installed.
83	132 KV Moga- Panjgrain Kalan	31.5	19-07-2020	20:29	19-07-2020	20:46	9:46	DPR Y-Φ Z-1	DPR Y-Φ Z-1	Bad weather
84	132 kv Ghula-Samaspur-Sehe	17.713	7/19/2020	10:45	19.7.2020	11.01	00:16	Directional E/F,B- Phase	Directional E/F,B- Phase	Due to heavy storm & Rain
85	132kV Verpal-TarnTaran	14.480	7/20/2020	3:13	20.7.20	3:37	00:24	Blue Phase O/C, E/F	IDMT 86	Due to Heavy Wind Storm and rain
86	132kv Verpal Hakima Gate Ckt.1	9.540	7/20/2020	23.45	21.7.20	0:25	00:40	E/F High Set	E/F High Set	Due to Branch of Tree Fall on line
87	132kv Verpal Hakima Gate Ckt.2	9.940	7/20/2020	23.45	21.7.20	6:50	07:05	O/C Y Phase High Set	DPR Y phase E/F Set	Due to Branch of Tree Fall on line

220

88	220 KV Sadig-Ferozepur Line	37.70	7/20/2020	5:07	7/20/2020	15:48	10:41	Main-I YB[Phase Zone-I, Location 17 km; Main-II RYB-phase, Zone-II, Location 18.08 km	No tripping	Due to bad weather conditions; Line energized after clearance certificate given by AO TL Mastewal.
89	220 KV Sadig-Kotkaror	37.4	7/20/2020	5:08	7/20/2020	15:43	10:36	Main-I, Main-II, Location 436 m	Main-I, Main-II, Zone-I, Location 21.68 Km	Due to bad weather conditions; Line energized after clearance certificate given by AO TL Mastewal.
90	220 KV Sadig-Muktisar	40.50	7/20/2020	5:08	7/20/2020	6:25	1:17	Main-I, Main-II, Zone-II, Location 51.8 km	"	Due to bad weather conditions
91	132 KV Kotkapura-Moga Line	34.6	7/20/2020	18:34	7/20/2020	20:28	0:54	O/C+E/F B Phase, Z- Phase, Z- 1,D=14.8 KM	O/C+E/F B Phase, Z- 1,D=25.92 KM	Transient Fault
92	132 KV Sarainaga -Moga (KKP2)Line	28.5	7/20/2020	5:25	7/20/2020	5:45	0:20	O/C+E/F R Phase,Z- 1,D=25.80 KM	Line is isolator controlled	Transient Fault
93	132 KV Sarainaga -Moga (KKP2)Line	28.5	7/20/2020	14:11	7/20/2020	14:19	0:08	O/C+E/F B Phase, Z-1,D=9.61 KM	Line is isolator controlled	Transient Fault
94	132 KV Sarainaga -Moga (KKP2)Line	28.5	7/20/2020	19:16	7/20/2020	19:48	0:32	O/C+E/F BR Phase,Z- 1,D=25.34 KM	Line is isolator controlled	STORM AND HEAVY RAIN
95	132 KV Moga- Panjgrain Kalan	31.5	20-07-2020	4:22	20-07-2020	4:50	0:40	DPR R-Φ Z1 5.775 KM	Breaker not installed.	Transient Fault
96	132 KV Moga- Panjgrain Kalan	31.5	20-07-2020	19:50	20-07-2020	20:27	0:23	DPR Y-Φ Z1 11.385 KM	Breaker not installed.	Transient Fault
97	132 KV Kotkaror-Ferozesmeh Line	18.6	7/20/2020	5:05	7/20/2020	11:35	0:30	RY Phase Highset trip	O/C RY-Phase Master trip	Due to bad weather conditions; Line energized after clearance certificate given by AO TL Mastewal.
98	132 KV Ferozepur - Manna Singh Wala	11.6	7/20/2020	5:02	20-07-2020	5:28	0:26	O/C Highest RYN Ph location 13.9 KM	O/C E/f	Due to bad Weather and Heavy Storm
99	132 KV Ferozshah-Manna Singh Wala Line	10	7/20/2020	5:05	20-07-2020	6:53	0:148	O/C RY ph Master trip	RY Ph Zone 1 loc. 3.3 Km	Due to bad Weather and Heavy Storm
100	132Kv Khera mandir-Sulttanpur	12.00	20-07-20	3.40	20-07-20	15:45	12:05	Not tripped	Dpr, R phase,Z-2,Fl-9.8 km	The disc insulators of Y phase at Tw no.46 and R phase at Tw no.48 were found flashed due to which line was tripped and same were replaced with new disc insulators.
101	132kv Verka -Pakharpura	20.000	7/21/2020	18.10	21.720	18.30	0:20	Dir O/C E/F	Breaker not tripped	Due to Heavy Jerk 132Kv Wadala Granthian Batala Ckt No.2

221

102	132kV Wadala Granthian -Batala Ckt.3	8.000	7/21/2020	18.10	21.7.20	18.34	00:24	DPR Raza RS Zone-2	Breaker not tripped	Due to Heavy Jerk 132Kv Wadala Granthian Batala Ckt No.2
103	132kV Batala Wadala Granthian Ckt.2	7.000	7/21/2020	18.10	21.7.20	18.35	00:25	DPR L-2 Pickup E/F Pickup Master Trip 86	DPR L1 pick up E/F Pick up	Due to Heavy Jerk 132Kv Wadala Granthian Batala Ckt No.2
104	132kV Batala Pakharipura	17.600	7/21/2020	18.10	21.7.20	20.40	02:30	DPR L-2 Pickup E/F Pickup Master Trip 86	Breaker not tripped	Due to Heavy Jerk 132Kv Wadala Granthian Batala Ckt No.2
105	132 KV Serainga -Moga (KKP2)Line	28.5	7/21/2020	17.11	7/21/2020	17.21	0:10	O/C+E/F B Phase,Z- 1.D=43.77 KM	Line is isolator controlled	Transient Fault
106	220 KV Sadig-Kotkaror	37.4	7/22/2020	0.25	7/22/2020	1.46	1:21	Master Trip	High Speed Master Relay & B Phase O/C	Transient Fault
107	220 KV Sadig-Muktasar	40.50	7/22/2020	0.25	7/22/2020	1.05	0:40	Master Trip	No tripping	Transient Fault
108	220 KV Sadig-Ferozepur	37.7	7/22/2020	0.25	7/22/2020	1.02	0:37	Master Trip	O/C E/F Backup Protection E/F	Transient Fault
109	132 KV Muktsar-Jalalabad Line	33	7/22/2020	4.58	7/22/2020	5.05	00:07	O/C+E/F B Phase,2-1,D=12.7 KM	Line is isolator controlled	Transient Fault try taken after concerned with SSE
110	132 KV Serainga -Moga (KKP2)Line	28.5	7/22/2020	6.23	7/22/2020	11.50	5:27	O/C+E/F B Phase,Z- 1.D=46.87 KM	Line is isolator controlled	Transient Fault
111	132 KV Moga- Panigrain Kalan	31.5	22-07-2020	5:18	22-07-2020	5:26	00:08	DPR BN-Φ Z1	Breaker not installed.	Transient Fault.
112	132 KV Goraya-Phillaur	12 KM	23-07-20	9:51	7/23/2020	10:25	00:34	R ph. E/F, Master trip	No indication on Phillaur end	Tripped alongwith tripping of 132KV Phillaur-Jamalpur ckt. (PC pikAWly dIAW hdwiegqW Anuswrt cwIu kIowI)
113	132 KV Phillaur-Jamalpur	17 KM	23-07-20	9:51	7/26/2020	22:08	82:17	DPR RN ZONE-1,LOC-16.48 KM,R 1.1.OC-2.3 KM Phase E/F	DPR R Phase ZONE-1,LOC-16.48 KM,R 1.1.OC-2.3 KM Phase E/F	Conductor breakdown between tower no - 8 & 9
114	132KV Batala-Kathunangal	22.000	7/24/2020	14.23	24.7.20	14.41	00:18	DPR L-1 Pickup Zone-1,86	Red Phase Zone-1 86	Due to construction of new building near batala end And come in contact with induction Zone
115	132KV Batala-Kathunangal	22.000	7/24/2020	14.55	24.7.20	18.18	03:23	DPR Red Phase Zone-1	Red Phase Zone-1 86	Due to construction of new building near batala end And come in contact with induction Zone
116	132KV verka-Kathuanagal	15.500	7/24/2020	14.23	24.7.20	14.48	00:25	Dir, O/C E/F 86	Breaker Not Tripped	Due to construction of new building near batala end And come in contact with induction Zone
117	132KV verka-Kathuanagal	15.500	7/24/2020	14.55	24.7.20	15.15	00:20	Master Trip 86	Breaker Not Tripped	Due to construction of new building near batala end And come in contact with induction Zone
118	132 KV Moga- Panigrain Kalan	31.5	24-07-2020	20.52	24-07-2020	21:03	00:11	DPR RN-Φ Z1 6.067 KM	Breaker not installed.	Transient Fault

222

119	132 kv Dohra-Bilaspur-Sihora	23.000	7/25/2020	19.10	25.7.2020	19.45	00:35	DPR Razia E/F B-Phase, Zone-2&3	Directional O/C,E/F	Temporary fault occurred due to flash over disc insulators.
120	132 KV GNIDTP- MES Cantt.	11.23	7/26/2020	5.06	7/26/2020	5:28	0:22	DPR CN-ph Z-1 L=3.1 KM Trip ABC	NA	De-capping of porcelain disc insulators was observed on 27.07.2020 which was attended by Hot Line Team Ludhiana on 28.07.2020 Transient Fault
121	132 KV Moga- Panigrain Kalan	31.5	26-07-2020	0:40	26-07-2020	0:48	00:08	DPR RN-Φ Z1 5.885 KM	Breaker not installed.	Transient Fault as Patrolling Between Tower No. 247 To 375 by AOTL Muktsar. No Fault Found, Line Charged on MSG of AOTL Muktsar.
122	132 KV Moga- Panigrain Kalan	31.5	26-07-2020	3:31	26-07-2020	13:17	09:46	DPR RN-Φ Z1 6.087 KM	Breaker not installed.	Transient Fault as Patrolling Between Tower No. 247 To 375 by AOTL Muktsar. No Fault Found, Line Charged on MSG of AOTL Muktsar.
123	132 KV Saranaga -Moga (KKP2)Line	26.5	7/27/2020	0:50	7/27/2020	0:56	00:06	O/C+E/F B Phase,Z-1,D=21.73 KM	Line is isolator controlled	Transient Fault
124	132 KV Saranaga -Moga (KKP2)Line	28.5	7/27/2020	23:20	7/27/2020	23:29	00:09	O/C+E/F B Phase,Z-1,D=9.34 KM	Line is isolator controlled	Transient Fault
125	132 KV Swadhi-Moga	42.000	7/27/2020	5.33	21.7.2020	7.03	01:30	Not Trip	AN-Phase, Zone-1,39.5 km	Temporary fault occurred due to flash over disc insulators.
126	132 KV Swadhi -Jamalpur	38.000	7/27/2020	5.33	27.7.2020	10.57	05:24	L-1,R-Phase,E/F,Zone-1,6.8km	R-Phase,Zone-1	Temporary fault occurred due to flash over disc insulators.
127	132KV Tarni-Taran-Verpal	14.480	7/28/2020	14.50	28.7.20	15.20	00:30	E/F, DM7-B6	E/F, Highset	Due to Some Transient Fault In line
128	132KV Verka-Pakharpura	20.000	7/28/2020	17.40	28.7.20	17.55	00:15	Dir, O/C, E/F, Master Trip	Breaker not tripped	Due to Some Transient Fault In line
129	132KV Verka-Kathurangal	15.500	7/28/2020	17.40	28.7.20	17.56	00:16	Dir, O/C, E/F, Master Trip	Breaker not tripped	Due to Some Transient Fault In line
130	132KV Verka-Power Colony	2.500	7/28/2020	17.40	28.7.20	19.10	01:30	Master Trip 86	Breaker not tripped	Due to Some Transient Fault In line
131	132KV Verpat-Mall Mandi	11.650	7/28/2020	14.52	28.7.20	15.20	00:28	E/F, Highset	Breaker not tripped	Due to Some Transient Fault In line
132	132KV Civiline-Power Colony	2.600	7/29/2020	12.50	29.7.20	13.47	00:57	Dir, O/C E/F 86	Breaker not tripped	Due to Some Transient Fault In line
133	132 KV Saranaga -Moga (KKP2)Line	28.5	7/29/2020	22:23	7/29/2020	22.31	00:08	O/C+E/F Y Phase,Z-1,D=22.38 KM	Line is isolator controlled	Transient Fault
134	132 KV Ferozpur-Fairidkot Line	41	7/29/2020	9:08	7/29/2020	9:48	00:40	BN Phase Zone-I, Location 7.8 km	NA, Isolator Control	Transient Fault Try taken by taking permission from PC Pailala
135	132 KV Moga-Dhalleke	19	7/29/2020	21:28	30.07.2020	18:25	20:57	DPR Y-ph 16.3 KM	Breaker not installed.	Conductor breakdown between Tower span no. 42-43 and Earth wire breakdown between Tower No. 42-43 and 46-47 due to heavy storm.

223

136	132Kv Kartarpur-Beas	27.00	29-07-20	21.32	29-07-20	22.53	01-21 9.7km	Dpr,BN Z-1,Fl-	Not tripped	The disc Insulators of B and R phase at Tw no. B7 were found flashed due to which line was tripped and same were replaced with new disc insulators.
137	132 KV Ferozpur-Faridkot Line	41	7/31/2020	11:17	7/31/2020	11:40	00:23 RN Phase Zone-2, Location 38.6 km	NA, Isolator Control	Transient Fault	Try taken by taking permission from PC, Patiala
138	132 KV Doraha-Bilaspur -Sihora	23,000	7/31/2020	20.20	31.7/2020	21.35	01:15 Low Oil Level	E/F Master Trip 86	Breaker not Tripped	Low Oil Level of SF-6 Gas
139	132kv TarnTaran-Verpal	14,480	8/1/2020	11.56	1.8,20	12.10	00:15 KM	DPR RN-Φ Z2 10.5 ON	Due to some transient fault	
140	220 KV Moga-Baghapurana Ckt-1	10	01-08-2020	10.38	01-08-2020	20.08	9.30 KM	DPR RN-Φ Z2 10.5 ON	Due to 220 KV/Moga- Baghapurana Ckt-2 BIID near Village Gill	
141	220 KV Moga-Baghapurana Ckt-2	10	01-08-2020	10.38	05-08-2020	21:22	10644 KM	DPR RN-Φ Z2 Dir O/C+E/F		
142	220 KV Baghapurana- Bajakhana Ckt-1	34.5	01-08-2020	10.38	01-08-2020	11:54	1:16 Main 1 & Main2, Master Trip DPR R-Φ Z1 251.4 KM	ON	Due to 220 KV/Moga- Baghapurana Ckt-2 on both ends	
143	220 KV Baghapurana- Bajakhana Ckt-2	34.5	01-08-2020	10.38	01-08-2020	11:40	1:02 Main 1 & Main2, Master Trip DPR R-Φ Z1 1.652 KM	Ph-AN, Main-1, Zone- none, Location None	Breakdown of Baghapurana- Moga Ckt-2 at Baghapurana end.	
144	132 KV Mukatsar-Malout Line	32.5	8/1/2020	7.55	8/1/2020	8.05	0:10 RN-ph-E/F,Z-2, 27.7 KM	RPh, O/C, E/F, Z-1, 1.07 KM	Transient Fault:	
145	132 KV Sarainaga -Moga { KKP2}Line	28.5	8/1/2020	23.21	8/1/2020	23.26	0:05 B PHASE 9.381KM ia68.42A, 147.8A,ic3.288A,	Line is isolator controlled	Transient Fault:	
146	220 KV Moga-Baghapurana Ckt-1	10	01-08-2020	10.38	01-08-2020	20.08	09:30 KM	DPR RN-Φ Z2 10.5 ON	Due to 220 KV Moga- Baghapurana Ckt-2	
147	220 KV Bagha purana-Bajakhana Ckt-1	34.5	01-08-2020	10.38	01-08-2020	11:54	01:16 Main 1 & Main2, Master Trip DPR R-Φ Z1 251.4 KM	ON	Due to 220 KV Moga- Baghapurana Ckt-2 on both ends	
148	132 KV Doraha-Bilaspur	9,506	8/1/2020	16.25	1.8/2020	18.43	00:18 Razoa TN Z-2 & 3	-	Temporary fault occurred due to flashover Disc insulators	
149	132 KV Bilaspur -Sihora	13,494	8/1/2020	18.25	1.8/2020	18.55	00:30 86	Directional E/F O/C -	Temporary fault occurred due to flashover Disc insulators	
150	132 KV Sarainaga -Moga { KKP2}Line	28.5	8/2/2020	1.12	8/2/2020	1.21	0.09 Z1 ia68.47A,ib140, 9A,ic3.353 KA	B PHASE DPR Line is isolator controlled	Transient Fault:	
151	132 KV Sarainaga -Moga { KKP2}Line	28.5	8/2/2020	2.44	8/2/2020	11.02	8:18 Z1,ia62.17A,ib144, 1A,ic3.353KA	Line is isolator controlled	Transient Fault:	
152	132 KV Moga-Gholian Kalan	16.2	02-08-2020	23.54	03-08-2020	0.11	00:17 KM	DPR R-Φ Z1 6.1 ON	Temporary fault occurred due to flashover Disc insulators	

2nd

153	220 KV Baghapurana-Moga Ckt-1	10	03-08-2020	21:40	08-08-2020	11:45	11:05	Backup O/C+E/F operated	ON	1) Line already energised from 220 KV S/S Moga with NO Load. Due to overloading condition on Single Ckt. Moga-Baghapurana Ckt-02, load is not loaded. 2) On dated:07-08-2020, Time:17:50 Hrs. when Ckt-1 is switched ON (After loaded on Moga-Baghapurana Ckt-02) R-Phase Current was Zero & Double on Ckt-2, seems any R-Phase jumper is damaged, message delivered to AEE/TL. 3) After attending fault on bay at 220 KV S/S Moga (Singhawala), Ckt-1 is loaded on Dated:08-08-2020. Time:11:45.
154	220 KV Badini - PGCIL Moga	26.219	03-08-2020	11:15	3.8.2020	18:34	07:19	Auto Redclose,ckt-1 Trip Faulty,Zone-1 BN-Phase,18.59 km	Trip	Temporary fault occurred due to flash over disc insulators.
155	132 KV Moga- Panigrain Kalan	31.5	05-08-2020	3:30	05-08-2020	16:36	13:08	DPR RN-Φ Z-1 1.475 KM	Breaker not installed.	After Clearance from AEE/TL (Clearing & Washing of Disc Insulators of Tower# 232 & 253). Line energised.
156	132kv Verpal Tarn Taran	14.480	8/6/2020	22:50	6.8.20	23:42	00:52	Master Trip 86	Master Trip 86	Due to some Transient fault
157	132 KV Moga- Dhalleke	14	06-08-2020	3:53	06-08-2020	4:11	0:18	DPR B-Φ Z-1 2.3 10.2 KM	Breaker not installed at dhalleke.	Transient Fault
158	132 KV Moga- Panigrain Kalan	31.5	08-08-2020	7:57	08-08-2020	20:29	12:32	DPR RN-Φ Z-1 6.103 KM	Breaker not installed.	Replacement of Disc Insulators of Tower No.265, R-phase.
159	132 KV Malout-Abohar line	29.64	8/10/2020	6:01	8/10/2020	6:11	0:10	E/F B PH, Z-1, 5.561 KM	Breaker NOT available	Transient Fault , Try Taken after permission from pc patiala
160	132 KV Malout-Abohar line	29.64	8/10/2020	14:32	8/10/2020	15:02	0:30	E/F B PH, Z-1, 3.427 KM	Breaker NOT available	Transient Fault , Try Taken after permission from pc patiala
161	220 KV Ferozepur Line - Sadiq	37.70	8/11/2020	18:55	12.08.2020	20:37	25:42	DPR I - YB phase Zone location 16.38 km; at 19:30 after try, RYB Phase Zone-1	No tripping	Due to conductor breakdown at Tower No. 121 B Phase, try taken at 19:30 by taking permission from PC Patiala but line didn't hold.
162	220 KV Sadiq -Kotkaror Line	37.4	8/11/2020	18:54	11.08.2020	19:25	0:31	O/C Y Phase	No tripping	Transient fault line energised by taking permission from PC Patiala from 220 KV Sadig end.

225

163	220 kV Mukatsar Sahib- Sadiq Line	37.00	8/11/2020	18:54	11.08.2020	21:55	3:01	Zone-II RYB Phase - Master Trip	Birding at Mukatsar Sahib end & breakdown of B Phase 121 Tower of 220 kV Sadiq-Ferozepur Line
164	132 kV Ferozeshah - Mania Singh Wala Line	10	8/11/2020	18:53	8/11/2020	19:55	1:02	Master Trip, L 2T, IP >2T	Transient fault, Lines energised by taking permission from PC Patiala
165	132 kV Ferozeshah-Kolkaror Line	18.6	8/11/2020	18:46	8/11/2020	19:43	0:57	Master Trip, L 2T, IP >2T	Transient fault, Lines energised by taking permission from PC Patiala
166	132 KV Moga- Gholian Kalan	15	12-08-2020	5:35	12-08-2020	6:43	3:08	DPR R-&Phi 21.2.3 ON	Due to tree branches
167	132 KV IGC- GNDTP Bathinda Line	16.76	8/12/2020	20:33	8/12/2020	20:57	0:24	Dir. O/C R-Phase	66 KV IGC , 66 KV Kotshamir also tripped at same time
168	132 KV Maur-IGC Bathinda Line	32.87	8/12/2020	20:33	8/12/2020	21:31	0:58	DPR(L=29.28KM, Zone -2, Trip phase ABC, Started phase -AN	Transient fault. The line was charged with approval of PC Patiala
169	132 kV Mania Singh Wala - Ferozeshah Line	10	8/12/2020	9:27	8/12/2020	9:37	0:10	B-Phase O/C Relay	Due to Overload. All supply of 220 kV S/S Ferozepur was fed from 220 kV S/S. Kothkror via 132 kV Ferozeshah-Mana Singh Wala and 132 kV Mana Singh Wala- Ferozepur line due to fault of 220 kV Sadiq line
170	132 KV Malout-Abonar line	29.64	8/12/2020	5:38	8/12/2020	5:50	0:12	E/F R PH, Z-1, 15.13 KM	Breaker NOT available Transient Fault, Try Taken after permission from pc patiala
171	132 KV Swadhi -Moga	42.000	8/12/2020	19:15	12.0.2020	20:25	0:1:10	RYB Phase 86, 1.6 Y Phase trip 38.7 KM KM Z-4	Temporary fault occurred due to flashover Disc insulators
172	132 KV Swadhi -Moga	42.000	8/12/2020	22.15	12.8.2020	22:35	0:0:20	RYB Phase 1.5 KM Y Phase 38.6 KM	Temporary fault occurred due to flashover Disc insulators
173	132 KV Swadhi -Jamaipur	38.000	8/12/2020	19.15	13.8.2020	16.17	21:02	Y Phase 86, 1.7 AB Phase E/F 35.1 KM KM	Red Phase Discs Burnt at Tower No 11/6/7
174	132kV Verpal Mall Mandi	11.650	8/13/2020	16.15	13.8.20	16.27	0:0:12	High set Master Trip 86	Due to some transient fault
175	132kv Mahipur-Banga Line	27.800	13-08-20	1.48	13//08/2020	2.02	0:0:14	B-Phase ZONE 1ST	BREAKER NOT TRIPPED
176	132kv Mahipur-Banga Line	27.800	13-08-20	3.20	13//08/2020	11.2	08:00	B-Phase, Zone-1, O/C+E/F B Phase,Z-1 D=9.310 KM	B-PHASE 2, NO SUSPECTED DISC INSULATORS REPLACED AT T. NO 06
177	132 KV Saraiwaga -Moga (KKP2)Line	28.5	8/14/2020	1.43	8/14/2020	1.50	0:07	Line is isolator controlled	Transient Fault

226

178	132 KV Sarainaga -Moga { KKP2}Line	28.5	8/14/2020	5:13	8/14/2020	5:25	0:12	O/C+E/F B Phase Z.	Line is isolator controlled	Transient Fault
179	132 KV Sarainaga -Moga { KKP2}Line	28.5	8/14/2020	23:50	8/14/2020	23:58	0:08	O/C+E/F B Phase Z-1,D=7.10 KM	Line is isolator controlled	Transient Fault
180	132 KV IGC- GNDTP Bathinda Line	16.76	8/14/2020	3:45	8/14/2020	4:18	0:33	DPR Zone-4 Dist -0.976 km (-5.186%) CA Phase	No Tripping	Maur line tripped from maur end at same time
181	132 KV Maur- IGC Bathinda Line	32.87	8/14/2020	3:45	8/14/2020	4:05	0:20	DPR(L=12.69KM, Zone -1, Trip phase ABC, Started phase -C,N, O/C B phase (1896A), E/F (2348A))	No Tripping	Transient fault, The line was charged with approval of PC Patiala
182	132 KV Maur-IGC Bathinda Line	32.87	8/14/2020	4:07	8/14/2020	4:17	0:10	DPR(L=0KM, Zone -1, Trip phase ABC, E/F (144 A))		Transient fault, The line was charged with approval of PC Patiala ( Breaker at 132 KV IGC Made on at 07:25 on 14.8.2020 )
183	132kv Verpal Hakima Gate Ckt 1	9.940	8/15/2020	10.40	15.8.20	13.65	0:3:15	O/C B Phase High Set E/F	Breaker not Tripped	Due to some transient fault
184	132kv Verpal Hakima Gate Ckt 2	9.940	8/15/2020	10.40	15.8.20	11.15	0:0:35	O/C B Phase High Set E/F	DPR ZONE 1 Master Trip 86 PSB	Due to some transient fault
185	132 KV Moga- Gholar Kalian	15	16-08-2020	1:24	16-08-2020	1:50	0:26	DPR R-Φ Z1, 6:1 KM	ON	Transient Fault After inspection of yard & approval of PC. Line energised.
186	132 Kv Ghulab- Shamspur - Sehia	17.713	8/17/2020	2.15	17.8.2020	2.31	0:0:16	Directional E/F O/C 86	Breaker NOT available	Temporary fault occurred due to flashover Disc insulators
187	132 KV Malout-Abohar line	29.54	8/18/2020	9:03	8/18/2020	9:13	0:10	E/F B PH, Z-1, 17.05 KM		Temporary fault occurred due to flash over disc insulators.
188	220 KV Ghulab- RTP	63.092	8/18/2020	12.02	18.8.2020	13.04	0:1:02	O/C R Phase Z-1 General Trip	O/C R Phase Z-1 8.2	Temporary fault occurred due to flash over disc insulators.
189	220 KV Doarah - PGCL	27.788	8/18/2020	12.10	18.8.2020	17.56	0:5:46	Main 1 & 2 DPR Operated, Z-1 RYB KM Phase	O/C R Phase Z-1 8.2	Temporary fault occurred due to flash over disc insulators.
190	220 Gaunsgarhi- RTP	77.071	8/18/2020	12.13	18.8.2020	13.20	0:1:07	Z-1, General Trip YB Phase 63.498 KM	Z-1 General Trip YB Phase 29.56 KM	Temporary fault occurred due to flash over disc insulators.
191	220 KV Sarnewal-Doraha Ckt-1	8.775	8/18/2020	14.01	18.8.2020	15.47	0:1:46	RYB Phase , SOTF Trip	O/C R Phase Z-1 8.2	Temporary fault occurred due to flash over disc insulators.
192	132 KV Muktsar-Kolkapura-1 Line	28.4	8/19/2020	12.33	8/19/2020	12.46	0:13	YPh, O/C, E/F	E/F	Transient Fault
193	132 KV Kolkapura 1-Moga Line	47.1	8/19/2020	12.33	8/19/2020	12.40	0:07	DPR zone 4 Yph O/C opid. 86 L- f 3.7031KM SOTF opid	-	Transient Fault , try taken after concerned with PC Patiala and SSE
194	220 KV Jagraon - Himmatsinghpur	47.5	8/19/2020	10.35	19.8.2020	10.58	0:0:23	Bus Bar Protection,LBB	Net Trip	Temporary fault occurred due to flash over disc insulators

227

C

195	132 KV Moga- Sosan	13.534	19-08-2020	6:00	19-08-2020	6:20	00:20	DPR BN-Φ Z1	ON	
196	220 KV G-1 - Ikdaha	1.8	8/21/2020	5:04	21.8-2020	5:45	00:41	REL670.B-Phase, Zone-1,2,3	On	Temporary fault occurred due to flashover Disc insulators
197	220 KV Ikdaha - Malerkotla	4.1	B/21/2020	5:04	21.8-2020	11.55	06:51	General Trip,B-Phase, Zone-1		Temporary fault occurred due to flash over disc insulators.
198	132 KV Moga- Panjgrain Kalan	31.5	22-08-2020	6:57	22-08-2020	7:05	00:08	DPR YN-Φ Z-1	Breaker not installed.	Temporary fault occurred due to flash over disc insulators.
199	132 KV IGC-GNDTP Bathinda Line	16.76	8/22/2020	2:22	8/22/2020	2:53	0:31	No Tripping	DPR RYB-Φ Z-2, L= 26.0 km	Transient Fault
200	132 KV Maur-IGC Bathinda Line	32.87	8/22/2020	2:22	8/22/2020	2:51	0:29	DPR (L=18.10KM, Zone-1, Trip phase ABC, Started phase -CN,		Maur line tripped from manu end at same time Transient fault The line was charged with approval of PC Patiala
201	132 KV Doreha-Bilaspur	9.506	8/23/2020	1:36	23.8-2020	1.58	00:22	Razia TN Z-2 & 3	-	Temporary fault occurred due to flashover Disc insulators
202	132 KV Bilaspur -Sihora	13.494	8/23/2020	1:36	23.8-2020	2:04	00:28	Directional O/C E/F , 86	-	Temporary fault occurred due to flashover Disc insulators
203	132 KV Mukatsar-Malout Line	32.5	B/27/2020	4.55	B/27/2020	5.05	0:10	BPh, O/C, E/F	BPh, O/C, E/F , Z-1, 1.098 km	Transient Fault
204	132 KV Mukatsar-Malout Line	32.5	B/27/2020	6.40	B/27/2020	6.52	0:12	BPh, O/C, E/F	BPh, O/C, E/F , Z-1, 1.024 km	Transient Fault
205	132 KV Moga- Panjgrain Kalan	31.5	28-08-2020	4:35	28-08-2020	5:52	1:17	DPR YN-Φ Z-1	Breaker not installed.	Due to rainy weather, Late Try Taken
206	132 KV Malout-Abhar line	29.64	B/28/2020	12:37	B/28/2020	12:47	0:10	E/F B phase, Z-1, 20.09 KM	Breaker NOT available	Transient Fault, Try Taken after permission from pc patiala
207	132Kv Pims-Science city	18.756,	28-08-2020	13.40	28.08.20	13.55	00:15	Not tripped	Dpr, RB phase,Z-1,Fl- 9.8km	The disc Insulators of R and B phase at T/w no.33 were found flashed due to which line was tripped and same were replaced with new disc insulators.
208	132 KV Swadhi - Jamalpur	38.000	B/30/2020	18.30	31.8-2020	14.30	20:00	B Phase ,E/F,Z- GF,Z-1,31.3 km		B-Phase Discs flashed at Tower no.16/2
209	132 KV Swadhi -Moga	42.000	B/30/2020	18.30	30.8-2020	18.55	00:25	Trip,CQ,no distance	CN Phase,no zone,45.4 km.	Temporary fault occurred due to flashover Disc insulators
210	132 KV Moga- Panjgrain Kalan	31.5	31-08-2020	9:37	31-08-2020	10:34	0:57	DPR RN-Φ Z-1	Breaker not installed.	Due to rainy weather, Late Try Taken
211	132 KV Moga- Gholian Kalan	1.5	02-09-2020	18.23	D2-09-2020	18:40	0:17	DPR R-Φ Z 7.7	Not Tripped	Transient Fault
212	220 KV Moga-Baghapurana Ckt-2	1.0	03-09-2020	18.58	04-09-2020	10:40	15:42	Main1 RN-Φ DPR ON		Due to tree fall on line
213	220 KV Baghapurana-Moga Ckt-1	1.0	03-09-2020	18.55	03-09-2020	19:14	0:19	Backup O/C+E/F	ON	Transient Fault
214	220 KV Line Bajakhan- Baghapurana Ckt 2	37.5	03-09-2020	18.59	03-09-2020	19.52	00:53	Main1 & Main2 AR ON Blocked		Temporary fault occurred due to flash over disc insulators.
215	132 KV Moga-Dhalleke	19.00	03-09-2020	18.55	03-09-2020	19:35	00:40	Master Trip	Breaker not installed at dhalleke.	Temporary fault occurred due to flash over Disc insulators

228

216	132Kv Kartarpur-Bees	27.00	03-09-20	12.10	03.09.20	13.10	01:00	Dpr, RN, Fi-0, 0km	Dpr, Master	The R phase clamp and jumper between Line isolator and R phase waverap at gantry Kartarpur sis were found damaged due to which line was tripped and same were replaced with new conductor.
217	132 KV Man Singh Wala - Ferozepur Line	11.6	9/4/2020	13:14	04.09.2020	14:20	01:06	DPR YN-phase Zone-1, 2, 8 km (24%) YN-phase	DPR YN-phase Zone-1, Location 5.6 km	Telephonic Message conveyed to AO TL 400 KV S/S Mastewal by concerned SSE & line energised as per directions from PC
218	132 KV Ferozeshah - Man Singh Wala Line	10	9/4/2020	13:12	04.09.2020	16:50	3:38	Master Trip, L, 2T, IP>2T	Master trip	Telephonic Message conveyed to AO TL 400 KV S/S Mastewal by concerned SSE & line energised as per directions from PC
219	132 KV Ferozeshah-Kotkror Line	18.6	9/4/2020	13:14	04.09.2020	14:10	0:56	O/C RYB Phase Highest	L2T, I>2T E/F	Telephonic Message conveyed to AO TL 400 KV S/S Mastewal by concerned SSE & line energised as per directions from PC
220	132 KV RTP - GACL	4.003	04/09/20	18.05	04.09.20	19.11	01:06	67 N, earth fault	Not tripped	As per relay indications, patrolling is done from tower no 01-11 and all jumpers, suspension clamps , tension fittings, nut bolts and clearances found ok. Line charged with the permission of PC Patiala
221	132 KV Saranaga-Moga(Till) kkp2) Line	28.5	9/5/2020	14:49	9/5/2020	14:57	00:08	O/C+E/F B Phase,Z, 2,D=23.39KM	line is isolator controlled Transient Fault Take try after concerned with SSE	
222	132 KV Saranaga-Moga(Till) kkp2) Line	28.5	9/5/2020	20:40	9/5/2020	20:45	00:05	O/C+E/F B Phase,Z, 2,D=23.38KM	line is isolator controlled Transient Fault Take try after concerned with SSE	
223	132 KV Ferozpur- Faridkot Line	41	9/5/2020	14:28	9/5/2020	20:40	6:12	DPR RN-phase, Zone-1, Location 26 km	Isolator control, No breaker	Due to damaged discs at Tower No. 07 (R-phase)
224	132 kv Doraha-Bilaspur	9.506	9/5/2020	15:48	5.9/2020	16:10	00:22	DPR,Raab,E/F,20 - ne-2, Zone-3		Temporary fault occurred due to flash over Disc insulators
225	132 KV Moga- Panigrain Kalan	31.5	06-09-2020	6.04	06-09-2020	6:14	0:10	DPR YN-Φ Z-1 22.744 KM	Breaker not installed,	Transient Fault
226	132 KV Saranaga-Moga( Till kkp2) line	28.5	9/6/2020	7:50	9/6/2020	7:58	00:08	O/C+E/F B Phase,Z, 2,D=23.35KM	line is isolator controlled Transient Fault Take try after concerned with SSE	
227	132 KV HAMIRPUR-CHOHAL	6.65	06-09-20	10.30	06/09/2020	12.02	01:32	O/C B-PHASE E/F	B-PHASE ZONE 1ST	(Flash over tempacrey fault& traicent fault)

229

228	132 KV S/S Nakkian - Ropar	33.935	9/11/2020	17.07	11.09.20	17.27	00:20	Not tripped	R phase,zone-1,21.5 Km	As per relay indications.
229	132 KV S/S Nakkian - Nakkian Power House	1.365	9/11/2020	17.07	11.09.20	17.32	00:25	Not tripped	R phase,zone-1,10.8 Km	As per relay indications. patrolling is done from tower no 20-46 and found that at tower no 25 R and Y phase 4-4 disc insulators got flashed due to birdage.
230	132 KV Tarn Taran-Verpal	14.480	9/14/2020	5.05	14.9.20	5.30	00:25	E/F DMT 86	E/F , Highset	Due to Transient Fault
231	132 KV Verpal-Mall Mandi	11.650	9/14/2020	5.01	16.9.20	1.10	44:09	B Phase High Set E/F	Breaker Not Tripped	Due to B phase Conductor broken between Tower no. 9 and 10 & tower no 9 cross arm bent.
232	132 KV Man Singh Wala - Ferozepur Line	11.6	9/15/2020	4:10	15.09.2020	4:45	0:35	DPR BN phase, Zone 1 location 2.3 km (20%), Trip ABC	DPR RYN PHASE, ZONE 1 Location 6.3 km,	Transient Fault, Line-energised after taking permission from PC Partial
233	132 KV Ferozeshah - Man Singh Wala Line	10	9/15/2020	4:10	15.09.2020	4:50	0:40	Y phase O/C	E/F relay Y phase L2T, Ip>2T	Energized after taking permission from pc & AO TL mastewal
234	132 KV Ferozeshah-Kotkror Line	18.6	9/15/2020	4:10	15.09.2020	4:58	0:48	R phase Highset	R phase O/C L2T, Ip>2T	Energized after taking permission from pc & AO TL mastewal
235	220 KV G-2 -Ganguwal	74.000	9/15/2020	18.35	15.9.2020	19.43	01:08	REL-670 Main-1,RYB-Phase, Z-4	ON	Temporary fault occurred due to flash over disc insulators.
236	220 KV G-2 -Bhati	12.023	9/15/2020	18.35	15.9.2020	19.45	01:10	Micom REL-670,RYB-Phase	ON	Temporary fault occurred due to flash over disc insulators.
237	220 KV G-2 -G-3	3.990	9/15/2020	18.35	15.9.2020	22.03	03:28	Directional E/F Tripping relay operated.	OFF	Accident Between tower no. 225 to 226
238	132 Kv Ghulal-Shamspur - Sehe	17.713	9/15/2020	13.15	15.9.2020	13.27	00:12	Directional E/F	-	Temporary fault occurred due to flashover Disc insulators.
239	132 KV Saranaga-Moga( TII Kp2) Line	28.5	9/16/2020	5.54	9/16/2020	6.01	00:07	O/C+E/F B Phase,Z-	Line is isolator controlled	Transient Fault take try after concerned with SSE
240	132Kv BBMB Jai-Dhillwan	37.00	17-09-20	13.17	17.09.20	13.24	00:07	1,D=17.11 KM Dpr, RN Z-1 FI- 16.2km	Not tripped.	There was a bird nest with metal wire on R phase cross at tw no. 267, line was tripped and same was cleared from the line.
241	132 KV Malout-Muktsar	32.5	9/19/2020	7.58	9/19/2020	8:25	0:27	E/F O/C R PH, Z-1, 0.30762 KM	E/F O/C R PH, Z-2, 28.7 KM	Transient Fault , Try Taken after permission from pc partiala

230

242	132 KV Ferozpur- Faridkot Line	4.1	9/19/2020	9:16	9/19/2020	9:30	0:14	DPR RN-Phase Zone-2, Location 38.4 km	Isolator control; No breaker	Transient Fault , Line-energised after taking permission from PC Patiala, AO TL & concerned SSE
243	132Kv BBM/B Jal-Dhiliwan	37.00	19-09-20	12.48	19.09.20	12.58	00:10	Dpr BN-Z-1,Fl- 16.50km	Not tripped.	The disc Insulators of B phase at Tw no.254 were found flashed due to which line was tripped and same were replaced with new disc insulators.
244	132 KV Swadhi -Moga	42.000	9/20/2020	20.45	20.9.2020	21.10	00:25	RYB -Phase ,Trip 1.84 KM Y-Phase,E/F ,Zone-8GF .Zone=2, 37.4 km	Y-Phase,36.61 KM	Temporary fault occurred due to flashover Disc insulators R-Phase Discs Flashed at tower no.1167
245	132 KV Swadhi -Jamalpur	38.000	9/20/2020	20.45	21.9.2020	13.00	16:15	Y-Phase,E/F ,Zone-1, 1.6 KM	-	R-Phase Discs Flashed at tower no.1167
246	132 kv Dohra-Bilaspur	9.506	9/21/2020	11.11	21.9.2020	11.57	0:46	ON	-	Supply Fail at Jamalpur end
247	132 Kv Ghulai- Jamalpur ckt-1	21.00	9/21/2020	11.11	21.9.2020	16.30	07:19	ON	E/F,O/C,R-Phase , Zone-1	Temporary fault occurred due to flashover Disc insulators
248	132 Kv Ghulai- Jamalpur ckt-2	21.00	9/21/2020	11.11	21.9.2020	19.01	07:50	ON	E/F,O/C,R-Phase , Zone-1	R-Phase Discs Flashed at tower no.309
249	132KV Batala-Kathungal	22.000	9/23/2020	11.42	23.9.20	11.50	0:08	O/C, Blue Phase 86	Breaker Not Tripped	Due to Transient Fault
250	132KV Civililine-Power Colony	2.600	9/23/2020	11.40	23.9.20	11.45	0:06	Dir, E/F Master Trip	Breaker Not Tripped	Due to Transient Fault
251	132 KV Balluana-Bathinda	14.15	9/23/2020	22:46	9/23/2020	22:55	0:09	DPR Z-1,O/C B- PHASE, 10.9 KM	-	DUE TO TRIPPING OF 132 KV LINE/After Permission sse Try Taken
252	132 Kv Balluana-Gidderbaha	19.15	9/23/2020	22.46	9/23/2020	23:05	0:19	DPR Z-1,O/C C-PH DPR Z-1 CN 12.0 KM63%	-	Transient Fault ,After Permission PC,Patiala and sse Try Taken
253	132 KV Malout-Muktsar	32.5	9/23/2020	0.57	9/23/2020	10.50	8:53	YPh, O/C, E/F, Z-2, 28.1 KM 0.546 km	YPh, O/C, E/F , Z-1, 8.2 km	TAKE TRY AFTER CLEARANCE CERTIFICATE GIVEN BY AOTL MKT. DAMAGED DISC STRING CHANGED OF Y- Ph AT RAIL POLE NO. 301
254	132Kv Khera mandi-Sultanganpur	12.00	24-09-20	12.10,	24.09.20	22.45	10:35	Not tripped.	Dpr, B phase,Z-2,Fl- 8.2km	Due to breakdown of B phase conductor between tower span no.49-50, line was tripped and same was attended.
255	132 KV S/S Nakkian - Nakkian Power House	1.365	9/24/2020	9.11	24.09.20	9.24	00:13	R phase,Earth fault,10.944 KM	An phase,21.5 KM zone-1	As per relay indications, patrolling is done from tower no 38-57 and found that at Tower No 54 R phase 02 No Disc insulators got flashed due to bridge
256	132 KV Moga- Panigrain Kalan	31.5	25-09-2020	3:54	25-09-2020	4:26	0:32	DPR BN-Φ Z-1 27.793 KM	Breaker not installed.	Transient Fault
257	132 KV Moga-Gholian Kalan	15	29-09-2020	16:52	29-09-2020	17.01	00:09	DPR RN-Φ Z-1 6.1 KM & E/F	Not Tripped	Transient Fault

231

231 A

258	132 KV Moga-Gholian Kalan	15	29-09-2020	17:01	30-09-2020	8:30	15:29	DPR RN-Φ Z-1 6:0 KM & E/F	Not Tripped	R-Φ disc insulator found flashed at Tower #21.
259	132 KV Moga-Panjgrain Kalan	31.5	29-09-2020	2:20	29-09-2020	2:43 *	0:23	DPR BN-Φ Z-1 19.86 KM	Breaker not installed.	Transient Fault
260	132KV Verpal-Hakima Gate Ckt-1	9.940	9/30/2020	1.50	30.9.20	2.20	00:30	Y Phase O/C, E/F Highset	Breaker Not Tripped	Due to Transient Fault
261	132KV Verpal-Hakima Gate Ckt-2	9.940	9/30/2020	1.50	30.9.20	2.25	00:35	Y Phase O/C, E/F ON DPR Y Phase 86 Highset	ON DPR Y Phase 86	Due to Transient Fault
262	132KV Civiline-Power Colony	2.600	9/30/2020	10.26	30.9.20	10.39	00:13	O/C, Blue Phase 86	Breaker Not Tripped	Due to Transient Fault
263	132KV Civiline-Naraingarh	11.570	9/30/2020	10.26	30.9.20	12.30	02:04	Blue Phase O/C, 86	Breaker Not Tripped	Due to Transient Fault
264	132KV Batala-Kathunangal	22.000	9/30/2020	10.25	30.9.20	10.30	00:05	O/C, Blue Phase 86	Breaker Not Tripped	Due to Transient Fault
265	132 Kv Ghulai, Shamspur - Sehe	17.713	9/30/2020	9.50	30.9.2020	14.10	04:20	Directional E/F .Trip	-	Temporary fault occurred due to flashover Disc insulators