

PUNJAB STATE TRANSMISSION CORPORATION LIMITED Regd. Office :- PSEB Head Office, The Mall, Patiala – 147001, Punjab, India O/o SE/Planning, PSTCL, Patiala

Fax/Ph:- 0175-2205502, Email:- <u>se-planning@pstcl.org</u> CIN-U40109PB2010SGCO33814

Amendment No: 22/2024-25

To

- 1) Dy. CE/TS (Design), PSTCL, Patiala.
- 2) Dy. CE /Grid Construction, PSTCL, Ludhiana.
- 3) Dy. CE /TLSC, PSTCL, Patiala.
- 4) SE /Civil Works, PSTCL, Patiala.

Memo No.454/57/P-2/70A/149 Dated: 12.11.2024

Subject: Regarding planning of 1 No. 66 kV line bay at 220 kV S/s Saidpura for new 66 kV S/s Bhagwanpura.

The scope of work is planned as following:

| Sr. No. | Name of Substation | Scope of Work | Est. Cost | Remarks |
|---------|--|--|---------------|---|
| 1. | 220 kV S/Stn. Saidpura (Dera Bassi) | 1 no. new 66 kV line bay at 220 kV S/Stn. Saidpura (Dera Bassi) for new 66 kV S/s Bhagwanpura | 57.27 lacs | 1. This work is being planned on the basis of Amendment No. 39/2023-24 dated 18/10/24 issued by PSPCL. 2. Work is being planned as per the confirmation of space availability by ASE/ P&M Division, PSTCL, Mohali vide his office mail dated 19.09.2024, Sr. Xen/TS(V), PSTCL, Patiala vide memo no.1820 dated 21.10.2024, Sr. Xen /Grid Construction, PSTCL, Patiala vide memo no. 3629 dated 14.10.2024 and Sr.Xen/Civil Works Division, PSTCL, Mohali vide memo no.2080 dated 25.09.2024. 3. Estimated cost has been considered as per cost data 2024-25 as furnished by O/o TS (D). 4. The expenditure shall be charged to the head "Additional 220/132/66 kV line bays", Sr. No. 70 of Annexure-3 of MYT 2023-26 as per provision of Approved Capital Investment Plan for the year 2023-24. Expenditure allocated upto March 25: Rs. 23.8 Crore. Expenditure already booked via amendments till date: 6.5 Crore Expenditure to be booked for this amendment: Rs.0.72 Crore (including EC & IDC) Balance expenditure for the control period: Rs. 16.58 Crore 5.This work shall be included in the 3rd MYT 2023-26 6.The work is subject to the ratification by the BoDs. |

Dated: 12.11.2024

This issues with the approval of the Director/Technical of PSTCL.

ASE/Planning-2 PSTCL, Patiala.

CC: - 458/64/ P-2/70A/149

- 1. Director/Technical, PSTCL, Patiala.
- 2. Engineer in Chief /TS, PSTCL, Patiala.
- 3. Chief Engineer/Planning, PSPCL, Patiala.
- 4. Chief Engineer/P&M, PSTCL, Ludhiana.
- 5. Chief Engineer/P&M, PSPCL, Ludhiana.
- 6. Dy. CE/Transmission Planning, PSPCL, Patiala.
- 7. Dy. CE /P&M Circle, PSTCL, Patiala.